MASSACHUSETTS BOARD OF CERTIFICATION
OF WASTEWATER TREATMENT PLANT OPERATORS

FACILITY GRADING REPORT

FACILITY NAME: BASF Bioresearch Corporation		FILE NO. 067B94
STREET ADDRESS: 100 Research Drive		
CITY/TOWN: Worcester	STATE: MA	ZIP: 01605-4314
TELEPHONE: 508-849-2558		DEP REGION: CERO
CONTACT NAME AND TITLE: Kenny J. Hartung, Safety & Ecology Specialist		
DISCHARGE PERMIT NUMBERS NPDES NO. MA NO. GW NO. SEWER CONNECTION PERMIT NO. UBWPCD # 758		
DATE RECEIVED: 5-12-94		
RATING RESULTS DATE RATED: 6-13-94 DATE BOARD APPROVED: 6-16-94		
RATED BY: John J. Jonasch, Certification Program, DEP Training Center		

INDUSTRIAL OR MUNICIPAL:	Industrial
RATING TOTAL:	4
GRADE:	1

Class	Cumulative Rating Value
Class 1 (M or I)	1-7
Class 2 (M or I)	8-20
Class 3 (M or I)	21-30
Class 4 (M or I)	31-50
Class 5	51-65
Class 6	66-80
Class 7	81 or more

RATING VALUES FOR CLASSIFICATION OF FACILITIES

UNIT	RATING	SCORE
pH Neutralization System	3-4	4

$$* \text{ BOD Removal Rating} = \frac{\text{Design BOD in Pounds/Day x "f"}}{1000}$$

"f" = 0.3 for primary treatment and 0.8 for secondary or higher facilities.