

Individual Groundwater Discharge Permit
Fact Sheet

I. APPLICANT, FACILITY INFORMATION, and DISCHARGE LOCATION

Name and Address of Applicant:

Town of Lynnfield, Public Works, 55 Summer Street,
Lynnfield, MA 01940

Name and Address of Facility where discharge occurs:

Lynnfield High School, 275 Essex Street, Lynnfield, MA

Discharge Information:

Groundwater Discharge Permit Number: 722-2

The Groundwater Discharge Permit will allow the applicant to discharge **12,980** gallons per day of treated sanitary wastewater from the **Lynnfield High School** to groundwaters of the Commonwealth not located in a sensitive area.

II. LIMITATIONS AND CONDITIONS

Discharge permit limitations are as listed in the ground water permit and are in conformance with 314 CMR 5.00, the Groundwater Discharge Permit Program.

III. PERMIT BASIS AND EXPLANATION OF EFFLUENT LIMITATIONS

An Individual Groundwater Discharge permit is required for this discharge in accordance with the Massachusetts Clean Water Act, M.G.L. c. 21, s. 26-53 and 314 CMR 5.03.

Effluent limitations are based upon the location of the discharge, the level of treatment, consideration of human health protection criteria and protection of the groundwaters of the Commonwealth. Based on the request of the Permittee, and review by MassDEP, the fecal Coliform effluent limit has been removed from the permit. Subsequent to the Permittee's permit renewal application, the school constructed two projects on or around the wastewater treatment plant facilities that have violated and/or impacted the facility's Groundwater permit requirements. As such, the Permittee is required to address and correct these issues as part of their permit renewal. The Reserve Soil Absorption System (SAS) impacted by the parking lot extension project is to be relocated as approved by MassDEP. A revised Groundwater Monitoring Well Plan shall be submitted for MassDEP review and approval to mitigate impacts from the rebuilt athletic fields and

This information is available in alternate format. Call Donald M. Gomes, ADA Coordinator at 617-556-1057. TDD# 1-866-539-7622 or 1-617-574-6868.

MassDEP on the World Wide Web: <http://www.mass.gov/dep>

 Printed on Recycled Paper

under drain systems. Lastly, student parking over access covers and hatches impedes and/or prevents access to wastewater treatment plant processes. The Permittee is to submit a plan for MassDEP review and approval to ensure free and clear access to treatment processes.

IV. COMMENT PERIOD, HEARING REQUESTS, AND PROCEDURES FOR FINAL DECISIONS

The public comment period for this permit is thirty (30) days following public notice in *The Environmental Monitor*. The public notice for this Individual Groundwater Discharge Permit occurred on [DATE].

Requests for an adjudicatory hearing must be submitted within thirty (30) days of the issuance/denial of the permit, by any person who is aggrieved by such issuance/denial.

A final decision on the issuance/denial of this permit will be made after the public notice period, and review of any comments received during this period.

V. STATE CONTACT INFORMATION

Additional information concerning the draft permit may be obtained between the hours of 9:00 a.m. and 5:00 p.m. Monday through Friday excluding holidays, from:

Joseph Nerden
MassDEP - NERO
205B Lowell Street
Wilmington, MA 01887
978-694-3239
Joseph.Nerden@state.ma.us

Kevin Brander, P.E.
Section Chief
Wastewater Management Program

DATE