



Massachusetts Department of Environmental Protection
Source Water Assessment and Protection (SWAP) Report
for
Tewksbury Water Division

What is SWAP?

The Source Water Assessment and Protection (SWAP) Program, established under the federal Safe Drinking Water Act, requires every state to:

- inventory land uses within the recharge areas of all public water supply sources;
- assess the susceptibility of drinking water sources to contamination from these land uses; and
- publicize the results to provide support for improved protection.

Susceptibility and Water Quality

Susceptibility is a measure of a water supply's potential to become contaminated due to land uses and activities within its recharge area.

A source's susceptibility to contamination does *not* imply poor water quality.

Water suppliers protect drinking water by monitoring for more than 100 chemicals, disinfecting, filtering, or treating water supplies, and using source protection measures to ensure that safe water is delivered to the tap.

Actual water quality is best reflected by the results of regular water tests. To learn more about your water quality, refer to your water supplier's annual Consumer Confidence Reports.

Table 1: Public Water System Information

<i>PWS Name</i>	Tewksbury Water Division
<i>PWS Address</i>	71 Merrimack Drive
<i>City/Town</i>	Tewksbury, Massachusetts 01876-1070
<i>PWS ID Number</i>	3295000
<i>Local Contact</i>	Lewis Zediana
<i>Phone Number</i>	(978) 858-0345

Introduction

We are all concerned about the quality of the water we drink. Public wells, reservoirs and rivers may be threatened by potential contaminant sources, including storm runoff, spills, and improper disposal of hazardous materials. Citizens, businesses and local officials can work together to better protect these drinking water sources.

Purpose of this report:


This report is a planning tool to support local and state efforts to improve water supply protection. By identifying land uses within water supply protection areas that may be potential sources of contamination, the assessment helps focus protection efforts on appropriate best management practices (BMPs) and drinking water source protection measures.

This report includes the following sections:

1. Description of the Water System
2. Land Uses in the Watershed
3. Source Water Protection
4. Emergency Planning Recommendations
5. Additional Resources Available for Source Water Protection
6. Appendices

What is a Watershed?

A watershed is the land area that catches and drains rainwater down-slope into a river, lake or reservoir. As water travels down from the watershed area it may carry contaminants from the watershed to the drinking water supply source. For protection purposes, watersheds are divided into protection Zones A, B and C.



Section 1: Description of the Water System

<i>Source Name</i>	<i>Source ID</i>	<i>Susceptibility</i>
Merrimack River	3295000-01S	High

The Tewksbury Water Division (Tewksbury) withdraws water from the Merrimack River to supply drinking water to the community of Tewksbury. The Massachusetts Surface Water Quality Standards classify the Merrimack River as a Class B waterway. That means that the water withdrawn for drinking water purposes must be treated.

For current information on monitoring results and treatment or for a copy of the most recent Consumer Confidence Report, please contact the public water system contact person listed above in Table 1. Drinking water monitoring data is also available on the web at <http://www.epa.gov/safewater/ccr1.html>.

Merrimack River Watershed

The Merrimack River flows for 78 miles through New Hampshire and for another 50 miles in Massachusetts, from Lowell to Newburyport and into the Atlantic Ocean. There are 1,200 square miles of watershed in Massachusetts in all or part of 24 communities. Upstream of the Tewksbury drinking water intake, the following communities are in the Merrimack River watershed: Dracut; Lowell; Chelmsford; Tyngsborough; Westford; Dunstable; Groton; Ayer; Littleton; Harvard; Boxborough; Ashby; and, Ashburnham. Sixteen percent

(16%) of the watershed in Massachusetts upstream of the Tewksbury intake is listed in DEP's Geographic Information System (GIS) databases as protected open space. The other 84% contains a mix of land uses such as residential homes, shopping malls, businesses, industrial processes, transportation corridors, agriculture, utility lines and recreation facilities.

Class B Drinking Water Sources

There are twelve Class B drinking water sources on rivers in Massachusetts, eleven in the urbanized northeast and one in the western part of the State. Five of these sources are located on the Merrimack River. The large watersheds and historically urbanized land uses associated with major rivers makes source protection a challenge at the Class B sources.

A Class B water body source such as the Merrimack River does not have Zone A, B and C protection areas, as do Class A water body sources. For the purposes of the SWAP assessments, a 400 foot setback area along the river and all feeder streams has been delineated for Class B water body sources that is referred to as an "Emergency Planning

Class B River Intakes

Class B water sources do not have Zone A, B and C protection areas as the Class A sources do. For the purposes of this report, an "Emergency Planning Zone" has been delineated. The **Emergency Planning Zone** is the land area within 400 feet of both sides of the river including all tributary streams and surface water bodies.

Zone". Land uses and activities within this zone are of particular concern for source protection and emergency planning because of their proximity to the water supply.

River drinking water sources are particularly susceptible to spills and accidental releases from public and private discharges; accidents related to vehicles, railroads, airports, boats; utility easements; fixed site releases at industrial and public facilities; inappropriate use of pesticides and fertilizers; improper disposal of hazardous household waste; and illegal dumping of a variety of substances.

This assessment has been conducted on the watershed area upstream of the Tewksbury Water Division intake to the state boundary. Potential threats that have been identified in New Hampshire have also been included. In addition, DEP has delineated a 400-foot emergency planning zone (shown on the GIS map that accompanies this report) adjacent to the river and its tributaries, up to the state boundary, for the purpose of this assessment.

This report contains a list of regulated facilities that are located within the watershed. Page 11 of this report contains recommendations for emergency planning.

Section 2: Land Uses in the Protection Areas

The protection area for Tewksbury is a mixture primarily of residential, commercial, industrial, and forest land uses (refer to attached map for details). Land uses and activities that are potential sources of contamination are listed in Table 2.

Key Land Uses and Protection Issues Include:

1. Activities in Emergency Planning Zone
2. Agricultural Activities
3. Hazardous Materials Manufacture, Storage and Use
4. Transportation Corridors
5. Stormwater Flows
6. Railroad Tracks
7. Transmission Lines
8. Combined Sewer Overflows
9. Recreation (beaches, campgrounds, boating)
10. Golf Courses
11. Road and Maintenance Depots
12. Federal Superfund Site and Oil or Hazardous Material Contamination Sites
13. Residential

1. Activities in Emergency Planning Zone - The Emergency Planning Zone is a 400 foot setback on either side of the river and all tributaries to a Class B river intake. Land use activities within an Emergency Planning Zone may have an impact on surface water sources. Wild animals and domestic pet wastes can carry waterborne diseases such as Giardia, Cryptosporidium, Salmonella, etc. while septic systems and road runoff can carry these as well as other contaminants.

Emergency Planning Zone Recommendations:

Work with communities within the Merrimack watershed to:

- ✓ Monitor and review activities within the Emergency Planning Zone.

2. Agricultural Activities – Agricultural land uses, cropland and pastures, comprise about 5% of the watershed. Pesticides and fertilizers have the potential to contaminate a drinking water source if improperly stored, applied, or disposed. If managed improperly, underground and aboveground storage tanks (USTs and ASTs) can be potential sources of contamination due to leaks or spills. Agricultural activities can also be a potential source of microbial contamination from improper manure management.

Agricultural Recommendations:

Work with communities within the Merrimack watershed to:

- ✓ Work with farmers to make them aware of the water supply and to encourage the use of a U.S. Natural Resources Conservation Service (NRCS) farm plan to protect water supplies.
- ✓ The Massachusetts Department of Food & Agriculture's booklet titled "On-Farm Strategies to Protect Water Quality - An Assessment & Planning Tool for Best Management Practices" (December 1996) describes technical and financial assistance programs related to the control of erosion and to the management of nutrients, pests, manure, grazing and irrigation.
- ✓ Work with farmers to ensure that pesticides, fertilizers and manure are being stored within a structure designed to prevent runoff.

What are BMPs?

Best Management Practices (BMPs) are measures that are used to protect and improve surface water and groundwater quality. BMPs can be structural, such as oil & grease trap catch basins, nonstructural, such as hazardous waste collection days or managerial, such as employee training on proper disposal procedures.

Benefits of Source Protection

Source Protection helps protect public health and is also good for fiscal fitness:

- Protects drinking water quality at the source
- Reduces monitoring costs through the DEP Waiver Program
- Treatment can be reduced or avoided entirely, saving treatment costs
- Prevents costly contamination clean-up
- Preventing contamination saves costs on water purchases, and expensive new source development

Contact your regional DEP office for more information on Source Protection and the Waiver Program.

3. Chemical and Hazardous Materials Manufacture, Storage and Use – Many large and small businesses use hazardous materials, produce hazardous waste products, and/or store large quantities of hazardous materials in USTs and ASTs. Although many facilities within the watershed use best management practices (BMPs), hazardous materials and waste can be unexpectedly released through spills, leaks or improper handling or storage, and become potential sources of contamination. Hazardous materials should never be disposed of to a septic system or floor drain leading directly to the ground.

Hazardous Materials Storage and Use Recommendations:

Work with communities within the Merrimack watershed to:

- ✓ Educate local businesses on BMPs for protecting water supplies, and encourage them to use BMPs for handling, storing and disposing of hazardous waste. Distribute the fact sheet “Businesses Protect Drinking Water” available in Appendix A and on www.mass.gov/dep/brp/dws/protect.htm, which provides BMPs for common business issues.
- ✓ Work with local businesses to register those facilities that are unregistered generators of hazardous waste or waste oil. Partnerships between businesses, water suppliers, and communities enhance successful public drinking water protection practices.
- ✓ Educate local businesses on Massachusetts floor drain requirements. See brochure “Industrial Floor Drains” for more information.
- ✓ Monitor water quality in the Merrimack River.
- ✓ Continue to plan and prepare for spills by communicating with facilities and conducting drills.

4. Transportation Corridors - Route 3, Route 495 and other paved and unpaved local roads and highways cross through the watershed. Spills from vehicular accidents are a major concern. In addition, roadway construction, maintenance, and typical highway use can all be potential sources of contamination. Accidents can lead to spills of gasoline and other potentially dangerous transported chemicals. Roadways are frequent sites for illegal dumping of hazardous or other potentially harmful wastes. (Continued on page 7)

**When you fertilize the lawn,
Remember
you're not *just* fertilizing the lawn.**



It's hard to imagine that a green, flourishing lawn could pose a threat to the environment, but the fertilizers you apply to your lawn are potential pollutants! If applied improperly or in excess, fertilizer can be washed off your property and end up in lakes and streams. This causes algae to grow, which uses up oxygen that fish need to survive. So if you fertilize, please follow directions and use sparingly.

The Massachusetts Department of Environmental Protection, One Winter Street, Boston, MA 02108




Figure 1: Sample watershed with examples of potential sources of contamination

Potential Source of Contamination vs. Actual Contamination

The activities listed in Table 2 are those that typically use, produce, or store contaminants of concern, which, if managed improperly, are potential sources of contamination (PSC).

It is important to understand that a release may never occur from the potential source of contamination provided facilities are using best management practices (BMPs). If BMPs are in place, the actual risk may be lower than the threat ranking identified in Table 2. Many potential sources of contamination are regulated at the federal, state and/or local levels, to further reduce the risk.

Table 2: Land Uses in the Watershed

For more information, refer to Appendix B: Regulated Facilities.

Land Uses	Quantity	Threat	Potential Sources of Contamination*
Agricultural			
Fertilizer Storage or Use	Few	M	Leaks, spills, improper handling, or over-application of fertilizers
Pesticide Storage or Use	Few	H	Leaks, spills, improper handling, or over-application of pesticides
Commercial			
Body Shops	2	H	Improper management of vehicle paints, solvents, and primer products
Gas Stations	6	H	Spills, leaks, or improper handling or storage of automotive fluids and fuels
Service Stations/ Auto Repair Shops	5	H	Spills, leaks, or improper handling of automotive fluids, and solvents
Bus and Truck Terminals	2	H	Spills, leaks, or improper handling of fuels and maintenance chemicals
Car/Truck/Bus Washes	1	L	Improper management of vehicle wash water; soaps; oils; greases; metals; salts
Cemeteries	Few	M	Leaks, spills, improper handling, or over-application of pesticides; historic embalming fluids (such as arsenic)
Dry Cleaners	1	H	Spills, leaks, or improper handling of solvents and wastes
Funeral Homes	Few	L	Spills, leaks, or improper handling of hazardous chemicals
Furniture Stripping and Refinishing	1	H	Spills, leaks, or improper handling of hazardous chemicals
Golf Courses	6	M	Over-application or improper handling of fertilizers or pesticides
Printer and Blueprint Shops	1	M	Spills, leaks, or improper handling or storage of printing inks and chemicals
Railroad Tracks and Yards	3	H	Over-application or improper handling of herbicides, leaks or spills of transported chemicals and maintenance chemicals; fuel storage
Sand and Gravel Mining/ Washing	Few	M	Spills or leaks from heavy equipment, fuel storage, clandestine dumping
Industrial			
Asphalt, Coal Tar, and Concrete Plants	1	M	Spills, leaks, or improper handling or storage of hazardous chemicals and wastes

Land Uses	Quantity	Threat	Potential Sources of Contamination
Industrial			
Chemical Storage or Manufacture	Numerous	H	Spills, leaks, or improper handling or storage of chemicals or process waste
Hazardous Materials Storage	Numerous	H	Spills, leaks from improper handling or storage of hazardous waste
Industrial Parks	Few	H	Leaks, spills of chemicals from improper handling or storage
Nuclear Power Plants	1	H	Spills, leaks, or improper handling of radioactive materials
Plastic Manufacturers	1	H	Spills, leaks, or improper handling or storage of solvents, resins and process wastes
Residential			
Fuel Oil Storage (at residences)	100+	M	Spills, leaks, or improper handling of fuel oil
Lawn Care/Gardening	100+	M	Over-application or improper storage and disposal of pesticides
Septic Systems/Cesspools	100+	M	Microbial contaminants, improper disposal of hazardous chemicals
Miscellaneous			
Aboveground Storage Tanks	Few	M	Spills, leaks, or improper handling of materials stored in tanks
Aquatic Wildlife	100+	L	Microbial contaminants
Combined Sewer Overflows	Few	L	Microbial and non-microbial contaminants including industrial wastewater; improper disposal of hazardous wastes
Fishing/Boating	100+	L	Fuel and other chemical spills, microbial contaminants
Landfills and Dumps	2	H	Seepage of leachate
Large Quantity Hazardous Waste Generators	14	H	Spills, leaks, or improper handling or storage of hazardous materials and waste
NPDES Locations	2	L	Improper disposal of hazardous material and wastes
Oil or Hazardous Material Sites	100+	--	Tier Classified Oil or Hazardous Materials Sites are not ranked due to their site-specific character. Individual sites are identified in Appendix B.
Road and Maintenance Depots	1	M	Spills, leaks, or improper handling or storage of de-icing materials, automotive fluids, fuel storage, and other chemicals
Schools, Colleges, and Universities	Few	M	Spills, leaks, or improper handling or storage of fuel oil, laboratory, art, photographic, machine shop, and other chemicals
Small Quantity Hazardous Waste Generators	28	M	Spills, leaks, or improper handling or storage of hazardous materials and waste
Stormwater Drains/Retention Basins	Numerous	L	Debris, pet waste, and chemicals in stormwater from roads, parking lots, and lawns
Superfund Sites	1	H	Spills, leaks, or improper handling or storage of oil or hazardous materials and waste

Land Uses	Quantity	Threat	Potential Sources of Contamination
Transmission Line Rights-of-Way	6	L	Construction and corridor maintenance, over-application or improper handling of herbicides
Transportation Corridors	2	M	Accidental leaks or spills of fuels and other hazardous materials, over-application or improper handling of pesticides
Underground Storage Tanks	100+	H	Spills, leaks, or improper handling of stored materials
Utility Substation Transformers	1	L	Spills, leaks, or improper handling of chemicals and other materials including PCBs
Very Small Quantity Hazardous Waste Generators	100+	L	Spills, leaks, or improper handling or storage of hazardous materials and waste
Waste Transfer/Recycling Stations	3	M	Improper management, seepage, and runoff of water contacting waste materials
<p>Notes:</p> <ol style="list-style-type: none"> 1. When specific potential contaminants are not known, typical potential contaminants or activities for that type of land use are listed. Facilities may not contain all of these potential contaminant sources, may contain other potential contaminant sources, or may use Best Management Practices to prevent contaminants from reaching drinking water supplies. 2. For more information on regulated facilities, refer to Appendix B: Regulated Facilities. 3. For information about Oil or Hazardous Materials Sites, refer to Appendix C: Tier Classified Oil and/or Hazardous Material Sites. <p>* THREAT RANKING - Where there are two rankings, the first is for ground water, the second for surface water. The rankings (high, moderate or low) represent the relative threat of each land use compared to other PSCs. The ranking of a particular PSC is based on a number of factors, including: the type and quantity of chemicals typically used or generated by the PSC; the characteristics of the contaminants (such as toxicity, environmental fate and transport); and the behavior and mobility of the pollutants in soils and groundwater.</p>			

(Continued from page 4)

De-icing salt, automotive chemicals and other debris on roads are picked up by stormwater and wash into catch basins. The steep topography of the watershed results in application of de-icing materials to protect public health and safety by keeping the roads passable.

Transportation Corridor Recommendations:

Work with communities within the Merrimack watershed to:

- ✓ Establish vegetated buffers along roads and parking areas to provide some filtration of contaminants.
- ✓ Encourage regular street sweeping. Appendix A contains a fact sheet titled *DPWs Protect Drinking Water*.
- ✓ Conduct emergency drills to be ready for spills.
- ✓ Regularly inspect the watersheds for illegal dumping and spills.
- ✓ Work with local emergency response teams to ensure that any spills can be effectively contained.
- ✓ Work with the City and State to have catch basins inspected, maintained, and cleaned on a regular schedule.

5. Stormwater Flows - Stormwater from roads and commercial development, such as malls in Nashua, New Hampshire, flows directly into the Merrimack River and its tributaries. Stormwater may contain debris, chemicals, bacteria, and nutrients that can impact water quality in the river. Spills can enter the river through stormwater flows.

Stormwater Flows Recommendations:

Work with communities within the Merrimack watershed to:

- ✓ Encourage parking lot sweeping in commercial areas.
- ✓ Conduct routine testing for bacteria in river after storms.
- ✓ Continue to plan and prepare for spills.
- ✓ If storm drainage maps are available, review the maps with emergency response teams.

6. Railroad Rights-of-Way - Railroad tracks are located along the bank of the Merrimack River. Railroad Rights-of-Way are potential sources of contamination because of the possibility of spills of transported materials, chemical releases during track maintenance or the over-application or improper handling of herbicides during rights-of-way maintenance.

The Rights-of-Way Management Regulations (333 CMR 11.00) were designed to minimize any potential harmful effects of herbicides used for vegetation control along Rights-of-Way in Massachusetts. The regulations promote the use of an integrated pest management (IPM) approach to vegetation control and require application setback distances to protect drinking water sources and other environmentally sensitive areas. Utilities must submit a Vegetation Management Plan (VMP) and a Yearly Operating Plan (YOP) to the Mass. Department of Food and Agriculture for approval and to the municipalities within which herbicide application is proposed.

Railroad Rights-of-Way Recommendations:
Work with communities within the Merrimack watershed to:

- ✓ Review the utility's YOP to ensure that BMPs for herbicide applications are in place.
- ✓ Plan for spills and conduct emergency response drills to test procedures.

**When you wash your car in the driveway,
Remember
you're not just washing your car in the driveway.**



All the soap, suds, and oily grit runs along the curb. Then into a storm drain and directly into our lakes, rivers, and streams. And that causes pollution which is unhealthy for everyone. So how do you avoid this whole mess? Easy! Wash your car on the grass or gravel instead of the street. Or better yet, take it to a car wash where the water gets treated or recycled.

The Massachusetts Department of Environmental Protection One Water Street Boston, MA 02108

7. Transmission (Utility) Lines - Transmission lines run throughout the watershed. These are potential sources of contamination because of the possibility of over-application or improper handling of herbicides during rights-of-way maintenance.

Transmission (Utility) Lines Recommendation:

Work with communities within the Merrimack watershed to:

- ✓ Monitor the YOP for pesticide applications.


8. Combined Sewer Overflows (CSOs) - Overflows from the Nashua, New Hampshire sewer system have the potential to cause microbial and non-microbial contaminants to enter the river during high stormwater flows.

Combined Sewer Overflows Recommendation:

Work with communities within the Merrimack watershed to:

- ✓ Continue working with existing committees and legislators on CSOs.

9. Recreation (beaches, campgrounds, boating) - the Merrimack River is a popular regional water resource and is used extensively



for boating and fishing. Other recreational uses include beaches and campgrounds along the shoreline.

Recreation Recommendations:

Work with communities within the Merrimack watershed to:

- ✓ Post water supply awareness signs along the banks of the river, at access points, and at the Tewksbury Water Division river intake.
- ✓ Incorporate drinking water protection education into community events.
- ✓ Develop a boater education program that addresses issues specific to boating and source protection
- ✓ Encourage boaters and other users to report spills.

10. Golf Courses - There are six golf courses within the assessment area. Potential contaminants include the over-application or improper handling of pesticides and fertilizers. Pesticides and fertilizers have the potential to contaminate a drinking water source if improperly stored, applied, or disposed. If managed improperly, Underground and Aboveground Storage Tanks (USTs and ASTs) can be potential sources of contamination due to leaks or spills of the fuel oil they store.

Golf Courses Recommendations:

Work with communities within the Merrimack watershed to:

- ✓ Encourage the golf course grounds manager to incorporate an Integrated Pest Management (IPM) approach into their grounds maintenance program. IPM is an ecologically-based approach to pest control that links together several related components, including monitoring and scouting, biological controls, mechanical and/or other cultural practices, and pesticide applications. By combining a number of these different methods and practices, satisfactory pest control can be achieved with less impact on the environment.
- ✓ Promote Best Management Practices (BMPs) for fuel oil storage, hazardous material handling, storage, disposal, and emergency response planning.
- ✓ Contact owners/operators about water supply awareness and protection.

11. Road and Maintenance Depots - Potential sources of contamination in state and municipal facilities can result from accidental dumping, spills, leaks, vehicle washing operations, or from wastewater treatment. Waste management and product storage pose the greatest threats with a wide variety of potentially harmful contaminants.

Road and Maintenance Depots Recommendations:

Work with communities within the Merrimack watershed to:

- ✓ **Best Management Practices** - The New England Environmental Assistance Team provides municipalities in New England with information on how to comply with environmental requirements, and how to prevent pollution. For more information about this EPA sponsored program visit their website at <http://www.epa.gov/region1/steward/neeat/muni/index.html>. Encourage road and maintenance depots to develop best management practices to ensure proper salt storage, proper maintenance of facilities and good housekeeping practices.
- ✓ Salt pile structures should be adequately sized to allow for the loading and unloading of salt within the structure. Review the Department of Environmental Protection's Drinking Water Program Guidelines On Deicing Chemical (Road Salt) Storage at <http://www.state.ma.us/dep/brp/dws/files/saltgui.doc>.
- ✓ Encourage proper storage of materials at these facilities. Appendix A contains a fact sheet titled *DPWs Protect Drinking Water*.

12. Presence of Federal Superfund Site and Oil or Hazardous Material Contamination Sites – The watershed for the Merrimack River contains a United States Environmental Protection Agency (USEPA) Superfund Site that is associated with DEP Tier Classified Oil and/or Hazardous Material Release Site indicated on the map as Release Tracking Number 2-0000136. The watershed within the Town of Tewksbury also contains DEP Tier Classified Oil and/or Hazardous Material Release Sites indicated on the maps as Release Tracking Numbers 3-0000439, 3-0000810, 3-0001162, 3-0001717, 3-0002516, 3-0003181, and 3-0012734. Refer to the attached maps and Appendix B for more information on these sites, and for information on DEP Tier Classified Oil and/or Hazardous Material Release Sites within the watershed for the Merrimack River.

Federal Superfund Site and Oil or Hazardous Material Contamination Sites Recommendation:

- ✓ Monitor progress on any ongoing remedial action conducted for the known oil or contamination sites.

Top 5 Reasons to Develop a Local Surface Water Protection Plan

- ❶ Reduces Risk to Human Health
- ❷ Cost Effective! Reduces or Eliminates Costs Associated With:
 - ♦ Increased monitoring and treatment
 - ♦ Water supply clean up and remediation
 - ♦ Replacing a water supply
 - ♦ Purchasing water
- ❸ Supports municipal bylaws, making them less likely to be challenged
- ❹ Ensures clean drinking water supplies for future generations
- ❺ Enhances real estate values - clean drinking water is a local amenity. A community known for its great drinking water in a place people want to live and businesses want to locate.

Information about DEP Tier Classified Oil or Hazardous Material Release Sites can be obtained at DEP's Bureau of Waste Site Cleanup's web site, www.state.ma.us/dep/bwsc. Sites are identified on the attached GIS map and site specific information is available in Appendix C.

Federal Superfund Site and Oil or Hazardous Material Contamination Sites Recommendation:

Work with communities within the combined watersheds to:

- ✓ Monitor progress on any ongoing remedial action conducted for the known oil or contamination sites.

13. Residential - Over 30% of the assessment area consists of residential land uses. If managed improperly, household hazardous waste, septic systems, lawn care and pet waste can all contribute to ground and surface water contamination. Household hazardous wastes include automotive wastes, paints, solvents and other substances that should be disposed of properly at a municipal collection site. If a septic system fails or is not properly maintained, it can be a potential source of microbial contamination. Improperly applied fertilizers and pesticides can wash off lawns and into surface waters. Pet waste may contain bacteria, parasites or viruses that are health risks.

- **Septic Systems** - Improper disposal of household hazardous chemicals to septic systems is a potential source of contamination. If septic systems fail or are not properly maintained they can be a potential source of microbial contamination.
- **Household Hazardous Materials** - Hazardous materials may include automotive wastes, paints, solvents, pesticides, fertilizers, and other substances. Improper use, storage, and disposal of chemical products used in homes are potential sources of contamination.
- **Heating Oil Storage** - If managed improperly, Underground and Aboveground Storage Tanks (USTs and ASTs) can be potential sources of contamination due to leaks or spills of the fuel oil they store.

Residential Land Use Recommendations:

Work with communities within the Merrimack watershed to:

- ✓ Control residential growth on undeveloped land.
- ✓ See www.state.ma.us/envir/ to obtain information on the build-out analyses for communities into which the watershed extends.
- ✓ Educate residents on how to protect water supplies. Distribute the fact sheet *Residents Protect Drinking Water* available in Appendix A and at www.mass.gov/dep/brp/dws/protect.htm.
- ✓ Post water supply awareness signs on streets throughout the watershed.
- ✓ Work with city boards and upstream communities to review and provide recommendations on proposed watershed development.

Other land uses and activities within the emergency planning zone and watershed that are potential sources of contamination are included in Table 2. Refer to Appendix A for more information about these land uses. Identifying potential sources of contamination is an important initial step in protecting your drinking water sources. Further local investigation will provide more in-depth information and may identify new land uses and activities that are potential sources of contamination. Once potential sources of contamination are identified, specific recommendations like those below should be used to better protect your water supply.

Section 3: Source Water Protection

Current Land Uses and Source Protection:

As with many water systems, this watershed contains potential sources of contamination. However, source protection measures reduce the risk of actual contamination, as illustrated in Figure 2. The Tewksbury Water Division is commended for taking an active role in protecting their drinking water source. Some examples of the staff's good work include the following:

Emergency Planning and Response - The Utility works with upstream communities in Massachusetts and New Hampshire on emergency response planning. They have an emergency management committee and coordinate activities with the Massachusetts Emergency Management Agency (MEMA) facility in Tewksbury.

Additional Documents:

To help with source protection efforts, more information is available by request or online at www.state.ma.us/dep/brp/dws including:

1. Water Supply Protection Guidance Materials such as model regulations, Best Management Practice information, and general water supply protection information.
2. MA DEP SWAP Strategy
3. Land Use Pollution Potential Matrix
4. Draft Land/Associated Contaminants Matrix

Communication with Other Communities - The Utility maintains contact with upstream communities, including those in New Hampshire, on a variety of source protection issues.

Section 4: Emergency Planning Recommendations

Prevention

Public water suppliers with a river source may take preventive measures to protect the source from unexpected releases. Here are some suggestions.

1. Title III (Emergency Planning and Community Right-to-Know) of the Superfund Amendments & Reauthorization Act (SARA) of 1986 required that each community **develop a comprehensive emergency response plan**. Suppliers should review the existing plan to ensure that water supply issues are satisfactorily addressed in the plan, that current response personnel and their correct telephone numbers are listed, and that the entire plan is regularly reviewed and updated by community officials.

The community plan, or a separate water supplier plan, should include copies of policies in the event of spills or releases; regulatory notification requirements such as what size spills are required to be reported, who to call, telephone numbers, and what information is required to be reported; map of intakes, tributaries, watershed boundaries, adjacent public wells, and locations of sites where spills or accidental releases could occur.

2. **Identify, map and distribute information** to local emergency responders regarding the locations of intakes on the river, tributaries, watershed boundaries, public wells adjacent to river; chemical use at municipal, state, and industrial facilities in watershed (contact Fire Dept., DEP); locations of stormwater drains and the locations of known dams in the event that they can be manipulated by authorized individuals for contaminant control.

The Fire Dept., Board of Health, Planning Board, Local Emergency Planning Committee (LEPC), DEP and others may have existing information to help with your work. SARA requires companies to work with the community's LEPC if they handle extremely hazardous chemicals in quantities above established thresholds.

3. **Develop a communication list** of contacts at upstream and downstream facilities, dams, as well as other public water suppliers on, or adjacent to, rivers. Notify owners and operators of these facilities about the location of your intake and request, in writing, that you be notified immediately in the event of a chemical spill or unexpected discharge. Take this opportunity to educate others about water supply protection.
4. **Provide comments** to municipal boards in other cities/towns in the watershed about proposed development, land use controls, Best Management Practices (BMPs) for stormwater flow into tributaries, and other issues to avoid future problems.
5. **Post signs** along major roads in watershed which direct the public to call "911" or other appropriate local number in case of spills. Be aware of accident-prone areas and transport routes of chemicals if possible.
6. **Educate** the public, local officials, Civil Defense, local emergency response team, and others about water supply protection issues. Educate businesses about toxic use reduction.
7. **Conduct household hazardous waste collection days** and establish permanent collection sites, away from sensitive watershed areas, for used batteries, paints, motor oil, etc.
8. **Conduct drills**, in coordination with local/regional response teams, to test policies and procedures and to practice responding to various situations. Including businesses, local officials and staff, Fire Departments, Boards of Health, Civil Defense, school administration, and others in planning and implementing the drills will allow for several town or region-wide concerns to be addressed and tested at the same time, including: issuing health advisories, conducting neighborhood and/or school evacuations, and evaluating the town's communication system (both making responders aware of the emergency and issuing advisories to the public when necessary via television, radio, and other news media), equipment and emergency plan in general.
9. Critique the drills and **modify components** of the emergency response system as needed.

Responding to Emergencies

Drinking water supply professionals responding to local emergencies need to be adequately prepared and trained, and know their roles and responsibilities. Here are some suggestions.

1. **Know regulatory reporting requirements** of state and federal agencies. Know who to call, telephone numbers and what information to report.
2. **Know your role & responsibilities**. Have access to, and be familiar with, the emergency communication list, policies and procedures for emergency response; know when, and how, to safely handle spills or other events until first responders arrive on scene; know what steps to take to avoid drawing contaminants into the water supply system; be familiar enough with local watershed characteristics to provide incident commander with information and advice.
3. **Provide training and materials to responding staff**. Water supply staff, including new employees, should be adequately trained, have access to appropriate materials (storm drain covers, absorbent pads, booms, etc.), up-to-date policies, procedures, and communication lists to perform tasks for which they are responsible.

Follow-up

Steps can be taken to ensure better preparedness in the event of future emergency situations. Here are some suggestions.

1. **Provide follow-up reports** to the public on the resolution of the situation.
2. **Share the information** learned from drills and real situations with others in order to better protect all public drinking water sources.

These recommendations are only part of your ongoing local drinking water source protection. Additional source protection recommendations are listed in the Key Issues above and Appendix A.

Section 5: Additional Resources Available for Source Water Protection

DEP staff, informational documents, and resources are available to help you build on this SWAP report as you continue to improve drinking water protection in your community. The Department's Source Protection Grant Program provides funds to assist public water suppliers in addressing water supply source protection through local projects. Protection recommendations discussed in this document may be eligible for funding under the Grant Program. Please note: each spring DEP posts a new Request for Response (RFR) for the grant program.

Other grants and loans are available through the Drinking Water State Revolving Loan Fund, the Clean Water State Revolving Fund, and other sources. For more information on grants and loans, visit the Bureau of Resource Protection's Municipal Services web site at: <http://mass.gov/dep/brp/mf/mfpubs.htm>.

The assessment and protection recommendations in this SWAP report are provided as a tool to encourage community discussion, support ongoing source protection efforts, and help set local drinking water protection priorities. Citizens and community officials should use this SWAP report to spur discussion of local drinking water protection measures. The water supplier should supplement this SWAP report with local information on potential sources of contamination and land uses. Local information should be maintained and updated periodically to reflect land use changes in the watershed. Use this information to set priorities, target inspections, focus education efforts, and to develop a long-term drinking water source protection plan.

Information about DEP Tier Classified Oil or Hazardous Material Release Sites can be obtained at DEP's Bureau of Waste Site Cleanup's web site, www.state.ma.us/dep/bwsc. Sites are identified on the attached GIS map and site specific information is available in Appendix C.

Section 6: Appendices

- A. Protection Recommendations
- B. List of Regulated Facilities (in Massachusetts)
- C. Table of Tier Classified Oil and/or Hazardous Material Sites
- D. Additional Documents on Source Protection

For More Information

Contact Anita Wolovick in DEP's NERO at (617) 654-6535 for more information and assistance on improving current protection measures.

Copies of this report have been provided to the public water supplier, town boards, and the local media.

APPENDIX A: DEP PERMITTED FACILITIES WITHIN TEWKSBURY'S WATER SUPPLY PROTECTION AREAS

DEP FACILITY NUMBER	FACILITY NAME	STREET ADDRESS	TOWN	PERMITTED ACTIVITY	ACTIVITY CLASS
38043	NEW ENGLAND HYDRO TRANS ELECTRIC	RADISSON RD	AYER	HANDLR	LARGE QUANTITY GENERATOR OF HAZ WASTE
--	BROOK VILLAGE CONDO	C/O RELIABLE PROP. MGMT/P.O. BOX 210	BOXBOROUGH	GROUND	GROUNDWATER DISCHARGE
39155	CHELMSFORD LANDFILL	SWAIN RD	CHELMSFORD	SLF	CHARGEABLE CLOSED LANDFILL
366769	MERRIMACK VALLEY SCREEN PRINTING INC	6 ADAMS ST	CHELMSFORD	PLANT	NON-NOTIFIER AQ FAC THAT IS SUBJ TO REGS BUT NOT PERMITTED
366769	MERRIMACK VALLEY SCREEN PRINTING INC	6 ADAMS ST	CHELMSFORD	DISCH	NON-NOTIFIER IWW FAC THAT IS SUBJ TO REGS BUT NOT PERMITTED
131963	UNITED CIRCUITS INC	100 PLEASANT ST	DRACUT	TURRPT	LARGE QUANTITY TOXICS USER
131963	UNITED CIRCUITS INC	100 PLEASANT ST	DRACUT	HANDLR	LARGE QUANTITY GENERATOR OF HAZ WASTE
298511	DUMONT ENTERPRISES INC	41 LOWELL ST	DUNSTABLE	HANDLR	VERY SMALL QUANTITY GENERATOR RCRA HAZARDOUS WASTE
298511	DUMONT ENTERPRISES INC	41 LOWELL ST	DUNSTABLE	HANDLR	SMALL QUANTITY GENERATOR WASTE OIL/PCBS
298511	DUMONT ENTERPRISES INC	41 LOWELL ST	DUNSTABLE	HANDLR	VERY SMALL QUANTITY GENERATOR RCRA HAZARDOUS WASTE
298511	DUMONT ENTERPRISES INC	41 LOWELL ST	DUNSTABLE	HANDLR	SMALL QUANTITY GENERATOR WASTE OIL/PCBS
366857	DUNSTABLE GAS INC	238 PLEASANT ST	DUNSTABLE	FULDSP	FUEL DISPENSER STAGEII
32187	WEST AUTO REPAIR	30 PLEASANT ST	DUNSTABLE	HANDLR	VERY SMALL QUANTITY GENERATOR RCRA HAZARDOUS WASTE

DEP FACILITY NUMBER	FACILITY NAME	STREET ADDRESS	TOWN	PERMITTED ACTIVITY	ACTIVITY CLASS
136387	GROTON AL PRIME	619 BOSTON RD	GROTON	FULDSP	FUEL DISPENSER STAGEII
136387	GROTON AL PRIME	619 BOSTON RD	GROTON	HANDLR	VERY SMALL QUANTITY GENERATOR WASTE OIL/PCBS
136387	GROTON AL PRIME	619 BOSTON RD	GROTON	HANDLR	VERY SMALL QUANTITY GENERATOR RCRA HAZARDOUS WASTE
136387	GROTON AL PRIME	619 BOSTON RD	GROTON	HANDLR	VERY SMALL QUANTITY GENERATOR RCRA HAZARDOUS WASTE
136387	GROTON AL PRIME	619 BOSTON RD	GROTON	HANDLR	VERY SMALL QUANTITY GENERATOR WASTE OIL/PCBS
39315	GROTON LANDFILL	600 COW POND BRK RD	GROTON	SLF	CHARGEABLE LANDFILL
363409	GROTON TRANSFER STATION	600 COW POND BROOK RD	GROTON	TRSTN	SMALL HANDLING FACILITY
377537	AGGREGATE INDUSTRIES	80 AYER RD	LITTLETON	TURRPT	LARGE QUANTITY TOXICS USER
--	LITTLETON NURSING HOME	2955 KEITH STREET	LITTLETON	GROUND	GROUNDWATER DISCHARGE
229723	MIDDLESEX CONCRETE	80 AYER RD	LITTLETON	HANDLR	LARGE QUANTITY GENERATOR OF HAZ WASTE
--	PONDSIDE APT. COMPLEX	488 COMMONWEALTH AVENUE	LITTLETON	GROUND	GROUNDWATER DISCHARGE
186901	VERYFINE PRODUCTS INC	20 HARVARD ROAD	LITTLETON	TURRPT	LARGE QUANTITY TOXICS USER
363549	WAKEFIELD MATERIALS CORPORATION	80 AYER RD	LITTLETON	TURRPT	LARGE QUANTITY TOXICS USER

DEP FACILITY NUMBER	FACILITY NAME	STREET ADDRESS	TOWN	PERMITTED ACTIVITY	ACTIVITY CLASS
370173	CHEVROLET OF LOWELL INC	831 ROGERS ST	LOWELL	HANDLR	SMALL QUANTITY GENERATOR RCRA HAZARDOUS WASTE
370173	CHEVROLET OF LOWELL INC	831 ROGERS ST	LOWELL	HANDLR	LARGE QUANTITY GENERATOR WASTE OIL/PCBS
--	COMPAQ COMPUTER CORP	550 KING STREET	LITTLETON	GROUND	GROUNDWATER DISCHARGE
53879	FREUDENBERG NONWOVEN	221 JACKSON ST	LOWELL	HANDLR	LARGE QUANTITY GENERATOR WASTE OIL/PCBS
53879	FREUDENBERG NONWOVEN	221 JACKSON ST	LOWELL	HANDLR	SMALL QUANTITY GENERATOR RCRA HAZARDOUS WASTE
53879	FREUDENBERG NONWOVEN	221 JACKSON ST	LOWELL	TURRPT	LARGE QUANTITY TOXICS USER
131011	IDEAL TAPE CO	1400 MIDDLESEX ST	LOWELL	HANDLR	LARGE QUANTITY GENERATOR RCRA HAZARDOUS WASTE
131011	IDEAL TAPE COMPANY	1400 MIDDLESEX ST	LOWELL	TURRPT	LARGE QUANTITY TOXIC USER
177799	JIFFY LUBE	645 ROGERS ST	LOWELL	HANDLR	VERY SMALL QUANTITY GENERATOR RCRA HAZARDOUS WASTE
177799	JIFFY LUBE	645 ROGERS ST	LOWELL	HANDLR	LARGE QUANTITY GENERATOR WASTE OIL/PCBS
53762	JOAN FABRICS CORP	27 JACKSON STREET	LOWELL	TURRPT	LARGE QUANTITY TOXIC USER
53845	LOWELL COGENERATION COMPANY LP	282 WESTERN AVE	LOWELL	HANDLR	VERY SMALL QUANTITY GENERATOR RCRA HAZARDOUS WASTE
53845	LOWELL COGENERATION COMPANY LP	282 WESTERN AVE	LOWELL	HANDLR	LARGE QUANTITY GENERATOR WASTE OIL/PCBS

DEP FACILITY NUMBER	FACILITY NAME	STREET ADDRESS	TOWN	PERMITTED ACTIVITY	ACTIVITY CLASS
53845	LOWELL COGENERATION COMPANY LP	282 WESTERN AVE	LOWELL	TURRPT	LARGE QUANTITY TOXIC USER
131026	MA COM INC	100 CHELMSFORD ST	LOWELL	TURRPT	LARGE QUANTITY TOXIC USER
131026	MA COM INC	100 CHELMSFORD ST	LOWELL	HANDLR	LARGE QUANTITY GENERATOR RCRA HAZARDOUS WASTE
215603	NE NO6 INC SPEEDEE OIL CHANGE & TUNE UP	1485 MIDDLESEX ST	LOWELL	HANDLR	LARGE QUANTITY GENERATOR WASTE OIL/PCBS
35763	NTI LUBRICATIONS INC	1713 MIDDLESEX ST	LOWELL	HANDLR	SMALL QUANTITY GENERATOR RCRA HAZARDOUS WASTE
35763	NTI LUBRICATIONS INC	1713 MIDDLESEX ST	LOWELL	HANDLR	LARGE QUANTITY GENERATOR WASTE OIL/PCBS
121233	OAK FINISHERS CO	REAR 165 JACKSON ST	LOWELL	TURRPT	LARGE QUANTITY TOXIC USER
131016	ROCHE BROTHERS BARREL & DRUM CO	161 PHOENIX AVE	LOWELL	HANDLR	LARGE QUANTITY GENERATOR RCRA HAZARDOUS WASTE
295908	RADIOLOGY RESOURCES INC	225 STEDMAN STREET - UNIT #33	LOWELL	HWR	HAZARDOUS WASTE RECYCLER
131016	ROCHE BROTHERS BARREL CO.	161 PHOENIX AVENUE	LOWELL	HANDLR	LARGE QUANTITY GENERATOR HAZARDOUS WASTE
365455	SPECIALTY MATERIALS INC	1449 MIDDLESEX AVE	LOWELL	TURRPT	LARGE QUANTITY TOXIC USER
365455	SPECIALTY MATERIALS INC	1449 MIDDLESEX AVE	LOWELL	HANDLR	LARGE QUANTITY GENERATOR RCRA HAZARDOUS WASTE
131030	TEXTRON SPECIALTY CORPORATION	1449 MIDDLESEX STREET	LOWELL	TURRPT	LARGE QUANTITY TOXICS USER

DEP FACILITY NUMBER	FACILITY NAME	STREET ADDRESS	TOWN	PERMITTED ACTIVITY	ACTIVITY CLASS
131030	TEXTRON SPECIALTY CORPORATION	1449 MIDDLESEX STREET	LOWELL	HANDLR	LARGE QUANTITY GENERATOR OF HAZ WASTE
34343	ASHLAND CHEMICAL CO	400 MAIN ST	TEWKSBURY	HANDLR	TRANSPORTER OF HAZARDOUS WASTE
34343	ASHLAND CHEMICAL COMPANY	400 MAIN ST	TEWKSBURY	TURRPT	LARGE QUANTITY TOXICS USER
53791	ECRM	554 CLARK RD	TEWKSBURY	HANDLR	LARGE QUANTITY GENERATOR OF HAZ WASTE
370388	3A GAS	257 MIDDLESEX RD	TYNGSBORO	FULDSP	FUEL DISPENSER
322941	ANDYS AUTO BODY	339 WESTFORD ST	TYNGSBORO	PLANT	AIR QUALITY PERMIT
322941	ANDYS AUTO BODY	339 WESTFORD ST	TYNGSBORO	HANDLR	VERY SMALL QUANTITY GENERATOR OF HAZ WASTE
348617	BARR ASSOC INC	300 POTASH HILL RD	TYNGSBORO	PLANT	AIR QUALITY PERMIT
320025	BELCASTRO FURNITURE RESTORATION	77 WESTECH DR	TYNGSBORO	PLANT	AIR QUALITY PERMIT
320025	BELCASTRO FURNITURE RESTORATION	77 WESTECH DR	TYNGSBORO	HANDLR	VERY SMALL QUANTITY GENERATOR OF HAZ WASTE
132303	BFI WASTE SYSTEMS OF NORTH AMERICA	385 DUNSTABLE RD	TYNGSBORO	HANDLR	LARGE QUANTITY GENERATOR HAZARDOUS WASTE
132303	BFI WASTE SYSTEMS OF NORTH AMERICA	385 DUNSTABLE RD	TYNGSBORO	HANDLR	SMALL QUANTITY GENERATOR OF HAZ WASTE
132303	BFI WASTE SYSTEMS OF NORTH AMERICA	385 DUNSTABLE RD	TYNGSBORO	DISCH	INDUSTRIAL WASTE WATER SURFACE WATER DISCHARGE

DEP FACILITY NUMBER	FACILITY NAME	STREET ADDRESS	TOWN	PERMITTED ACTIVITY	ACTIVITY CLASS
298585	BRITE KLEEN CLEANERS	26 WESTFORD RD	TYNGSBORO	HANDLR	VERY SMALL QUANTITY GENERATOR OF HAZ WASTE
32160	COLONIAL AUTO BODY	121 LAKEVIEW AVE	TYNGSBORO	HANDLR	SMALL QUANTITY GENERATOR OF HAZ WASTE
110594	DANA WALLBOARD SUPPLY INC	6 CUMMINGS RD	TYNGSBORO	HANDLR	VERY SMALL QUANTITY GENERATOR OF WASTE OIL OR PCBS
302562	DUFFS GARAGE	92 KENDALL RD	TYNGSBORO	DISCH	BELOW INDUSTRIAL WASTE WATER REG LEVELS
302562	DUFFS GARAGE	92 KENDALL RD	TYNGSBORO	HANDLR	VERY SMALL QUANTITY GENERATOR OF HAZ WASTE
291199	DUNBAR BUS CO	33 MIDDLESEX RD	TYNGSBORO	HANDLR	VERY SMALL QUANTITY GENERATOR OF HAZ WASTE
132214	HUSSEY PLASTICS INC	65 MIDDLESEX RD	TYNGSBORO	HANDLR	VERY SMALL QUANTITY GENERATOR OF HAZ WASTE
307332	INDEPENDENT SPRAY	26R WOODLAWN ST	TYNGSBORO	PLANT	AIR QUALITY PERMIT
307332	INDEPENDENT SPRAY	26R WOODLAWN ST	TYNGSBORO	HANDLR	VERY SMALL QUANTITY GENERATOR OF HAZ WASTE
368183	MOBIL 12369	95-97 WESTFORD RD	TYNGSBORO	FULDSP	FUEL DISPENSER
324984	MUTUAL OIL	397 MIDDLESEX RD	TYNGSBORO	FULDSP	FUEL DISPENSER
321837	MUTUAL OIL CO INC	397 MIDDLESEX RD	TYNGSBORO	HANDLR	VERY SMALL QUANTITY GENERATOR OF WASTE OIL OR PCBS
368441	NEW ENGLAND TRANSIT SALES INC	30 PROGRESS AV	TYNGSBORO	HANDLR	SMALL QUANTITY GENERATOR OF WASTE OIL OR PCBS

DEP FACILITY NUMBER	FACILITY NAME	STREET ADDRESS	TOWN	PERMITTED ACTIVITY	ACTIVITY CLASS
132833	PICONICS INC	26 CUMMINGS RD	TYNGSBORO	PLANT	AIR QUALITY PERMIT
132833	PICONICS INC	26 CUMMINGS RD	TYNGSBORO	DISCH	INDUSTRIAL WASTE WATER HOLDING TANK
132833	PICONICS INC	26 CUMMINGS RD	TYNGSBORO	HANDLR	SMALL QUANTITY GENERATOR OF HAZ WASTE
853	THUNDERBIRD PLAZA	MIDDLESEX RD	TYNGSBORO	GROUND	GROUNDWATER DISCHARGE
209890	TJ MAXX PLAZA	440 MIDDLESEX RD	TYNGSBORO	GROUND	GROUNDWATER DISCHARGE
230673	TOWN AND COUNTRY GARAGE	54 PAWTUCKET BLVD	TYNGSBORO	FULDSP	FUEL DISPENSER
37104	TYNGSBORO AUTO WORKS	33 MIDDLESEX RD	TYNGSBORO	HANDLR	VERY SMALL QUANTITY GENERATOR OF HAZ WASTE
310633	TYNGSBORO HIGHWAY DEPT	89 KENDELL RD	TYNGSBORO	FULDSP	FUEL DISPENSER
130848	WESTFORD ANODIZING CORP	12 NORTH MAIN ST	WESTFORD	HANDLR	LARGE QUANTITY GENERATOR HAZARDOUS WASTE
130848	WESTFORD ANODIZING CORP	12 NORTH MAIN ST	WESTFORD	TURRPT	LARGE QUANTITY TOXICS USER
--	WESTFORD MIDDLE SCHOOL	35 TOWN FARM ROAD	WESTFORD	GROUND	GROUNDWATER DISCHARGE

UNDERGROUND STORAGE TANKS WITHIN TEWKSBURY'S WATER SUPPLY PROTECTION AREAS

FACILITY NAME	ADDRESS	TOWN	DESCRIPTION	NUMBER OF TANKS
M W LEAHY CO INC	21 WESTFORD RD	AYER	TRUCK/TRANSPORT	3
MASS DPW MAINT DEPOT	SWANSON RD	BOXBOROUGH	STATE	2
TOSCO #2634709	1425 MASSACHUSETTS AVE	BOXBOROUGH	GAS STATION	4
BOMIL G.P. WELL # 1,3,4	RICHARDSON ROAD	CHELMSFORD	UTILITIES	3
CUMBERLAND GULF #2428	71 DRUM HILL RD	CHELMSFORD	GAS STATION	5
MARCHAND OIL CO INC	89 STEADMAN ST	CHELMSFORD	PETR. DISTR	7
SHELL SERVICE STATION 22013090505	188 PRINCETON BLVD	CHELMSFORD	GAS STATION	4
SUNOCO #0011-8927	100 DRUM HILL RD	CHELMSFORD	GAS STATION	3
TOSCO #2634732	5 DRUM HILL RD	CHELMSFORD	GAS STATION	3
BELL ATLANTIC (5243-07)	28 DIANA LN	DRACUT	UTILITIES	3
BELL ATLANTIC CENTRAL OFFICE	1212 MAMMOTH RD	DRACUT	UTILITIES	1
DRACUT AUTO CARE INC	500 NASHUA RD	DRACUT	GAS STATION	3
HIGHWAY DEPT	833 HILDRETH ST	DRACUT	MUNICIPAL	2

FACILITY NAME	ADDRESS	TOWN	DESCRIPTION	NUMBER OF TANKS
JAY'S SERVICE CENTER INC	1225 MAMMOTH RD	DRACUT	GAS STATION	6
JIM'S SERVICE STATION INC	1643 LAKEVIEW AVE	DRACUT	GAS STATION	4
P J KEATING COMPANY	240 BRIDGE ST	DRACUT	TRUCK/TRANSPORT	1
SHELL SERVICE STATION 22018770200	1100 LAKEVIEW ST	DRACUT	GAS STATION	4
DUNSTABLE GENERAL STORE INC	238 PLEASANT ST	DUNSTABLE	GAS STATION	3
A L PRIME ENERGY	619 BOSTON RD	GROTON	GAS STATION	3
TOWN OF GROTON HIGHWAY DEPT	500 COW POND BROOK RD	GROTON	MUNICIPAL	2
ARCHER'S MOBIL # 01-787	500 KING ST	LITTLETON	GAS STATION	5
DCM ENTERPRISES INC	25 KING ST	LITTLETON	GAS STATION	5
LITTLETON CITGO	256 AYER RD	LITTLETON	GAS STATION	3
NATIONAL FREIGHT INC #09	194 AYERS RD	LITTLETON	TRUCK/TRANSPORT	3
SHELL SERVICE STATION #137781	460 KING ST	LITTLETON	GAS STATION	3
TMC LEASING LLC	80 AYER RD	LITTLETON	INDUSTRIAL	2

FACILITY NAME	ADDRESS	TOWN	DESCRIPTION	NUMBER OF TANKS
TOWN OF LITTLETON	39 AYER RD	LITTLETON	MUNICIPAL	3
VERYFINE PRODUCTS INC	20 HARVARD RD	LITTLETON	INDUSTRIAL	3
ADVANCED AUTO PERFORMANCE	479 BROADWAY ST	LOWELL	GAS STATION	2
AMES CORPORATION	121 CHURCH ST	LOWELL	OTHER	1
BELL ATLANTIC	115 APPLETON ST	LOWELL	UTILITIES	1
BRIDGE STREET SUNOCO	356 BRIDGE ST	LOWELL	GAS STATION	3
COLONIAL GAS CO	775 DUTTON ST	LOWELL	UTILITIES	3
FORMER DEMERS SHELL STATION	550 BRIDGE ST	LOWELL	GAS STATION	5
GASOLINE MERCHANTS INC	276 HIGH ST	LOWELL	GAS STATION	4
GASOLINE MERCHANTS INC	710-724 LAKEVIEW AVE	LOWELL	GAS STATION	3
GEOFFREYS SERVICE STATION	290 WESTFORD ST	LOWELL	GAS STATION	1
GEORGE MACHERAS	66 BROADWAY ST	LOWELL	OTHER	1
GETTY STATION #30618	801 LAKEVIEW AVE	LOWELL	GAS STATION	2

FACILITY NAME	ADDRESS	TOWN	DESCRIPTION	NUMBER OF TANKS
GORHAM STREET SUNOCO	380 GORHAM ST	LOWELL	GAS STATION	3
HAFFNER'S	1150 BRIDGE ST	LOWELL	GAS STATION / PETR. DISTR	7
HAFFNER'S	189 APPLETON ST	LOWELL	GAS STATION	3
HAFFNER'S	215 DUTTON ST	LOWELL	GAS STATION	6
HESS 21322	558 PAWTUCKET ST	LOWELL	GAS STATION	3
HESS 21509	300 MERRIMACK ST	LOWELL	GAS STATION	3
IDEAL TAPE COMPANY	1400 MIDDLESEX ST	LOWELL	INDUSTRIAL	3
JIM WITT PONT-GMC TRUCK INC	1365 MIDDLESEX ST	LOWELL	VEHICLE DEALER	1
JOAN FABRICS CORP PLANT #14	27 JACKSON ST	LOWELL	INDUSTRIAL	1
KAZANJIAN ENTERPRISE	1460 MIDDLESEX ST	LOWELL	GAS STATION	5
KINNEY'S TEXACO SERVICE INC	262 PAWTUCKET ST	LOWELL	GAS STATION	3
LOWELL GENERAL HOSPITAL	295 VARNUM AVE	LOWELL	HOSPITAL	2
LOWELL REGIONAL WATER UTILITY	815 PAWTUCKET BLVD	LOWELL	MUNICIPAL	2

FACILITY NAME	ADDRESS	TOWN	DESCRIPTION	NUMBER OF TANKS
MOUJAES INC C&J MOBIL	443 BRIDGE ST	LOWELL	GAS STATION	4
MULDOON BROTHERS INC	498 BROADWAY ST	LOWELL	GAS STATION	2
PALMER'S AUTOMOTIVE	1500 MIDDLESEX ST	LOWELL	GAS STATION	1
PETE AND RAY AUTO REPAIR INC	472 PRINCETON BLVD	LOWELL	GAS STATION	3
RAY MARCHAND OIL / AUTO	493 PRINCETON BLVD	LOWELL	GAS STATION	4
ROD'S AUTO CARE	626 ROGERS ST	LOWELL	GAS STATION	5
RONS TEXACO	360 MAMMOTH RD	LOWELL	GAS STATION	3
SUNOCO #0005-2894	711 ROGERS ST	LOWELL	GAS STATION	5
TONY'S FILLING STATION INC	51 MAMMOTH RD	LOWELL	GAS STATION	2
UNIVERSITY OF LOWELL	SOUTH CAMPUS	LOWELL	OTHER	1
UNIVERSITY OF LOWELL NORTH CAMPUS	NEW (1989) DORMITORY	LOWELL	OTHER	1
US POSTAL SERVICE LOWELL MAINT	44 POST OFFICE SQ	LOWELL	FEDERAL / NON-MILITARY	4
USA PETROLEUM CORP	780 ROGERS ST	LOWELL	GAS STATION	3

FACILITY NAME	ADDRESS	TOWN	DESCRIPTION	NUMBER OF TANKS
CRANE RENTAL CO INC	205 OLD MAIN ST	TEWKSBURY	OTHER	2
MOBIL #01-JFA	2 MAIN ST	TEWKSBURY	GAS STATION	6
MOBIL #01-PRJ	940 ANDOVER ST	TEWKSBURY	GAS STATION	5
SHELL STATION # 116791	365 MAIN ST	TEWKSBURY	GAS STATION	1
TEXACO SERVICE	1975 MAIN ST	TEWKSBURY	GAS STATION	5
TEXACO SERVICE LOC #11-025-0018	1 MAIN ST	TEWKSBURY	GAS STATION	4
BROWNING-FERRIS IND OF MASS INC	385 DUNSTABLE RD	TYNGSBOROUGH	TRUCK/TRANSPORT	2
DUSTY & SONS INC	257 MIDDLESEX RD	TYNGSBOROUGH	GAS STATION	4
MIDDLESEX TEXACO	397 MIDDLESEX RD	TYNGSBOROUGH	GAS STATION	2
MOBIL #01-E5Y	95-97 WESTFORD RD	TYNGSBOROUGH	GAS STATION	3
TOWN & COUNTRY	54 PAWTUCKET BLVD	TYNGSBOROUGH	OTHER	4
TOWN OF TYNGSBORO HIGHWAY DEPT	89 KENDALL RD	TYNGSBOROUGH	MUNICIPAL	2
COOK OIL CO INC	23 FORGE VILLAGE RD	WESTFORD	OTHER	1

FACILITY NAME	ADDRESS	TOWN	DESCRIPTION	NUMBER OF TANKS
CUMBERLAND FARMS #2408	158-180 LITTLETON RD	WESTFORD	GAS STATION	4
GETTY STATION #30562	1 OAK HILL RD	WESTFORD	GAS STATION	2
GETTY STATION #30633	262 GROTON RD	WESTFORD	GAS STATION	3
MOBIL #361	185 LITTLETON RD	WESTFORD	GAS STATION	4
ROBERT M HICKS INC	124 MAIN ST	WESTFORD	CONTRACTOR	1
WESTFORD CITGO	169 PLAIN RD	WESTFORD	GAS STATION	3
WESTFORD TIRE & AUTO	215 GROTON RD	WESTFORD	GAS STATION	4

FOR MORE INFORMATION ON UNDERGROUND STORAGE TANKS, VISIT THE MASSACHUSETTS DEPARTMENT OF FIRE SERVICES WEB SITE:
[HTTP://WWW.STATE.MA.US/DFS/UST/USTHOME.HTM](http://www.state.ma.us/dfs/ust/usthome.htm)

NOTE: THIS APPENDIX INCLUDES ONLY THOSE FACILITIES WITHIN THE WATER SUPPLY PROTECTION AREA(S) THAT MEET STATE REPORTING REQUIREMENTS AND REPORT TO THE APPROPRIATE AGENCIES. ADDITIONAL FACILITIES LOCATED WITHIN THE WATER SUPPLY PROTECTION AREA(S) SHOULD BE CONSIDERED IN LOCAL DRINKING WATER SOURCE PROTECTION PLANNING.

APPENDIX B – Table of Tier Classified Oil and/or Hazardous Material Sites within Tewksbury Water Supply Protection Areas

DEP’s datalayer depicting oil and/or hazardous material (OHM) sites is a statewide point data set that contains the approximate location of known sources of contamination that have been both reported and classified under Chapter 21E of the Massachusetts General Laws. Location types presented in the layer include the approximate center of the site, the center of the building on the property where the release occurred, the source of contamination, or the location of an on-site monitoring well. Although this assessment identifies OHM sites near the source of your drinking water, the risks to the source posed by each site may be different. The kind of contaminant and the local geology may have an effect on whether the site poses an actual or potential threat to the source.

The DEP’s Chapter 21E program relies on licensed site professionals (LSPs) to oversee cleanups at most sites, while the DEP’s Bureau of Waste Site Cleanup (BWSC) program retains oversight at the most serious sites. This privatized program obliges potentially responsible parties and LSPs to comply with DEP regulations (the Massachusetts Contingency Plan – MCP), which require that sites within drinking water source protection areas be cleaned up to drinking water standards.

For more information about the state’s OHM site cleanup process to which these sites are subject and how this complements the drinking water protection program, please visit the BWSC web page at <http://www.state.ma.us/dep/bwsc>. You may obtain site -specific information two ways: by using the BWSC Searchable Sites database at <http://www.state.ma.us/dep/bwsc/sitellst.htm>, or you may visit the DEP regional office and review the site file. These files contain more detailed information, including cleanup status, site history, contamination levels, maps, correspondence and investigation reports, however you must call the regional office in order to schedule an appointment to view the file.

The table below contains the list of Tier Classified oil and/or Hazardous Material Release Sites that are located within your drinking water source protection area.

Table 1: Bureau of Waste Site Cleanup Tier Classified Oil and/or Hazardous Material Release Sites (Chapter 21E Sites) - Listed by Release Tracking Number (RTN)

RTN	Release Site Address	Town	Contaminant Type
3-0019820	5 Drumhill Rd	Chelmsford	Oil And Hazardous Material
3-0000496	1095 Lakeview Ave	Dracut	Oil
3-0001069	Broadway Rd	Dracut	Oil
3-0002400	25 Victory Ln	Dracut	Oil
3-0003492	1507 Lakeview Ave	Dracut	--
3-0004645	91 Mill St	Dracut	Oil
3-0004651	2060 Bridge St	Dracut	--
3-0016749	1507 Lakeview Ave	Dracut	Oil
2-0013472	238 Pleasant Street	Dunstable	Oil And Hazardous Material
3-0000041	200 Market St	Lowell	--
3-0000347	1 Kyan St	Lowell	--

RTN	Release Site Address	Town	Contaminant Type
3-0000351	161 Phoenix Ave	Lowell	--
3-0000355	Broadway Dummer St	Lowell	Oil
3-0000535	Aiken Ave Perkins St	Lowell	--
3-0000852	43 Lakeview Ave	Lowell	--
3-0001052	150 Phoenix Ave	Lowell	--
3-0001056	Varnum Ave	Lowell	--
3-0001328	356 Bridge St	Lowell	--
3-0001620	66 Broadway	Lowell	Oil
3-0001954	1682-1700 Middlesex St	Lowell	--
3-0002044	1465 Middlesex St	Lowell	--
3-0002544	1 University Ave	Lowell	--
3-0002609	262 Pawtucket St	Lowell	--
3-0002629	774 Dutton St	Lowell	--
3-0002756	224 Walker St	Lowell	--
3-0004509	253 Merrimack St	Lowell	Oil
3-0004561	2461 Market St	Lowell	Oil
3-0004664	205 Church St	Lowell	Oil
3-0011528	Westford St	Lowell	Oil And Hazardous Material
3-0013603	262 Pawtucket St	Lowell	Oil and Hazardous Material
3-0014250	Pevey St @ Arlene St	Lowell	--
3-0014974	780 Rogers St	Lowell	Oil
3-0017036	180 Church St	Lowell	Oil
3-0017559	290 Westford St	Lowell	Oil
3-0017804	479 Broadway	Lowell	Oil
3-0018004	50 Arcand Dr	Lowell	Oil
3-0018128	219 East Merrimac St	Lowell	Oil
3-0018153	498 Broadway	Lowell	Oil
3-0019949	10 Technology Dr	Lowell	Oil And Hazardous Material
3-0000439	400 Main St Rte 38	Tewksbury	--

RTN	Release Site Address	Town	Contaminant Type
3-0000810	2 Main St	Tewksbury	Oil
3-0001162	450 Clark Rd	Tewksbury	--
3-0001717	365 Main St	Tewksbury	--
3-0002516	1 Main St	Tewksbury	--
3-0003181	940 Andover St	Tewksbury	Oil
3-0012734	Main St And Clark Rd	Tewksbury	Oil
2-0000136	475-530 Dunstable Road	Tyngsboro	--
2-0000392	292 Middlesex Road	Tyngsboro	--
2-0000428	Westech Drive	Tyngsboro	Oil
2-0010348	138-142 Frost Street	Tyngsboro	Hazardous Material
2-0011257	95-97 Westford Road	Tyngsboro	Oil And Hazardous Material
2-0012727	54 Pawtucket Blvd	Tyngsboro	Oil
2-0013702	95 97 Westford Road	Tyngsboro	Hazardous Material

For more location information, please see the attached map. The map lists the release sites by Release Tracking Number (RTN).