

Appendix B

QuikMail

Page 1 of 1

Current Folder: **INBOX**
[Compose](#) [Addresses](#) [Folders](#) [Options](#) [Search](#) [Help](#) [Calendar](#)

Sign Out
Go to Quik Cop

[Message List](#) | [Delete](#)

[Previous](#) | [Next](#)

[Forward](#) | [Reply](#) | [Reply All](#)

Subject: RMV response

[View Full Header](#)
[View Printable Version](#)

From: poconnor@beverlyma.gov

Date: Sat, February 17, 2007 1:37 pm

To: north@quik.com

Priority: Normal

At 1222 on Thursday, February 15 2007, Beverly Firefighters responded to 176 Cabot St. for a report of a suspicious odor inside the building. Upon arrival, firefighters entered and evacuated the building. During the ensuing investigation, there was a faint odor which was attributed to the use of portable electric space heaters at employee workstations. As a precautionary measure, Deputy Chief Paul Cotter walked through the building, Registry section and basement, with a meter to check for carbon monoxide and hydrocarbons. Zero readings were received throughout building.

Peter O'Connor
Captain
Beverly Fire Department

[Download this as a file](#)

[Take Address](#)

FAX ATTN: ARIC WARRREN