

INDOOR AIR QUALITY ASSESSMENT

**Department of Revenue
90 Everett Avenue
Chelsea, MA**



Prepared by:
Massachusetts Department of Public Health
Bureau of Environmental Health
Indoor Air Quality Program
September 2016

Background

Building:	Department of Revenue (DOR)
Address:	90 Everett Avenue, Chelsea, MA
Assessment Requested by:	Joshua Martin, Deputy Director, Office of Facilities Management, Massachusetts DOR
Reason for Request:	Lease renewal IAQ status report
Date of Assessment:	September 14, 2016
Massachusetts Department of Public Health/Bureau of Environmental Health (MDPH/BEH) Staff Conducting Assessment:	Ruth Alfasso, Environmental Engineer/Inspector, IAQ Program
Building Description:	Four-story, flat-roofed building in an office park/mall area. DOR offices occupy the third and fourth floors of this building. The building has several other office tenants.
Building Population:	Approximately 150 employees over the two floors
Windows:	Not openable

Methods

Please refer to the IAQ Manual for methods, sampling procedures, and interpretation of results (MDPH, 2015).

IAQ Testing Results

The following is a summary of indoor air testing results (Table 1).

- **Carbon dioxide levels** were above 800 parts per million (ppm) in all areas assessed, indicating inadequate fresh air in the space.
- **Temperature** was within the recommended range of 70°F to 78°F in all areas assessed.
- **Relative humidity** was within the recommended range of 40% to 60% in all areas assessed.
- **Carbon monoxide** levels were non-detectable in all indoor areas assessed.

- *Fine particulate matter (PM2.5)* concentrations measured were below the National Ambient Air Quality Standard (NAAQS) level of 35 µg/m³ in all areas assessed.

Ventilation

A heating, ventilating, and air conditioning (HVAC) system has several functions. First, it provides heating and, if equipped, cooling. Second, it is a source of fresh air. Finally, an HVAC system will dilute and remove normally occurring indoor environmental pollutants by not only introducing fresh air, but also filtering the airstream and ejecting stale air to the outdoors via exhaust ventilation. Even if an HVAC system is operating as designed, point sources of respiratory irritation may exist and affect symptoms in sensitive individuals. The following analysis examines and identifies components of the HVAC system and likely sources of respiratory irritant/allergen exposure due to water damage, aerosolized dust, and/or chemicals found in the indoor environment.

Fresh air is provided by air handling units (AHUs) located on the roof. Air from the AHUs is filtered, heated/cooled, and delivered to rooms via ducted supply vents (Pictures 1 and 2). Air is returned/exhausted through vents in the ceiling (Picture 3).

The assessment results indicate that the ventilation system is not providing adequate fresh air for the occupancy in the building. At the time of the visit, air was flowing from supply vents, and the system appeared to be on in all areas examined. However the carbon dioxide readings, which ranged from 1,476 ppm to 1,716 ppm, were significantly and consistently elevated over the MDPH recommended level of 800 ppm. This indicates that the system is not bringing in sufficient fresh air during operation. The likely reasons for this involve the operation of the energy management system and the settings that determine the percent fresh air and recycled air that are being delivered to the supply vents. Fresh air dampers that are mechanically stuck closed may also lead to higher than optimal levels of carbon dioxide, however the results over the entire space are consistent, which means the cause is more likely overall system settings than a single fault.

It is recommended that HVAC systems be re-balanced every five years to ensure adequate air systems function (SMACNA, 1994). It is unknown when the last time this system was balanced.

Microbial/Moisture Concerns

A few water-damaged ceiling tiles were observed on the 4th floor. The damage appears to be from a condensation leak from a HVAC system component in the ceiling. The conditions causing the leak should be fixed, and the tiles should be replaced.

Plants were observed in office areas (Table 1; Pictures 4 and 5). Plants can be a source of pollen and mold, which can be respiratory irritants to some individuals. Plants should be properly maintained and equipped with drip pans to prevent water damage to porous materials. Plants should also be located away from air diffusers to prevent the aerosolization of dirt, pollen, and mold.

Small refrigerators and water dispensers were observed in carpeted areas (Picture 6). These appliances may spill or leak and lead to carpet damage and microbial growth. It is recommended that these appliances be located in areas without carpeting or on waterproof mats. Carpet squares could also be replaced with tile in areas where water dispensers and refrigerators are located.

One of the refrigerators in a break room had evidence of a spill inside (Picture 7). Refrigerators should be kept clean to prevent odors and microbial growth. One of the break room sink cabinet had water stains (Picture 8), which suggests that leaks or condensation is occurring. The area underneath sinks tends to be a moist environment, so storage of porous items or large amounts of items should be avoided. These areas should be checked periodically for leaks and dampness.

Plants and trees were observed very close to and touching the exterior of the building envelope (Picture 9). This can lead to deterioration of the building envelope due to root infiltration and dampness against the exterior surface. Plants can be a source of debris and pollen to air intakes. Plants should be trimmed away from the building and from overhanging the roof.

Other IAQ Evaluations

Exposure to low levels of total volatile organic compounds (TVOCs) may produce eye, nose, throat, and/or respiratory irritation in some sensitive individuals. To determine if VOCs were present, BEH/IAQ staff examined rooms for products containing VOCs. BEH/IAQ staff noted hand sanitizers, cleaners, and dry erase materials in use within the building (Picture 8;

Table 1). All of these products have the potential to be irritants to the eyes, nose, throat, and respiratory system of sensitive individuals.

The offices were mostly carpeted. Carpets should be cleaned annually (or semi-annually in soiled/high traffic areas) in accordance with Institute of Inspection, Cleaning and Restoration Certification (IICRC) recommendations, (IICRC, 2012).

In some areas, stored materials and accumulated items make it more difficult for custodial staff to clean. Items should be stored neatly and moved periodically to allow for wet wiping and vacuuming of surfaces.

Personal fans were observed in a number of areas. Fan blades to some of these units had settled dust, which can be reaerosolized when the fan is activated.

Conclusions/Recommendations

Based on observations at the time of assessment, the following is recommended:

1. Investigate the cause of high carbon dioxide readings, including adjustment of settings on the energy management for the HVAC system and operability of all dampers. The BEH/IAQ program can return on request to confirm that these adjustments have been successful.
2. Operate supply and exhaust ventilation in all areas during occupied periods.
3. Have the HVAC system balanced every 5 years in accordance with SMACNA recommendations (SMACNA, 1994).
4. Repair conditions leading to ceiling leaks and water-damaged ceiling tiles, and replace the tiles.
5. Keep indoor plants in good condition, avoid overwatering, and avoid placing them on porous items such as carpets or paper. Also, keep plants out of the air stream of supply vents.
6. Consider locating refrigerators and water dispensers in non-carpeted areas or place on a waterproof mat.
7. Clean refrigerator spills promptly and clean refrigerators out regularly to avoid odors and microbial growth.
8. Avoid storing porous items or large amounts of items under sinks.

9. For buildings in New England, periods of low relative humidity during the winter are often unavoidable. Therefore, scrupulous cleaning practices should be adopted to minimize common indoor air contaminants whose irritant effects can be enhanced when the relative humidity is low. To control for dusts, a high efficiency particulate arrestance (HEPA) filter equipped vacuum cleaner in conjunction with wet wiping of all surfaces is recommended. Avoid the use of feather dusters. Drinking water during the day can help ease some symptoms associated with a dry environment (throat and sinus irritations).
10. Reduce the use of cleaning products, sanitizers, and scented products.
11. Change filters on AHUs on a regular schedule at least twice a year.
12. Clean carpeting in accordance with IICRC recommendations (IICRC, 2012).
13. Reduce accumulated materials on flat surfaces and store in an organized manner to allow for thorough cleaning.
14. Clean the blades of personal fans periodically to avoid aerosolizing dusts.
15. Refer to resource manual and other related IAQ documents located on the MDPH's website for further building-wide evaluations and advice on maintaining public buildings. These documents are available at: <http://mass.gov/dph/iaq>.

References

IICRC. 2012. Institute of Inspection, Cleaning and Restoration Certification. Carpet Cleaning: FAQ. Retrieved from <http://www.iicrc.org/consumers/care/carpet-cleaning/#faq>.

MDPH. 2015. Massachusetts Department of Public Health. Indoor Air Quality Manual: Chapters I-III. Available at: <http://www.mass.gov/eohhs/gov/departments/dph/programs/environmental-health/exposure-topics/iaq/iaq-manual/>.

SMACNA. 1994. HVAC Systems Commissioning Manual. 1st ed. Sheet Metal and Air Conditioning Contractors' National Association, Inc., Chantilly, VA.

Picture 1



Air supply vent next to the windows

Picture 2




Supply vent

Picture 3



Typical exhaust vent

Picture 4



Plant drip pan in need of cleaning and undersized/overwatered

Picture 5



Plants in an office

Picture 6



Water cooler on carpet

Picture 7



Spills/stains in the refrigerator

Picture 8



Water stains and cleaning products under sink

Picture 9



Trees and bushes against the building exterior

Table 1

Location	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Temp (°F)	Relative Humidity (%)	PM2.5 (µg/m ³)	Occupants in Room	Windows Openable	Ventilation		Remarks
								Supply	Exhaust	
Background	347	ND	76	64	15					Sunny, light wind
4 th floor										
02 (cubes)	1569	ND	74	55	4	0	N	Y	Y	
10 (cubes)	1589	ND	74	57	4	1	N	Y	Y	
15 (cubes)	1614	ND	74	57	4	3	N	Y	Y	DEM, PC
17 (cubes)	1587	ND	74	57	4	2	N	Y	Y	
20 (cubes)	1578	ND	74	56	3	2	N	Y	Y	Plants
25 (cubes)	1712	ND	74	56	3	1	N	Y	Y	
27 (cubes)	1565	ND	75	55	3	1	N	Y	Y	Plants
29 (cubes)	1675	ND	74	56	4	1	N	Y	Y	

ppm = parts per million

AI = accumulated items

DEM = dry erase materials

NC = not carpeted

PF = personal fan

µg/m³ = micrograms per cubic meter

CP = cleaning products

HS = hand sanitizer

PC = photocopier

Comfort Guidelines

Carbon Dioxide: < 800 ppm = preferred
> 800 ppm = indicative of ventilation problems

Temperature: 70 - 78 °F
Relative Humidity: 40 - 60%

Table 1 (continued)

Location	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Temp (°F)	Relative Humidity (%)	PM2.5 (µg/m ³)	Occupants in Room	Windows Openable	Ventilation		Remarks
								Supply	Exhaust	
32 (cubes)	1702	ND	74	56	4	2	N	Y	y	
35 (cubes)	1679	ND	74	55	4	2	N	Y	Y	Stained carpet
39 (cubes)	1677	ND	74	56	4	2	N	Y	Y	
401	1580	ND	74	54	3	1	N	Y	Y	DEM
402	1545	ND	74	55	3	0	N	Y	Y	DEM, plant, food
403	1581	ND	74	55	4	1	N	Y	Y	DEM
404	1619	ND	74	54	3	0	N	Y	Y	DEM
405	1606	ND	74	55	4	1	N	Y	Y	DEM, recycling, plants
406	1589	ND	74	55	4	1	N	Y	Y	Plants, food
407	1586	ND	74	57	3	0	N	Y	Y	Plants, DEM

ppm = parts per million

AI = accumulated items

DEM = dry erase materials

NC = not carpeted

PF = personal fan

µg/m³ = micrograms per cubic meter

CP = cleaning products

HS = hand sanitizer

PC = photocopier

Comfort Guidelines

Carbon Dioxide: < 800 ppm = preferred
> 800 ppm = indicative of ventilation problems

Temperature: 70 - 78 °F
Relative Humidity: 40 - 60%

Table 1 (continued)

Location	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Temp (°F)	Relative Humidity (%)	PM2.5 (µg/m ³)	Occupants in Room	Windows Openable	Ventilation		Remarks
								Supply	Exhaust	
408	1602	ND	74	58	4	1	N	Y	Y	HS
409	1587	ND	73	57	3	2	N	Y	Y	DEM, plant
410	1572	ND	73	57	4	0	N	Y	Y	DEM
411	1602	ND	73	55	3	0	N	Y	Y	HS, PF, DEM
412	1550	ND	74	54	3	0	N	Y	Y	DEM, PF
413	1716	ND	74	55	5	0	N	Y	Y	DEM
414	1707	ND	74	56	4	2	N	Y	Y	DEM
415	1716	ND	74	55	3	0	N	Y	Y	DEM
416	1669	ND	75	56	4	1	N	Y	Y	DEM
42 (cubes)	1661	ND	74	56	4	1	N	Y	Y	

ppm = parts per million

AI = accumulated items

DEM = dry erase materials

NC = not carpeted

PF = personal fan

µg/m³ = micrograms per cubic meter

CP = cleaning products

HS = hand sanitizer

PC = photocopier

Comfort Guidelines

Carbon Dioxide: < 800 ppm = preferred
> 800 ppm = indicative of ventilation problems

Temperature: 70 - 78 °F
Relative Humidity: 40 - 60%

Table 1 (continued)

Location	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Temp (°F)	Relative Humidity (%)	PM2.5 (µg/m ³)	Occupants in Room	Windows Openable	Ventilation		Remarks
								Supply	Exhaust	
45 (cubes)	1687	ND	74	57	4	1	N	Y	Y	
48 (cubes)	1680	ND	74	57	4	6	N	Y	Y	
52 (cubes)	1634	ND	75	55	4	2	N	Y	Y	Solar gain, CP, food, AI
53 (cubes)	1590	ND	74	54	4	2	N	Y	Y	
54 (cubes)	1606	ND	74	57	6	3	N	Y	Y	Solar gain
55 (cubes)	1578	ND	73	55	3	0	N	Y	Y	DEM, plants
57 (cubes)	1577	ND	74	55	3	3	N	Y	Y	
64 (cubes)	1578	ND	75	55	3	4	N	Y	Y	
65 (cubes)	1630	ND	74	55	3	2	N	Y	Y	
Conference 2	1584	ND	73	55	3	2	N	Y	Y	

ppm = parts per million

AI = accumulated items

DEM = dry erase materials

NC = not carpeted

PF = personal fan

µg/m³ = micrograms per cubic meter

CP = cleaning products

HS = hand sanitizer

PC = photocopier

Comfort Guidelines

Carbon Dioxide: < 800 ppm = preferred
> 800 ppm = indicative of ventilation problems

Temperature: 70 - 78 °F
Relative Humidity: 40 - 60%

Table 1 (continued)

Location	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Temp (°F)	Relative Humidity (%)	PM2.5 (µg/m ³)	Occupants in Room	Windows Openable	Ventilation		Remarks
								Supply	Exhaust	
Kitchen	1587	ND	74	57	4	0	N	Y	Y	Exhaust appears to be direct, DEM, food, fridge, microwave, NC
Library	1553	ND	76	55	3	0	N	Y	Y	
Office (no number)	1574	ND	74	56	3	2	N	Y	Y	DEM
Training	1570	ND	74	54	4	0	N	Y	Y	DEM, computers
3 rd floor										
Kitchen	1511	ND	74	56	4	1	N	Y	Y	NC, dirty fridge, stains under sink
Ladies restroom							N	Y	Y	Cleaner odors
Training	1647	ND	74	54		2	N	Y	Y	
Conference 3-2	1566	ND	75	54	4	2	N	Y	Y	Water cooler on carpet
Conference 1	1559	ND	76	53	4	1	N	Y	Y	

ppm = parts per million

AI = accumulated items

DEM = dry erase materials

NC = not carpeted

PF = personal fan

µg/m³ = micrograms per cubic meter

CP = cleaning products

HS = hand sanitizer

PC = photocopier

Comfort Guidelines

Carbon Dioxide: < 800 ppm = preferred
> 800 ppm = indicative of ventilation problems

Temperature: 70 - 78 °F
Relative Humidity: 40 - 60%

Table 1 (continued)

Location	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Temp (°F)	Relative Humidity (%)	PM2.5 (µg/m ³)	Occupants in Room	Windows Openable	Ventilation		Remarks
								Supply	Exhaust	
Conference 3-1	1500	ND	73	58	4	3	N	Y	Y	Water cooler on carpet, DEM
04 (cubes)	1571	ND	75	54	3	2	N	Y	Y	Solar gain
08 (cubes)	1595	ND	74	54	4	0	N	Y	Y	Solar gain
15 (cubes)	1568	ND	74	55	4	1	N	Y	Y	
19 (cubes)	1571	ND	74	55	4	2	N	Y	Y	
22 (cubes)	1561	ND	74	55	4	1	N	Y	Y	Stained carpet
23 (cubes)	1526	ND	74	55	4	2	N	Y	Y	
33 (cubes)	1498	ND	74	56	4	1	N	Y	Y	Water cooler on carpet
43 (cubes)	1476	ND	75	55	4	3	N	Y	Y	Plant
62 (cubes)	1529	ND	73	56	4	1	N	Y	Y	

ppm = parts per million

AI = accumulated items

DEM = dry erase materials

NC = not carpeted

PF = personal fan

µg/m³ = micrograms per cubic meter

CP = cleaning products

HS = hand sanitizer

PC = photocopier

Comfort Guidelines

Carbon Dioxide: < 800 ppm = preferred
> 800 ppm = indicative of ventilation problems

Temperature: 70 - 78 °F
Relative Humidity: 40 - 60%

Table 1 (continued)

Location	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Temp (°F)	Relative Humidity (%)	PM2.5 (µg/m ³)	Occupants in Room	Windows Openable	Ventilation		Remarks
								Supply	Exhaust	
64 (cubes)	1532	ND	73	54	4	1	N	Y	Y	Plant
66 (cubes)	1554	ND	72	54	3	0	N	Y	Y	
76 (cubes)	1627	ND	76	53	4	1	N	Y	Y	
301	1555	ND	74	54	3	1	N	Y	Y	DEM
302	1567	ND	75	52	3	0	N	Y	Y	DEM
304	1588	ND	76	53	3	2	N	Y	Y	DEM
305	1570	ND	76	53	3	2	N	Y	Y	Big tree outside
306	1656	ND	76	53	4	1	N	Y	Y	DEM
307	1589	ND	74	55	4	1	N	Y	Y	DEM, soda cans
308	1599	ND	74	54	4	1	N	Y	Y	

ppm = parts per million

AI = accumulated items

DEM = dry erase materials

NC = not carpeted

PF = personal fan

µg/m³ = micrograms per cubic meter

CP = cleaning products

HS = hand sanitizer

PC = photocopier

Comfort Guidelines

Carbon Dioxide: < 800 ppm = preferred
> 800 ppm = indicative of ventilation problems

Temperature: 70 - 78 °F
Relative Humidity: 40 - 60%

Table 1 (continued)

Location	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Temp (°F)	Relative Humidity (%)	PM2.5 (µg/m ³)	Occupants in Room	Windows Openable	Ventilation		Remarks
								Supply	Exhaust	
309	1597	ND	74	54	4	1	N	Y	Y	DEM
310	1614	ND	74	54	4	0	N	Y	Y	
311	1593	ND	74	54	4	2	N	Y	Y	
312	1523	ND	74	56	4	1	N	Y	Y	
315	1496	ND	74	55	3	0	N	Y	Y	DEM
316	1487	ND	74	56	3	0	N	Y	Y	DEM

ppm = parts per million

AI = accumulated items

DEM = dry erase materials

NC = not carpeted

PF = personal fan

µg/m³ = micrograms per cubic meter

CP = cleaning products

HS = hand sanitizer

PC = photocopier

Comfort Guidelines

Carbon Dioxide: < 800 ppm = preferred
> 800 ppm = indicative of ventilation problems

Temperature: 70 - 78 °F
Relative Humidity: 40 - 60%