

# Appendix A

## Carbon Dioxide and its Use in Evaluating Adequacy of Ventilation in Buildings

The Bureau of Environmental Health's (BEH) Indoor Air Quality (IAQ) Program examines indoor air quality conditions that may have an effect on building occupants. The status of the ventilation system, potential moisture problems/microbial growth and identification of respiratory irritants are examined in detail, which are described in the attached report. In order to examine the function of the ventilation system, measurements for carbon dioxide, temperature and relative humidity are taken. Carbon dioxide measurements are commonly used to assess the adequacy of ventilation within an indoor environment.

Carbon dioxide is an odorless, colorless gas. It is found naturally in the environment and is produced in the respiration process of living beings. Another source of carbon dioxide is the burning of fossil fuels. Carbon dioxide concentration in the atmosphere is approximately 250-600 ppm (Beard, 1982; NIOSH, 1987).

Carbon dioxide measurements within an occupied building are a standard method used to gauge the adequacy of ventilation systems. Carbon dioxide is used in this process for a number of reasons. Any occupied building will have normally occurring environmental pollutants in its interior. Human beings produce waste heat, moisture and carbon dioxide as by-products of the respiration process. Equipment, plants, cleaning products or supplies normally found in any building can produce gases, vapors, fumes or dusts when in use. If a building has an adequately operating mechanical ventilation system, these normally occurring environmental pollutants will be diluted and removed from the interior of the building. The introduction of fresh air both increases the comfort of the occupants and serves to dilute normally occurring environmental pollutants.

## Appendix A

An operating exhaust ventilation system physically removes air from a room and thereby removes environmental pollutants. The operation of supply in conjunction with the exhaust ventilation system creates airflow through a room, which increases the comfort of the occupants. If all or part of the ventilation system becomes non-functional, a build up of normally occurring environmental pollutants may occur, resulting in an increase in the discomfort of occupants.

The MDPH approach to resolving indoor air quality problems in schools and public buildings is generally two-fold: 1) improving ventilation to dilute and remove environmental pollutants and 2) reducing or eliminating exposure opportunities from materials that may be adversely affecting indoor air quality. In the case of an odor complaint of unknown origin, it is common for BEH staff to receive several descriptions from building occupants. A description of odor is subjective, based on the individual's life experiences and perception. Rather than test for a potential series of thousands of chemicals to identify the unknown material, carbon dioxide is used to judge the adequacy of airflow as it both dilutes and removes indoor air environmental pollutants.

As previously mentioned, carbon dioxide is used as a diagnostic tool to evaluate air exchange by building ventilation systems. The presence of increased levels of carbon dioxide in indoor air of buildings is attributed to occupancy. As individuals breathe, carbon dioxide is exhaled. The greater the number of occupants, the greater the amount of carbon dioxide produced. Carbon dioxide concentration build up in indoor environments is attributed to inefficient or non-functioning ventilation systems. The Occupational Safety and Health Administration (OSHA) standard for carbon dioxide is 5,000 parts per million parts of air (ppm). Workers may be exposed to this level for 40 hours/week, based on a time-weighted average (OSHA, 1997).

# Appendix A

Carbon dioxide can be a hazard within enclosed areas with **no air supply**. These types of enclosed areas are known as confined spaces. Manholes, mines and sewer systems are examples of confined spaces. An ordinary building is not considered a confined space. Carbon dioxide air exposure limits for employees and the general public have been established by a number of governmental health and industrial safety groups. Each of these standards of air concentrations is expressed in parts per million (ppm). *Table 1* is a listing of carbon dioxide air concentrations and related health effects and standards.

The MDPH uses a guideline of 800 ppm for publicly occupied buildings (Burge et al., 1990; Gold, 1992; Norback, 1990; OSHA, 1994; Redlich, 1997; Rosenstock, 1996; SMACNA, 1998). A guideline of 600 ppm or less is preferred in schools due to the fact that the majority of occupants are young and considered to be a more sensitive population in the evaluation of environmental health status. Several sources indicate that indoor air problems *are significantly reduced* at 600 ppm or less of carbon dioxide (ACGIH, 1998; Bright et al., 1992; Hill, 1992; NIOSH, 1987). Inadequate ventilation and/or elevated temperatures are major causes of complaints such as respiratory, eye, nose and throat irritation, lethargy and headaches.

Air levels for carbon dioxide that indicate that indoor air quality may be a problem have been established by the American Society of Heating, Refrigerating and Air-conditioning Engineers (ASHRAE). Above 1,000 ppm of carbon dioxide, ASHRAE recommends adjustment of the building's ventilation system (ASHRAE, 1989). In 2001, ASHRAE modified their standard to indicate that no more than 700 ppm above the outdoor air concentration; however 800 ppm is the level where further investigation will occur.

Carbon dioxide itself has no acute (short-term) health effects associated with low level exposure (below 5,000 ppm). The main effect of carbon dioxide involves its ability to displace

# Appendix A

oxygen for the air in a confined space. As oxygen is inhaled, carbon dioxide levels build up in the confined space, with a decrease in oxygen content in the available air. This displacement of oxygen makes carbon dioxide a simple asphyxiant. At carbon dioxide levels of 30,000 ppm, severe headaches, diffuse sweating, and labored breathing have been reported. No **chronic** health effects are reported at air levels below 5,000 ppm.

Air testing is one method used to determine whether carbon dioxide levels exceed the comfort levels recommended. If carbon dioxide levels are over 800-1,000 ppm, the MDPH recommends adjustment of the building's ventilation system. The MDPH recommends that corrective measures be taken at levels above 800 ppm of carbon dioxide in office buildings or schools. (Please note that carbon dioxide levels measured below 800 ppm may not decrease indoor air quality complaints). Sources of environmental pollutants indoors can often induce symptoms in exposed individuals regardless of the adequacy of the ventilation system. As an example, an idling bus outside a building may have minimal effect on carbon dioxide levels, but can be a source of carbon monoxide, particulates and odors via the ventilation system.

Therefore, the MDPH strategy of adequate ventilation coupled with pollutant source reduction/removal serves to improve indoor air quality in a building. Please note that each table included in the IAQ assessment lists BEH comfort levels for carbon dioxide levels at the bottom (i.e. carbon dioxide levels between 600 ppm to 800 ppm are acceptable and <600 ppm is preferable). While carbon dioxide levels are important, focusing on these air measurements in isolation to all other recommendations is a misinterpretation of the recommendations made in these assessments.

# Appendix A

**Table 1: Carbon Dioxide Air Level Standards**

Carbon Dioxide Level	Health Effects	Standards or Use of Concentration	Reference
250-600 ppm	None	Concentrations in ambient air	Beard, R.R., 1982 NIOSH, 1987
600 ppm	None	Few indoor air complaints, used as reference for air exchange for protection of children	ACGIH, 1998; Bright et al., 1992; Hill, 1992; NIOSH 1987
800 ppm	None	Used as an indicator of ventilation adequacy in schools and public buildings, used as reference for air exchange for protection of children	Mendler, 2003 Bell, A. A., 2000; NCOSP, 1998; SMACNA, 1998; EA, 1997; Redlich, 1997; Rosenstock, 1996; OSHA, 1994; Gold, 1992; Burge et al., 1990; Norback, 1990 ; IDPH, Unknown
1000 ppm	None	Used as an indicator of ventilation inadequacy concerning removal of odors from the interior of building.	ASHRAE, 1989
950-1300 ppm*	None	Used as an indicator of ventilation inadequacy concerning removal of odors from the interior of building.	ASHRAE, 1999
700 ppm (over background)	None	Used as an indicator of ventilation inadequacy concerning removal of odors from the interior of building.	ASHRAE, 2001
5000 ppm	No acute (short term) or chronic (long-term) health effects	Permissible Exposure Limit/Threshold Limit Value	ACGIH, 1999 OSHA, 1997
30,000 ppm	Severe headaches, diffuse sweating, and labored breathing	Short-term Exposure Limit	ACGIH, 1999 ACGIH. 1986

\* outdoor carbon dioxide measurement +700 ppm

# Appendix A

## References

- ACGIH. 1986. Documentation of the Threshold Limit Values. American Conference of Governmental Industrial Hygienists. Cincinnati, OH.
- ACGIH. 1998. Industrial Ventilation A Manual of Recommended Practice. 23rd Edition. American Conference of Governmental Industrial Hygienists. Cincinnati, OH.
- ACGIH. 1999. Guide to Occupational Exposures-1999. American Conference of Governmental Industrial Hygienists, Cincinnati, OH.
- ASHRAE. 1989. Ventilation for Acceptable Indoor Air Quality. American Society of Heating, Refrigeration and Air Conditioning Engineers. ANSI/ASHRAE 62-1989.
- ASHRAE. 1999. Ventilation for Acceptable Indoor Air Quality. American Society of Heating, Refrigeration and Air Conditioning Engineers. ANSI/ASHRAE 62-1999.
- ASHRAE. 2001. Ventilation for Acceptable Indoor Air Quality. American Society of Heating, Refrigeration and Air Conditioning Engineers. ANSI/ASHRAE 62-2001.
- Beard, R.R. 1982. Chapter Fifty-two, Inorganic Compounds of Oxygen, Nitrogen, and Carbon. *Patty's Industrial Hygiene and Toxicology, Vol. IIC. 3rd ed.* Clayton, G. D. & Clayton, F. E., eds. John Wiley & Sons, New York, NY.
- Bright, P.; Mader, M.; Carpenter, D.; and Hermon-Cruz, I.Z. 1992. Guideline for Indoor Air Surveys. Brooks Air Force Base, TX. Armstrong Laboratory, Occupational and Environmental Health Directorate. NTIS AL-TR-1992-0016.
- Burge, H. and Hoyer, M. 1990. Focus On ... Indoor Air Quality. *Appl. Occup. Environ. Hyg.* 5(2):88.
- EA. 1997. Indoor Air Quality. Environment Australia, Department of the Environment, Sport and Territories, Canberra, Australia.  
<http://laptop.deh.gov.au/soe/1996/publications/technical/pubs/12indora.pdf>
- Gold, D. 1992. Indoor Air Pollution. *Clinics in Chest Medicine.* 13(2):224-225.
- Hill, B.; Craft, B.; and Burkart, J. 1992. Carbon Dioxide, Particulates and Subjective Human Responses in Office Buildings without Histories of Indoor Air Quality Problems. *Appl. Occup. Environ. Hyg.* 7(2): 101-111.
- IDPH. Unknown. Illinois Department of Public Health Guidelines for Indoor Air Quality. Illinois Department of Public Health, Springfield, IL.  
[http://www.idph.state.il.us/envhealth/factsheets/indoorairqualityguide\\_fs.htm](http://www.idph.state.il.us/envhealth/factsheets/indoorairqualityguide_fs.htm)
- Mendler, S. and Odell, W. 2003. Indoor Air Quality for the EPA. *ArchitectureWeek.* April 16, 2003. [http://www.architectureweek.com/2003/0416/environment\\_1-2.html](http://www.architectureweek.com/2003/0416/environment_1-2.html)

# Appendix A

NCOSP. 1998. Workplace Requirements for Safety & Health, Indoor Air Quality 3.3.3. NC Office of State Personnel, Raleigh, NC.

<http://www.oshr.nc.gov/Support/Safety/safetyhandbook.pdf>

NIOSH. 1987. Guidance for Indoor Air Quality Investigations. Cincinnati, OH. National Institute for Occupational Safety and Health, Hazards Evaluations and Technical Assistance Branch, Division of Surveillance, Hazard Evaluation and Field Studies.

Norback, D.; Torgen, M.; and Edling, C. 1990. Volatile Organic Compounds, Respirable Dust, and Personal Factors Related to Prevalence and Incidence of Sick Building Syndrome in Primary Schools. *British Journal of Industrial Medicine*. 47:740.

OSHA. 1994. Occupational Safety and Health Administration. Indoor Air Quality (Proposed Regulation), *Federal Register* 59:15968-16039, (1994) Appendix A.

OSHA. 1997. Limits for Air Contaminants. Occupational Safety and Health Administration. Code of Federal Regulations. 29 C.F.R 1910.1000 Table Z-1-A.

Redlich, C.; Sparer, J.; and Cullen, M. 1997. Sick-building Syndrome. *Lancet*. 349:1016.

Rosenstock, L. 1996. NIOSH Testimony to the U.S. Department of Labor on Air Quality, *Appl. Occup. Environ. Hyg.* 11(12):1368.

SMACNA. 1998. Indoor Air Quality: A Systems Approach. 3<sup>rd</sup> ed. Sheet Metal and Air Conditioning Contractors' National Association, Inc, Chantilly, VA. National Association, Inc.