

**Summary of Tritium Detected in Surface Water Samples
through June 30, 2016**

Pilgrim Nuclear Power Station

Plymouth, MA

Sample Collection Date	Reported By	Tritium Concentration (pCi/L)	
		North of MW 205 (Intake)	Surface Water Inlet at Boat Ramp
July 7, 2010	Energy	<402	<402
	MDPH/MERL	<300	<300
July 26, 2010	Energy	<339	<340
	MDPH/MERL	<300	<300
August 2, 2010	Energy	<466	<466
	MDPH/MERL	<300	<300
August 9, 2010	Energy	<316	<314
	MDPH/MERL	***	***
August 26, 2010	Energy	<343	<347
	MDPH/MERL	***	***
August 30, 2010	Energy	<320	<319
	MDPH/MERL	***	***
September 7/8, 2010	Energy	<328	<326
	MDPH/MERL	<300	<300
September 13, 2010	Energy	<378	<374
	MDPH/MERL	***	***
September 20/21, 2010	Energy	<393	<389
	MDPH/MERL	***	***
September 28/29, 2010	Energy	<309	<311
	MDPH/MERL	***	***
October 4, 2010	Energy	<303	<305
	MDPH/MERL	<300	<300
October 13, 2010	Energy	<346	<343
	MEPH/MERL	***	***
October 18, 2010	Energy	<325	<325
	MDPH/MERL	<300	<300
November 1, 2010	Energy	<339	<312
	MDPH/MERL	<300	<300
November 16, 2010	Energy	<301	<305
	MDPH/MERL***		
November 22, 2010	Energy	<319	<319
	MDPH/MERL***		

< = Not detected above the detection limit shown. MERL's lower detection limit is 300 pCi/L.

**Summary of Tritium Detected in Surface Water Samples
through June 30, 2016**

Pilgrim Nuclear Power Station

Plymouth, MA

Sample Collection Date	Reported By	Tritium Concentration (pCi/L)	
		North of MW 205 (Intake)	Surface Water Inlet at Boat Ramp
November 30, 2010	Entergy MDPH/MERL ***	<317	<398
December 9, 2010	Entergy MDPH/MERL	<418 <300	<416 <300
December 15, 2010	Entergy MDPH/MERL ***	<354	<371
January 4, 2011	Entergy MDPH/MERL	<313 <300	<338 <300
March 2, 2011	Entergy MDPH/MERL	<399 <300	<325 <300
March 29, 2011	Entergy MDPH/MERL	<328 <300	<327 <300
April 27, 2011	Entergy MDPH/MERL	<390 <300	<389 <300
May 25, 2011	Entergy MDPH/MERL	<372 <300	<379 <300
June 21, 2011	Entergy MDPH/MERL	<318 <300	<319 <300
July 19, 2011	Entergy MDPH/MERL	<306 <300	No Sample No Sample
August 16, 2011	Entergy MDPH/MERL	<377 <300	No Sample No Sample
September 13, 2011	Entergy MDPH/MERL	<375 <300	No Sample No Sample
October 11, 2011	Entergy MDPH/MERL	<300 <300	No Sample No Sample
November 8, 2011	Entergy MDPH/MERL	<400 <300	No Sample No Sample
February 7, 2012	Entergy MDPH/MERL	<414 <300	No Sample No Sample
February 21, 2012	Entergy MDPH/MERL	<333 <300	No Sample No Sample

< = Not detected above the detection limit shown. MERL's lower detection limit is 300 pCi/L.

**Summary of Tritium Detected in Surface Water Samples
through June 30, 2016**

Pilgrim Nuclear Power Station

Plymouth, MA

Sample Collection Date	Reported By	Tritium Concentration (pCi/L)	
		North of MW 205 (Intake)	Surface Water Inlet at Boat Ramp
March 6, 2012	Entergy	<373	No Sample
	MDPH/MERL	<300	No Sample
March 20, 2012	Entergy	<411	No Sample
	MDPH/MERL	<300	No Sample
April 3, 2012	Entergy	<385	No Sample
	MDPH/MERL	<300	No Sample
April 17, 2012	Entergy	<346	No Sample
	MDPH/MERL	<300	No Sample
May 9, 2012	Entergy	<388	No Sample
	MDPH/MERL	<300	No Sample
May 21, 2012	Entergy	<405	No Sample
	MDPH/MERL	<300	No Sample
May 25, 2012	Entergy	<428	No Sample
	MDPH/MERL	<300	No Sample
June 26, 2012	Entergy	No Sample	<419
	MDPH/MERL	No Sample	<300
July 23, 2012	Entergy	< 419	No Sample
	MDPH/MERL	< 300	No Sample
August 6, 2012	Entergy	< 398	No Sample
	MDPH/MERL	< 300	No Sample
August 20, 2012	Entergy	< 364	No Sample
	MDPH/MERL	< 300	No Sample
September 10, 2012	Entergy	< 333	No Sample
	MDPH/MERL	< 300	No Sample
September 17, 2012	Entergy	< 351	No Sample
	MDPH/MERL	< 300	No Sample
October 1, 2012	Entergy	< 419	No Sample
	MDPH/MERL	< 300	No Sample
October 15, 2012	Entergy	< 359	No Sample
	MDPH/MERL	< 300	No Sample
October 22, 2012	Entergy	< 356	< 397
	MDPH/MERL	< 300	< 300

< = Not detected above the detection limit shown. MERL's lower detection limit is 300 pCi/L.

**Summary of Tritium Detected in Surface Water Samples
through June 30, 2016**

Pilgrim Nuclear Power Station

Plymouth, MA

Sample Collection Date	Reported By	Tritium Concentration (pCi/L)	
		North of MW 205 (Intake)	Surface Water Inlet at Boat Ramp
October 29, 2012	Entergy	< 352	No Sample
	MDPH/MERL	< 300	No Sample
November 12, 2012	Entergy	< 377	< 391
	MDPH/MERL	< 300	< 300
November 26, 2012	Entergy	< 371	No Sample
	MDPH/MERL	< 300	No Sample
December 10, 2012	Entergy	< 381	No Sample
	MDPH/MERL	< 300	No Sample
December 24, 2012	Entergy	< 329	No Sample
	MDPH/MERL	< 300	No Sample
January 7, 2013	Entergy	< 346	No Sample
	MDPH/MERL	< 300	No Sample
January 21, 2013	Entergy	< 365	No Sample
	MDPH/MERL	< 300	No Sample
February 4, 2013	Entergy	< 439	No Sample
	MDPH/MERL	< 300	No Sample
February 18, 2013	Entergy	< 421	< 425
	MDPH/MERL	< 300	< 300
March 11, 2013	Entergy	< 408	No Sample
	MDPH/MERL	< 300	No Sample
March 18, 2013	Entergy	< 373	No Sample
	MDPH/MERL	< 300	No Sample
April 1, 2013	Entergy	< 343	No Sample
	MDPH/MERL	< 300	No Sample
April 15, 2013	Entergy	< 333	No Sample
	MDPH/MERL	< 300	No Sample
April 29, 2013	Entergy	< 336	No Sample
	MDPH/MERL	< 300	No Sample
May 13, 2013	Entergy	< 413	< 432
	MDPH/MERL	< 300	< 300

< = Not detected above the detection limit shown. MERL's lower detection limit is 300 pCi/L.

**Summary of Tritium Detected in Surface Water Samples
through June 30, 2016**

Pilgrim Nuclear Power Station

Plymouth, MA

Sample Collection Date	Reported By	Tritium Concentration (pCi/L)	
		North of MW 205 (Intake)	Surface Water Inlet at Boat Ramp
May 27, 2013	Entergy	< 376	No Sample
	MDPH/MERL	< 300	No Sample
June 10, 2013	Entergy	< 348	No Sample
	MDPH/MERL	< 300	No Sample
June 24, 2013	Entergy	< 351	No Sample
	MDPH/MERL	< 300	No Sample
July 8, 2013	Entergy	< 333	No Sample
	MDPH/MERL	< 300	No Sample
July 22, 2013	Entergy	< 414	No Sample
	MDPH/MERL	< 300	No Sample
August 5, 2013	Entergy	< 357	No Sample
	MDPH/MERL	< 300	No Sample
August 19, 2013	Entergy	< 351	No Sample
	MDPH/MERL	< 300	No Sample
August 26, 2013	Entergy	< 384	< 360
	MDPH/MERL	< 300	< 300
September 2, 2013	Entergy	< 438	No Sample
	MDPH/MERL	< 300	No Sample
September 16, 2013	Entergy	< 436	No Sample
	MDPH/MERL	< 300	No Sample
September 30, 2013	Entergy	< 356	No Sample
	MDPH/MERL	Unable to Analyze	No Sample
October 14, 2013	Entergy	< 379	No Sample
	MDPH/MERL	< 300	No Sample
October 28, 2013	Entergy	< 356	No Sample
	MDPH/MERL	< 300	No Sample
November 4, 2013	Entergy	No Sample	< 356
	MDPH/MERL	No Sample	< 300
November 11, 2013	Entergy	< 361	No Sample
	MDPH/MERL	< 300	No Sample
November 25, 2013	Entergy	< 308	No Sample
	MDPH/MERL	< 300	No Sample

< = Not detected above the detection limit shown. MERL's lower detection limit is 300 pCi/L.

**Summary of Tritium Detected in Surface Water Samples
through June 30, 2016**

Pilgrim Nuclear Power Station

Plymouth, MA

Sample Collection Date	Reported By	Tritium Concentration (pCi/L)	
		North of MW 205 (Intake)	Surface Water Inlet at Boat Ramp
December 9, 2013	Entergy	< 366	No Sample
	MDPH/MERL	< 300	No Sample
December 23, 2013	Entergy ***		No Sample
	MDPH/MERL	< 300	No Sample
January 6, 2014	Entergy	< 379	No Sample
	MDPH/MERL	< 300	No Sample
January 13, 2014	Entergy	< 347	No Sample
	MDPH/MERL	< 300	No Sample
January 20, 2014	Entergy	< 348	No Sample
	MDPH/MERL	< 300	No Sample
February 3, 2014	Entergy	< 404	No Sample
	MDPH/MERL	< 300	No Sample
February 10, 2014	Entergy	< 361	< 370
	MDPH/MERL	< 300	< 300
February 17, 2014	Entergy	< 376	No Sample
	MDPH/MERL	< 300	No Sample
February 24, 2014	Entergy	< 337	No Sample
	MDPH/MERL	< 300	No Sample
March 3, 2014	Entergy	< 355	No Sample
	MDPH/MERL	< 300	No Sample
March 10, 2014	Entergy	< 351	No Sample
	MDPH/MERL	< 300	No Sample
March 17, 2014	Entergy	< 329	No Sample
	MDPH/MERL	< 300	No Sample
March 24, 2014	Entergy	< 311	No Sample
	MDPH/MERL	< 300	No Sample
March 31, 2014	Entergy	< 367	No Sample
	MDPH/MERL	< 300	No Sample
April 7, 2014	Entergy	< 353	No Sample
	MDPH/MERL	< 300	No Sample

< = Not detected above the detection limit shown. MERL's lower detection limit is 300 pCi/L.

**Summary of Tritium Detected in Surface Water Samples
through June 30, 2016**

Pilgrim Nuclear Power Station

Plymouth, MA

Sample Collection Date	Reported By	Tritium Concentration (pCi/L)	
		North of MW 205 (Intake)	Surface Water Inlet at Boat Ramp
April 14, 2014	Entergy	< 332	No Sample
	MDPH/MERL	< 300	No Sample
April 21, 2014	Entergy	< 352	No Sample
	MDPH/MERL	< 300	No Sample
April 28, 2014	Entergy	< 316	No Sample
	MDPH/MERL	< 300	No Sample
May 5, 2014	Entergy	< 317	No Sample
	MDPH/MERL	< 300	No Sample
May 12, 2014	Entergy	< 343	< 368
	MDPH/MERL	< 300	< 300
May 19, 2014	Entergy	< 364	No Sample
	MDPH/MERL	< 300	No Sample
May 26, 2014	Entergy	< 370	No Sample
	MDPH/MERL	< 300	No Sample
June 2, 2014	Entergy	< 345	No Sample
	MDPH/MERL	< 300	No Sample
June 12, 2014	Entergy	<378	No Sample
	MDPH/MERL	<300	No Sample
June 16, 2014	Entergy	<336	No Sample
	MDPH/MERL	<300	No Sample
June 25, 2014	Entergy	<341	No Sample
	MDPH/MERL	<300	No Sample
June 30, 2014	Entergy	<412	No Sample
	MDPH/MERL	<300	No Sample
July 7, 2014	Entergy	<416	No Sample
	MDPH/MERL	<300	No Sample
July 14, 2014	Entergy	<405	No Sample
	MDPH/MERL	<300	No Sample
July 21, 2014	Entergy	<396	No Sample
	MDPH/MERL	<300	No Sample
July 28, 2014	Entergy	<386	No Sample
	MDPH/MERL	<300	No Sample

< = Not detected above the detection limit shown. MERL's lower detection limit is 300 pCi/L.

**Summary of Tritium Detected in Surface Water Samples
through June 30, 2016**

Pilgrim Nuclear Power Station

Plymouth, MA

Sample Collection Date	Reported By	Tritium Concentration (pCi/L)	
		North of MW 205 (Intake)	Surface Water Inlet at Boat Ramp
August 4, 2014	Entergy	<383	No Sample
	MDPH/MERL	<300	No Sample
August 11, 2014	Entergy	<366	No Sample
	MDPH/MERL	<300	No Sample
August 19, 2014	Entergy	<363	No Sample
	MDPH/MERL	<300	No Sample
August 25, 2014	Entergy	<372	No Sample
	MDPH/MERL	<300	No Sample
September 2, 2014	Entergy	<400	No Sample
	MDPH/MERL	<300	No Sample
September 9, 2014	Entergy	<312	No Sample
	MDPH/MERL	<300	No Sample
September 15, 2014	Entergy	<375	No Sample
	MDPH/MERL	<300	No Sample
September 22, 2014	Entergy	<386	No Sample
	MDPH/MERL	<300	No Sample
September 29, 2014	Entergy	<416	No Sample
	MDPH/MERL	<300	No Sample
October 6, 2014	Entergy	No Sample	<427
	MDPH/MERL	No Sample	<300
October 10, 2014	Entergy	<388	No Sample
	MDPH/MERL	<300	No Sample
October 13, 2014	Entergy	<351	No Sample
	MDPH/MERL	305	No Sample
October 24, 2014	Entergy	<390	No Sample
	MDPH/MERL	<300	No Sample
October 28, 2014	Entergy	<391	No Sample
	MDPH/MERL	<300	No Sample
November 7, 2014	Entergy	<390	No Sample
	MDPH/MERL	<300	No Sample
November 10, 2014	Entergy	<361	No Sample
	MDPH/MERL	<300	No Sample

< = Not detected above the detection limit shown. MERL's lower detection limit is 300 pCi/L.

**Summary of Tritium Detected in Surface Water Samples
through June 30, 2016**

Pilgrim Nuclear Power Station

Plymouth, MA

Sample Collection Date	Reported By	Tritium Concentration (pCi/L)	
		North of MW 205 (Intake)	Surface Water Inlet at Boat Ramp
November 19, 2014	Entergy	<382	No Sample
	MDPH/MERL	<300	No Sample
November 21, 2014	Entergy	No Sample	<386
	MDPH/MERL	No Sample	<300
November 24, 2014	Entergy	<391	No Sample
	MDPH/MERL	<300	No Sample
December 1, 2014	Entergy	<360	No Sample
	MDPH/MERL	<300	No Sample
December 8, 2014	Entergy	<397	No Sample
	MDPH/MERL	<300	No Sample
December 15, 2014	Entergy	<396	No Sample
	MDPH/MERL	<300	No Sample
December 22, 2014	Entergy	<358	No Sample
	MDPH/MERL	<300	No Sample
December 29, 2014	Entergy	<354	No Sample
	MDPH/MERL	<300	No Sample
January 5, 2015	Entergy	<351	No Sample
	MDPH/MERL	<300	No Sample
January 12, 2015	Entergy	<349	No Sample
	MDPH/MERL	<300	No Sample
January 19, 2015	Entergy	<356	No Sample
	MDPH/MERL	<300	No Sample
February 1, 2015	Entergy	<352	No Sample
	MDPH/MERL	<300	No Sample
February 5, 2015	Entergy	<345	No Sample
	MDPH/MERL	<300	No Sample
February 10, 2015	Entergy	<408	No Sample
	MDPH/MERL	<300	No Sample
February 17, 2015	Entergy	<426	No Sample
	MDPH/MERL	<300	No Sample
February 27, 2015	Entergy	<400	No Sample
	MDPH/MERL	<300	No Sample

< = Not detected above the detection limit shown. MERL's lower detection limit is 300 pCi/L.

**Summary of Tritium Detected in Surface Water Samples
through June 30, 2016**

Pilgrim Nuclear Power Station

Plymouth, MA

Sample Collection Date	Reported By	Tritium Concentration (pCi/L)	
		North of MW 205 (Intake)	Surface Water Inlet at Boat Ramp
March 2, 2015	Entergy MDPH/MERL	<388 <300	No Sample No Sample
March 9, 2015	Entergy MDPH/MERL	<401 <300	No Sample No Sample
March 20, 2015	Entergy MDPH/MERL	<382 <300	No Sample No Sample
March 23, 2015	Entergy MDPH/MERL	<364 <300	No Sample No Sample
April 2, 2015	Entergy MDPH/MERL	<361 <300	<363 <300
April 6, 2015	Entergy MDPH/MERL	<309 <300	No Sample No Sample
April 16, 2015	Entergy MDPH/MERL	<308 <300	No Sample No Sample
April 20, 2015	Entergy MDPH/MERL	<340 <300	No Sample No Sample
April 27, 2015	Entergy MDPH/MERL	<345 <300	No Sample No Sample
May 4, 2015	Entergy MDPH/MERL	<245 <300	No Sample No Sample
May 11, 2015	Entergy MDPH/MERL	<285 <300	No Sample No Sample
May 18, 2015	Entergy MDPH/MERL	<281 <300	No Sample No Sample
May 25, 2015	Entergy MDPH/MERL	<315 <300	No Sample No Sample
June 1, 2015	Entergy MDPH/MERL	<317 <300	No Sample No Sample
June 8, 2015	Entergy MDPH/MERL	<339 <300	No Sample No Sample

< = Not detected above the detection limit shown. MERL's lower detection limit is 300 pCi/L.

**Summary of Tritium Detected in Surface Water Samples
through June 30, 2016**

Pilgrim Nuclear Power Station

Plymouth, MA

Sample Collection Date	Reported By	Tritium Concentration (pCi/L)	
		North of MW 205 (Intake)	Surface Water Inlet at Boat Ramp
June 15, 2015	Entergy	<327	<330
	MDPH/MERL	<300	<300
June 24, 2015	Entergy	<311	No Sample
	MDPH/MERL	<300	No Sample
June 29, 2015	Entergy	<332	No Sample
	MDPH/MERL	<300	No Sample
July 6, 2015	Entergy	<336	No Sample
	MDPH/MERL	<300	No Sample
July 14, 2015	Entergy	<333	No Sample
	MDPH/MERL	<300	No Sample
July 20, 2015	Entergy	<319	No Sample
	MDPH/MERL	<300	No Sample
July 27, 2015	Entergy	<348	No Sample
	MDPH/MERL	<300	No Sample
August 3, 2015	Entergy	<183	No Sample
	MDPH/MERL	<300	No Sample
August 10, 2015	Entergy	<319	No Sample
	MDPH/MERL	<300	No Sample
August 17, 2015	Entergy	<325	No Sample
	MDPH/MERL	<300	No Sample
08/25/15	Entergy	<338	No Sample
	MDPH/MERL		No Sample
08/31/15	Entergy	<342	No Sample
	MDPH/MERL	<300	No Sample
09/11/15	Entergy	<341	No Sample
	MDPH/MERL	<300	No Sample
09/14/15	Entergy	<338	No Sample
	MDPH/MERL	<300	No Sample
09/23/15	Entergy	<339	No Sample
	MDPH/MERL	<300	No Sample

< = Not detected above the detection limit shown. MERL's lower detection limit is 300 pCi/L.

**Summary of Tritium Detected in Surface Water Samples
through June 30, 2016**

Pilgrim Nuclear Power Station

Plymouth, MA

Sample Collection Date	Reported By	Tritium Concentration (pCi/L)	
		North of MW 205 (Intake)	Surface Water Inlet at Boat Ramp
09/28/15	Energys	<317	No Sample
	MDPH/MERL	<300	No Sample
10/08/15	Energys	<323	No Sample
	MDPH/MERL	<300	No Sample
10/15/15	Energys	<336	No Sample
	MDPH/MERL	<300	No Sample
10/20/15	Energys	<336	No Sample
	MDPH/MERL	<300	No Sample
10/30/15	Energys	<315	No Sample
	MDPH/MERL	<300	No Sample
11/04/15	Energys	<322	No Sample
	MDPH/MERL	<300	No Sample
11/13/15	Energys	<332	No sample
	MDPH/MERL	<300	No sample
11/16/15	Energys	<350	<337
	MDPH/MERL	<300	<300
11/23/15	Energys	<282	No Sample
	MDPH/MERL	<300	No Sample
11/30/15	Energys	<285	No Sample
	MDPH/MERL	<300	No Sample
12/07/15	Energys	<327	No Sample
	MDPH/MERL	<300	No Sample
12/14/15	Energys	<300	No Sample
	MDPH/MERL	<300	No Sample
12/21/15	Energys	<317	No Sample
	MDPH/MERL	<300	No Sample
12/31/15	Energys	<309	No Sample
	MDPH/MERL	<300	No Sample
01/04/16	Energys	<344	No Sample
	MDPH/MERL	<300	No Sample
1/11/2016	Energys	<346	No Sample
	MDPH/MERL	<300	No Sample

< = Not detected above the detection limit shown. MERL's lower detection limit is 300 pCi/L.

**Summary of Tritium Detected in Surface Water Samples
through June 30, 2016**

Pilgrim Nuclear Power Station

Plymouth, MA

Sample Collection Date	Reported By	Tritium Concentration (pCi/L)	
		North of MW 205 (Intake)	Surface Water Inlet at Boat Ramp
1/18/2016	Entergy MDPH/MERL	<347 <300	No Sample No Sample
1/25/2016	Entergy MDPH/MERL	<348 <300	No Sample No Sample
2/1/2016	Entergy MDPH/MERL	<320 <300	No Sample No Sample
2/12/2016	Entergy MDPH/MERL	<328 <300	No Sample No Sample
2/15/2016	Entergy MDPH/MERL	<324 <300	No Sample No Sample
2/22/2016	Entergy MDPH/MERL	<322 <300	<337 <300
2/29/2016	Entergy MDPH/MERL	<289 <300	No Sample No Sample
3/8/2016	Entergy MDPH/MERL	<280 <300	No Sample No Sample
3/14/2016	Entergy MDPH/MERL	<283 <300	No Sample No Sample
3/22/2016	Entergy MDPH/MERL	<317 <300	No Sample No Sample
3/29/2016	Entergy MDPH/MERL	<314 <300	No Sample No Sample
4/4/2016	Entergy MDPH/MERL	<320 <300	No Sample No Sample
4/11/2016	Entergy MDPH/MERL	<316 <300	No Sample No Sample
4/19/2016	Entergy MDPH/MERL	<312 <300	No Sample No Sample
4/25/2016	Entergy MDPH/MERL	<327 <300	<305 <300

< = Not detected above the detection limit shown. MERL's lower detection limit is 300 pCi/L.

**Summary of Tritium Detected in Surface Water Samples
through June 30, 2016**

Pilgrim Nuclear Power Station

Plymouth, MA

Sample Collection Date	Reported By	Tritium Concentration (pCi/L)	
		North of MW 205 (Intake)	Surface Water Inlet at Boat Ramp
5/2/2016	Entergy	<315	No Sample
	MDPH/MERL	<300	No Sample
5/9/2016	Entergy	<327	No Sample
	MDPH/MERL	<300	No Sample
5/16/2016	Entergy	<324	No Sample
	MDPH/MERL	<300	No Sample
5/24/2016	Entergy	<193	No Sample
	MDPH/MERL	<300	No Sample
6/2/2016	Entergy	<299	No Sample
	MDPH/MERL	<300	No Sample
6/6/2016	Entergy	<308	No Sample
	MDPH/MERL	<300	No Sample
6/13/2016	Entergy	<296	No Sample
	MDPH/MERL	<300	No Sample
6/20/2016	Entergy	<304	No Sample
	MDPH/MERL	<300	No Sample
6/27/2016	Entergy	<174	No Sample
	MDPH/MERL	<300	No Sample

1. Entergy samples collected by Entergy/Consultant and analyzed by Entergy contract laboratory; MDPH split samples received from Entergy and analyzed by Massachusetts Environmental Radiation Laboratory (MERL)

< = Not detected above the detection limit shown. MERL's lower detection limit is 300 pCi/L.