



The Commonwealth of Massachusetts

Executive Office of Health and Human Services

Department of Public Health

Bureau of Environmental Health

Community Sanitation Program

5 Randolph Street

Canton, MA 02021

Telephone: (781) 828-8046

Facsimile: (781) 828-7703

mikel.beacham@state.ma.us

DEVAL L. PATRICK
GOVERNOR

TIMOTHY P. MURRAY
LIEUTENANT GOVERNOR

JUDYANN BIGBY, MD
SECRETARY

JOHN AUERBACH
COMMISSIONER

February 8, 2011

Karin T. Bergeron, Superintendent
Old Colony Correctional Center
1 Administration Road
Bridgewater, MA 02324

Re: Facility Inspection

Dear Superintendent Bergeron:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, and Department of Public Health Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 1999 Food Code; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; I conducted an inspection of the Bridgewater Correctional Complex Core Services on January 28, 2011, accompanied by Bill Pappas, Environmental Health Officer, Steve Burnett, Deputy Director and Lt. Ed Costa. Violations noted are listed below (* indicates conditions documented on previous inspection reports).

Main Kitchen

Swill Room

No Violations Noted

Directors Office

No Violations Noted

Cooler 9

No Violations Noted

Cart Storage Room

FC 6-501.11

Repairing: Floor tiles damaged

FC 6-303.11(B)(3)

Lighting Intensity: Light out

Kitchen

FC 6-501.11*

Repairing: Ceiling damaged

FC 6-501.11*

Repairing: Floor tiles damaged

| | |
|--|--|
| <i>Diet Kitchen</i> FC 6-501.11 | Repairing: Cove tiles damaged |
| <i>Roll Call Room</i> | No Violations Noted |
| <i>Cooler 1</i> | No Violations Noted |
| <i>Cooler 3</i> FC 6-501.11 | Repairing: Floor grate damaged |
| <i>Baxter Ovens</i> | No Violations Noted |
| <i>Inmate Bathroom</i> | No Violations Noted |
| <i>Utensil Cabinet</i> | No Violations Noted |
| <i>Freezer 1</i> FC 6-303.11(A) FC 6-501.11* | Lighting Intensity: 2 lights out Repairing: Floor tiles damaged |
| <i>Cooler 2</i> FC 4-501.11(B) FC 6-501.11* | Maintenance and Operation, Equipment: Floor sweep loose Repairing: Floor tiles damaged |
| <i>Dry Storage</i> | No Violations Noted |
| <u>Market Area</u> | |
| <i>Cooler 4</i> FC 6-501.12(A) FC 6-303.11(A) FC 3-302.11(A)(4) | Maintenance and Operation: Cleaning: Debris on floor Lighting Intensity: 1 light out Preventing Food and Ingredient Contamination: Preventing cross contamination, food not appropriately covered (cream of wheat) |
| <i>Cooler 5</i> FC 4-501.11(B) | Maintenance and Operation, Equipment: Gasket damaged |
| <i>Freezer 2</i> FC 4-501.11(B) | Maintenance and Operation, Equipment: Threshold damaged |
| <i>Cooler 6</i> | No Violations Noted |
| <i>Inmate Bathroom</i> | No Violations Noted |
| <i>Toxic/Caustic</i> | No Violations Noted |

Warehouse

Double Door Freezer

FC 4-501.11(A)

FC 6-303.11(A)

Maintenance and Operation, Equipment: Ice build-up in corners

Lighting Intensity: 1 light out

Single Door Freezer

FC 6-501.11

FC 4-501.11(A)

Repairing: Ramp at entrance damaged

Maintenance and Operation, Equipment: Ice build-up on ceiling

Bakery

FC 5-205.15(B)

FC 6-501.11*

FC 4-501.11(A)

FC 4-501.11(A)

Plumbing System, Operations and Maintenance: Plumbing system not maintained in good repair, hose faucet leaking

Repairing: Floor tiles damaged

Maintenance and Operation, Equipment: Proofers not in use

Maintenance and Operation, Equipment: Ovens not in use

Dry Storage

FC 6-201.16(A)

Design, Construction, and Installation; Cleanability: Walls not easily cleanable (paint)

Bathroom

No Violations Noted

Cooler 12

FC 4-501.11(B)

FC 6-303.11(A)

FC 6-501.11

Maintenance and Operation, Equipment: Threshold damaged

Lighting Intensity: 1 light out

Repairing: Floor tiles damaged

Cooler 11

No Violations Noted

Freezer

FC 4-501.11(A)

Maintenance and Operation, Equipment: Safety shield on AC unit missing

Pot Area

Main Area

FC 6-303.11(B)(1)

FC 6-501.11

FC 6-501.11

FC 4-903.11(B)(2)*

Lighting Intensity: 2 lights missing

Repairing: Floor tiles damaged by window

Repairing: Wall paint chipping/peeling near sink

Protection of Clean Items, Storing: Some pots and pans not inverted

Inmate Bathroom

No Violations Noted

Dining Area

FC 6-501.11

FC 6-501.11*

FC 4-501.11

Repairing: Ceiling paint chipping/peeling

Repairing: Floor tiles damaged in right rear corner

Good Repair: Retractable sprayer hose hangs below flood rim on sink

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please indicate next to each entry on the inspection report a plan of correction. Said plan of correction must be submitted within ten working days of receiving this report and should detail the specific steps that will be taken and the date of expected compliance. The plan of correction should be submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Community Sanitation Regulations" (available in both PDF and RTF formats).

To review the Food Establishment regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "Retail" click "105 CMR 590.000 - State Sanitary Code Chapter X – Minimum Sanitation Standards for Food Establishments" and "1999 Food Code".

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,

Mikel Beacham
Environmental Health Inspector, CSP, BEH

cc: Suzanne K. Condon, Associate Commissioner, Director, BEH
Steven Hughes, Director, CSP, BEH
JudyAnn Bigby, MD, Secretary, Executive Office of Health and Human Services
Luis S. Spencer, Acting Commissioner, DOC
Sgt. Bill Pappas, Environmental Health Officer
Joe Eugenio, Food Service Director
John Economines, Deputy Director
Steve Burnett, Deputy Director
Bridgewater Board of Health
Clerk, Massachusetts House of Representatives
Clerk, Massachusetts Senate
Mary Elizabeth Heffernan, EOPS