



The Commonwealth of Massachusetts

Executive Office of Health and Human Services

Department of Public Health

Bureau of Environmental Health

Community Sanitation Program

5 Randolph Street

Canton, MA 02021

Telephone: (781) 828-8046

Facsimile: (781) 828-7703

Nicholas.Gale@massmail.state.ma.us

DEVAL L. PATRICK
GOVERNOR

TIMOTHY P. MURRAY
LIEUTENANT GOVERNOR

JOHN W. POLANOWICZ
SECRETARY

LAUREN A. SMITH, MD, MPH
INTERIM COMMISSIONER

April 9, 2013

Thomas M. Hodgson, Sheriff
Bristol County Sheriff's Office
Dartmouth Women's Center
400 Faunce Corner Road
North Dartmouth, MA 02747

Re: Dartmouth Women's Center Facility Inspection

Dear Sheriff Hodgson:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, and Department of Public Health Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 1999 Food Code; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; I conducted an inspection of the Bristol County Sheriff's Office Dartmouth Women's Center on March 27, 2013 accompanied by Lieutenant Andrew Mitzan, Environmental Health and Safety Officer and Paul Halfmann, Assistant Director of the Community Sanitation Program. Violations noted are listed below (* indicates conditions documented on previous inspection reports).

Interior

Visiting Area

No Violations Noted

Lobby

No Violations Noted

Officers Room

- FC 4-501.11(B)* Maintenance of Operation, Equipment: Equipment components not maintained in a state of good repair, refrigerator gasket damaged
- FC 4-601.11(C) Cleaning of Equipment and Utensils, Objective: Non-food contact surface dirty, interior of refrigerator dirty
- FC 4-601.11(C) Cleaning of Equipment and Utensils, Objective: Non-food contact surface dirty, ice build-up in freezer
- FC 4-903.11(A)(2) Protection of Clean Items, Storing: Single-service items not protected from contamination, utensils left uncovered
- 105 CMR 451.350 Structural Maintenance: Window cracked

<i>Male Bathroom</i> 105 CMR 451.126	Hot Water: Hot water temperature recorded at 138 ⁰ F
<i>Female Bathroom</i>	No Violations Noted
Control Room	No Violations Noted
Laundry 105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, sink leaking
Food Service Area	
<i>Dining</i> 105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, sink leaking
<i>Kitchen</i> FC 4-903.11(B)(2)* FC 4-903.11(A)(2)* FC 3-701.11(A) FC 6-501.11 FC 5-202.12(A)	Protection of Clean Items, Storing: Trays not inverted Protection of Clean Items, Storing: Single-service items not protected from contamination, utensils left uncovered Contaminated Food, Disposition: Unsafe, adulterated, or not honestly presented food not properly reconditioned or discarded, old food left out Maintenance and Operation; Repairing: Facility not in good repair, sprayer head drops below water line Plumbing System, Design: Handwashing sinks water temperature recorded at 140 ⁰ F
<i>Staff Bathroom</i>	No Violations Noted
A Wing	
<i>Day Room</i>	No Violations Noted
<i>Cells</i> 105 CMR 451.322*	Cell Size: All cells double bunked
<i>Bathroom</i>	No Violations Noted
<i>Bathroom Janitor's Closet</i> 105 CMR 451.123	Maintenance: No hot water supplied to slop sink
B Wing	
<i>Hallway</i> 105 CMR 451.350	Structural Maintenance: Wall damaged, paint peeling
<i>Cells</i> 105 CMR 451.322* 105 CMR 451.353	Cell Size: All cells double bunked Interior Maintenance: Door does not close properly in cell # B14
<i>Bathroom</i> 105 CMR 451.130	Plumbing: Plumbing not maintained in good repair, sinks leaking

105 CMR 451.110(A) Hygiene Supplies at Toilet and Handwash Sink: No paper towels at handwash sinks

Showers

105 CMR 451.123 Maintenance: Shower curtain missing

Bathroom Janitor's Closet

105 CMR 451.123 Maintenance: No hot water supplied to slop sink

C Wing

Cells

105 CMR 451.322* Cell Size: All cells double bunked

Bathroom

105 CMR 451.123 Maintenance: Toilet out-of-order

Shower

105 CMR 451.123 Maintenance: Shower curtain missing

Bathroom Janitor's Closet

105 CMR 451.123 Maintenance: No hot water supplied to slop sink

D Wing

Cells

105 CMR 451.322* Cell Size: All cells double bunked

Bathroom

No Violations Noted

Showers

105 CMR 451.123 Maintenance: Shower head damaged in shower # 1

Observations and Recommendations

- The inmate population was 90 at the time of inspection
- Floor paint is worn in all cells. However, paint remains intact and easily cleanable

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please indicate next to each entry on the inspection report a plan of correction. Said plan of correction must be submitted within ten working days of receiving this report and should detail the specific steps that will be taken and the date of expected compliance. The plan of correction should be submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at www.mass.gov/dph/dcs and click on "Community Sanitation Regulations" (available in both PDF and RTF formats).

To review the Food Establishment regulations please visit the Food Protection website at www.mass.gov/dph/fpp and click on "Food Protection Regulations". Then under "Retail" click "105 CMR 590.000 - State Sanitary Code Chapter X - Minimum Sanitation Standards for Food Establishments" and "1999 Food Code".

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,



Nicholas Gale
Environmental Health Inspector, CSP, BEH

cc: Suzanne K. Condon, Associate Commissioner, Director, BEH
Steven Hughes, Director, CSP, BEH
John W. Polanowicz, Secretary, Executive Office of Health and Human Services
Luis S. Spencer, Commissioner, DOC
Steven Sousa, Superintendent
Andrew Mitzan, EHSO
Dartmouth Board of Health
Clerk, Massachusetts House of Representatives
Clerk, Massachusetts Senate
Andrea J. Cabral, Secretary, EOPS