



The Commonwealth of Massachusetts

City / Town of _____



SELF-SERVICE MOTOR FUEL FACILITY INSPECTION

Rev. 4.1.2016

Facility: _____ Date of Inspection: _____

Address: _____ City/Town: _____

Owner/Manager: _____ Tel #: _____

MGL, Chapter 148 §13 Requirements	Yes	No
License (FP-002) to store flammable liquids posted - MGL, Chapter 148 §13		
Certificate of Registration (FP-005) posted - MGL, Chapter 148 §13		
527 CMR 1.00: Chapter 66 Requirements	Yes	No
Permit to store flammable and combustible liquids – 527 CMR 1: Chapter 66, Section 66.1.5		
527 CMR 1.00: Chapter 1 Requirements	Pass	Fail
Fire suppression system inspected semi-annually - 527 CMR 1: Chapter 1, Section 1.1.4		
527 CMR 1.00: Chapter 42 Requirements	Pass	Fail
Fuel nozzles shall not surpass outer PLB grooves (see guidelines for self-service stations) In no event fuel hose shall exceed 18ft - 527 CMR 1: Chapter 42, Section 42.5.5.1		
Automatic shutoff fuel dispensing nozzles installed with hold/latch open device (new and under maintenance facilities) 527 CMR 1: Chapter 42, Section 42.5.6.1		
Portable fire extinguisher on island(s) minimum 80 BC rating inspected annually by a company with Certificate of Registration - 527 CMR 1: Chapter 42, Section 42.7.2.5.2		
Fire suppression system installed, according to State Fire Marshal - 527 CMR 1: Chapter 42, Section 42.7.2.5.3		
Console operator has been instructed and trained on operations of the service facility including the suppression system emergency controls - 527 CMR 1: Chapter 42, Section 42.7.4.1		
Facilities of 1,000 sq ft or less of retail sales area and eight or less fueling positions may be operated by one employee. More than 1,000 sq ft of retail area and less than eight positions shall be operated by more than one employee during non peak hours - 527 CMR 1: Chapter 42, Section 42.7.4.3		
Positive Limiting Barrier (PLB) installed/maintained according to site plans. (Free of dirt and debris) - 527 CMR 1: Chapter 42, Section 42.7.4.5		
“Extinguish All Smoking Materials & Stop Engine While Refueling” sign posted on both ends of pump dispensing island. Shall consist of block letters no less than 2 inches in height and either be red letters on white background or white letters on red background - 527 CMR 1: Chapter 42, Section 42.7.4.5 (1)(c)		
Controlling console in constant attendance by operator during pump operations 527 CMR 1: Chapter 42, Section 42.7.4.5 (1)(d)		
Intercom system maintained in proper operating conditions on each island 527 CMR 1: Chapter 42, Section 42.7.4.5 (1)(e)		
Convex mirrors or CCTV cameras & monitors are installed and maintained to provide visibility 527 CMR 1: Chapter 42, Section 42.7.4.5 (1)(f)		
Clear and unobstructed view to dispensing island from console operator - 527 CMR 1: Chapter 42, Section 42.7.4.5 (1)(f)		
Unrelated business (vending areas, convenience food mart, repair shops, car washes, etc) is operated by others - 527 CMR 1: Chapter 42, Section 42.7.4.5 (1) (g)		
Controlling console includes an emergency shut off switch which instantly cuts all pumping power to all fuel pumps - 527 CMR 1: Chapter 42, Section 42.7.4.5 (1)(h)		
Automatic credit card reading device installed and does not activate dispenser 527 CMR 1: Chapter 42, Section 42.7.4.5 (1) (l) 1, 2, 3		
Split island facility: Emergency switch installed and accessible on full service islands, which activate fire suppression system and deactivate power to self-service dispensers - 527 CMR 42.7.4.5 (2) (a) (b)		

Comments: _____

Inspected By: _____ Date: _____

Operator Name (print): _____ Owner Signature: _____