



CHARLES D. BAKER
GOVERNOR

KARYN E. POLITO
LIEUTENANT GOVERNOR

JAY ASH
SECRETARY OF HOUSING AND
ECONOMIC DEVELOPMENT

Commonwealth of Massachusetts
Division of Professional Licensure
BOARD OF STATE EXAMINERS OF PLUMBERS
AND GAS FITTERS

1000 Washington Street • Boston • Massachusetts • 02118

JOHN C. CHAPMAN
UNDERSECRETARY OF
CONSUMER AFFAIRS AND
BUSINESS REGULATION

CHARLES BORSTEL
DIRECTOR, DIVISION OF
PROFESSIONAL LICENSURE

SEPTEMBER 30, 2015 BOARD MEETING MINUTES

MEMBERS	APPOINTMENT	PRESENT	ABSENT
Mr. Paul Kennedy Sr.	Chairman, Journeyman Gasfitter	✓	
Mr. Joseph McNamee	Member, Master Gas Fitter	✓	
Mr. Bahig A. Kaldas, P. E.	Member, Plumbing Engineer	✓	
Mr. Greg Hanley	Consumer Member	✓	
Mr. Steve Harold	Member, Master Plumber	✓	
Mr. John MacDonald	Member, LP Installer	✓	
Ms. Ruth Alfasso	Member, Dept. of Public Health	✓	
Mr. Harold Knight	Member, Journeyman Plumber	✓	
Mr. Dan Kilburn	Member, Public Safety	✓	

9:00 A.M. AGENDA REVIEW: By Chairman Paul Kennedy

9:05 A.M.: APPROVAL OF PREVIOUS MEETING MINUTES:

- The September 2, 2015 Board Meeting Minutes
Postponed to next meeting
- The September 2, 2015 Executive Session Minutes
Postponed to next meeting

VOCATIONAL SCHOOL PROJECTS

V1) UPPER CAPE COD TECHNICAL SCHOOL – 220 SANDWICH ROAD - BOURNE

Residential Project: Applicant is not required to attend. (*Habitat for Humanity – 185 Wareham Road - Marion*)

Meeting Notes:

A motion was made by Mr. Hanley and seconded by Ms. Alfasso to approve the project as requested

Unanimous

V2) SMITH VOCATIONAL HIGH SCHOOL – 80 LOCUST STREET - NORTHAMPTON

Residential Project: Applicant is not required to attend. (*Habitat for Humanity – 235 E. Pleasant St. – Amherst*)

Meeting Notes:

A motion was made by Mr. Hanley and seconded by Ms. Alfasso to approve the project as requested

Unanimous



V3) LEOMINSTER CTE HIGH SCHOOL – LEOMINSTER

Commercial Project: Applicant is required to attend. (New Patriots Veteran Outreach Center – 10 Wachusett Street – Fitchburg)

Meeting Notes: Old church rectory that they gave to the veterans. Need a HP rest room and a kitchen sink in order to open. 7 for 1 week and 9 for the 2nd week. There will be 2 instructors onsite at all times. Electricians, carpenters and HVAC will also be involved in this project.

*A motion was made by Mr. Knight and seconded by Mr. Hanley to approve this project as requested
Unanimous*

DISCUSSION(S)

D1) ENVIRO POWER LLC

Enviro Power, LLC is developing a novel combined generator (mCHP) and would like to place a Beta Prototype in the field for testing. Enviro Power is partnering with Holyoke Gas and Electric, to roll out their Beta test unit at one of their customer sites where they will use certified contractors and use the gas and plumbing best practices for the installation.

Meeting Notes: They are building the product now and would like to get it placed at this location for test purposes only.

A motion was made by Mr. McNamee and seconded by Ms. Alfasso to table as the applicant did not have enough information to allow the board to make a decision on this product. Mr. Kilburn will work with Enviro-Power LLC to determine if and when they would be able to get a test site.

Unanimous

D2) DELEGATED AUTHORITY

Discussion and possible vote

Meeting Notes: Mr. Hanley noted that he thought the authority should only be issued to the ED and not to anyone else. Attorney Kilb noted that it is common DPL process this authority is granted to his associate as well and that this is only authority to approve things the Board would always approve at a meeting.

A motion was made by Mr. Kilburn and seconded by Mr. MacDonald to accept the policy as written below.

DELEGATION OF AUTHORITY

Most Recent Adoption Date: September 30, 2015

The Board of State Examiners of Plumbers and Gas Fitters of Real Estate Appraisers (“Board”) hereby adopts the following rules governing the delegation of its authority to staff necessary to meet the day to day requirements of the Board.

The Board hereby delegates the following authority to the Executive Director, Associate Executive Director, Deputy Director, and Board Counsel:

1. To act as signatory for any Board decisions, correspondence, or other actions taken by the Board. This shall include, but not be limited to, signing Orders to Show Cause, advisory letters, and Final Decisions executed by the Board;
2. License Application Matters
 - (a) To issue licenses where the applicant has provided sufficient information to show he/she meets all prerequisites for licensure per 248 CMR and M.G.L. c. 142.

BOARD OF STATE EXAMINERS OF PLUMBERS AND GASFITTERS SEPTEMBER 30, 2015

- (b) To approve transitional arrangements utilized by a business entity changing a corporate officer per 248 CMR 3.00.
- (c) To allow applicants permission to take an examination when seeking a waiver based on out of state/out of country experience, education, and/or licensure which complies with the Board's substantially equivalent policy (last amended April 24, 2013).
- (d) To review applicant's criminal records and apply the Board's CORI Policy (currently December 5, 2007 with addendum barring level 3 sexual offenders approved on August 23, 2012) .
- (e) To allow a licensee who is a Master plumber the permission to sit for a Master Gasfitters examination.
- (e) To allow applicants to take the journeyman examination where social security records showing employment are not available because 1) the apprentice was employed by a municipality, or 2) the apprentice worked for an institution not in the business of plumbing as described in 248 CMR 3.03(1)(b)(1).
- (f) To allow an applicant to sit for an examination up to two additional times after six failures so long as 1) the applicant takes a 30 hour preparation course after the sixth failure, and 2) at least 60 days must pass between additional examination attempts.

3. Disciplinary Matters

- (a) To send complaints to the Office of Prosecutions for further handling, back to the Office of Investigation for further investigation, and closing complaints after a final disposition has been made by the Board and/or any subcommittees created by the chair on behalf of the Board;
- (b) To execute and amend consent agreements on the behalf of the Board within the scope of recommendations by the Board and/or any subcommittees created by the chair on behalf of the Board;
- (c) To commence summary suspension proceedings when the given licensee's continued practice would jeopardize the public's health, safety, or welfare; and
- (d) To execute final decisions and orders by default, including the uniform sanctions used by the Board for that purpose, against licensed and unlicensed individuals where those individuals have failed to appear and defend themselves in an adjudicatory proceeding.

4. Plumbing/Gas Code Matters

- (a) To process and approve applications and renewals for product acceptance where the product in question complies with the provisions of 248 CMR and meets nationally recognized standards.
- (b) To process and approve applications and renewals for product acceptance where the product in question does not comply with 248 CMR because they are not tested/listed in compliance with nationally recognized standards but has been tested as safe and effective for operation by a registered engineer or other neutral/third party accreditation bodies.
- (c) To process and approve and renewals for product acceptance where the product in question meets the material requirements of 248 CMR but are constructed from china, stainless steel, solid surface products (such as Corian, soapstone, granite), or other similar products

BOARD OF STATE EXAMINERS OF PLUMBERS AND GASFITTERS SEPTEMBER 30, 2015

- (d) Where a variance has been filed, to allow the installation of either bottled water or dispensing machines in lieu of drinking fountains in office facilities when rough plumbing is installed to allow for a future drinking fountain.
- (e) Where a variance has been filed, to waive the installation of showers in office facilities.
- (f) Where a variance has been filed, to allow the installation of a single laundry sink per laundry facility in a dormitory in lieu of one laundry sink for every 50 persons.
- (g) Where a variance has been filed, to approve alternatives to the interceptors and separators required by 248 CMR 10.09 when meeting the requirements of the Board policy entitled “Commercial Buildings Utilizing Overhead Garage Doors” (most recently updated May 6, 2015).

D3) CODE REVISIONS (SECTION 10.06)

Additional information

The Chairman asked that the discussion be postponed to next meeting

D4) NEW ENGLAND PLUMBING & GAS INSPECTOR ASSOCIATION

Will be hosting the Plumbing Board Meeting at the Cape Cod Resort in Hyannis on April 6, 2016

Meeting Notes: Peter DeFreitas stated that it will be a joint meeting with the Cape Cod and New England Associations.

VARIANCE REQUEST(S)

PV198) ALGONQUIN GAS TRANSMISSION- 8 WILSON WAY - WESTWOOD

Mr. Niti Tottempudi is requesting a variance from 248 CMR 10.09 (1) to allow sealing of the existing floor drains and eliminating the oil/water separator. The Westwood Board of Health does not oppose this variance request.

Meeting Notes: They would like to seal the floor drains and remove the existing separator. They will not be parking vehicles in the building but still need to pull the vehicles in to load them. Mr. Kennedy noted that the Board has never allowed this in the past.

A motion was made by Mr. MacDonald and seconded by Mr. McNamee to deny the request to permanently seal the floor drains and disconnect the existing separator.

Recused: Mr. Knight (Westwood Inspector) Unanimous

PV041) U-NAME IT SELF STORAGE, LLC – 203 CIRCUIT AVENUE – WEST SPRINGFIELD

Mr. Robert Kushner is requesting a variance from 248 CMR Section 10.09. The petitioner notes no plumbing work is being performed. The plumbing inspector is requiring him to install floor drains and associated piping and to pitch the floor to the drains. The applicant is seeking this variance to allow the storage of such private passenger motor vehicles without the installation of floor drains and a separator. The West Springfield Board of health has been notified of this request.

Meeting Notes: This is an old factory building without floor drains. It has now been converted over to a storage facility. Some of the storage units currently have cars stored in them. There are 200+ spaces from 200 to 1000 square feet. Mr. Kennedy noted that the Board has never allowed this. The local building inspector provided documentation and pictures showing some of the storage spaces being used as repair garages.

A motion was made by Mr. MacDonald and seconded by Ms. Alfasso to deny this request.

Unanimous

PV044 CITYLINE AUTO BROKERS – 497 BROADWAY – MALDEN

Mr. Edward Colameta is requesting a variance from 248 CMR 10.09 to allow the use of an auto showroom housing 10 vehicles without the installation of floor drains and a separator. No repairs, detailing or alterations are done to any vehicle at this location. The Malden Board of Health has been notified.

Meeting Notes: These are used cars and there is no service performed on the vehicles. Mr. Peluso noted that the Board had just recently approved 6 cars at this location.

A motion was made by Mr. MacDonald and seconded by Mr. Kilburn to deny this request. The applicant must abide by the terms of the current Board Policy for “Commercial Buildings Utilizing Overhead Garage Doors”. A copy of the Policy will be sent to the applicant.

Unanimous

PV049) KENDRIGAN PLACE – 10 WINTER STREET – QUINCY

Mr. William Lane Jr. from Superior plumbing is requesting a variance from 248 CMR 10.06 to allow connection to the existing waste for a new rest room and common area sink using schedule 40 PVC. All existing waste piping in the building is schedule 40 PVC. The Department of Health, after consultation the local plumbing inspector, does not object to granting this variance request. Mr. Mattes (local inspector) notes the entire building is residential and all drainage piping is PVC and he has no problem with granting the request.

Meeting Notes: They are remodeling 81 apartments. On the first floor they want to add a small sales office.

A motion was made by Mr. Harold and seconded by Mr. Hanley to allow the installation of PVC for the office area of this building.

Unanimous

PV050) PHILIP SCHWARTZ – 178 WATER STREET – NEWBURYPORT

Mr. Philip Schwartz is requesting a variance from 248 CMR Section 10.10 to allow the installation of a seasonal shower and a clam sink in the new barn. The Newburyport Board of Health supports the variance request.

Meeting Notes: Extensive remodeling on the house and they are building a 2 car barn/garage. He would like to install a clam sink and a shower in the barn. The local inspector told them they could not run the drain back to the house but instead had to run it to the street.

A motion was made by Mr. Knight and seconded by Mr. Harold to allow the drain for the barn to run into the basement of the house and connect to the main drain inside the house.

Unanimous

PV064) TENNIS HUT – 128 WILBRAHAM ROAD – HAMPDEN

Shannon Alther is requesting a variance from 248 CMR 10.10 (18) to allow a single unisex toilet in the tennis hut at this time and to then utilize the new squash building as the main activity center for this area of the property with the intended occupancy amounts between 16 and 40 person. The applicant properly petitioned the Hampden Board of Health.

Meeting Notes: There is a new clubhouse built about 350’ away. The new bathrooms to be built next year will only be 150’ away.

A motion was made by Mr. Kilburn and seconded by Ms. Alfasso to allow the single user unisex toilet for the tennis hut.

Unanimous

PV065) U-MASS BOSTON – FIELD STATION – 180 POLPUS ROAD – NANTUCKET

Ms. Jane Duff Gleason is requesting a variance from 248 CMR 10.10 to allow a single handicapped accessible unisex toilet room cut into the existing building envelope with access only from the outside. As this is a State project, a Board of Health petition is not required.

BOARD OF STATE EXAMINERS OF PLUMBERS AND GASFITTERS SEPTEMBER 30, 2015

Meeting Notes: It's an existing wood frame building originally a two car garage. It was converted to a field station in the 1970's. There are currently no facilities in the building. They would like to install a handicap accessible toilet with access only on the outside of the building.

A motion was made by Mr. Hanley and seconded by Mr. Harold to allow the installation of one unisex rest room with access only from the outside of the building.

Unanimous

PV066) DENTAL OFFICE – 509 CONDORD STREET – FRAMINGHAM

Mr. Domenic Valente is requesting a variance from 248 CMR Section 10.10 to allow the installation of a handicapped accessible urinal. Mr. Valente noted that the existing restroom has a handicapped toilet. The applicant properly petitioned the Framingham Board of Health.

Meeting Notes:

A motion was made by Mr. Hanley and seconded by Ms. Alfasso to table this request as the applicant did not appear.

Unanimous

PV068) DOVER RUG – 15 THIRD AVENUE - BURLINGTON

Mr. Todd Nordblom is requesting a variance from 248 CMR Section 10.10 to allow the installation of one unisex handicapped accessible restroom in lieu of the required two. The applicant properly petitioned the Burlington Board of Health.

Meeting Notes: This business will only have 2 employees working at one time on a regular basis. The total retail space is 2200 square feet.

A motion was made by Mr. Hanley and seconded by Mr. Knight to allow the installation of one unisex employee rest room.

Unanimous

PV069) UMASS AMHERST ROBSHAM CENTER – 360 CAMPUS WAY - AMHERST

Mr. Brian Cuff is requesting a variance from 248 CMR Section 10.06 (2). The Petitioner notes that during a site inspection by the State plumbing inspector, it was noted that PVC piping used for the inside leaders were in violation of the plumbing code, and that the piping should be cast-iron. As this is a State project, a Board of Health petition is not required.

Meeting Notes: This relates to a car port and rain leader/gutter issue. It does tie into a storm drain below ground. The Inspector noted that there is a 6' line being installed underground that all of the interior PVC drops tie into. This is an existing asphalt parking lot that they are building a structure above.

A motion was made by Mr. Kaldas and seconded by Mr. Hanley to continue this request until they can determine exactly where the drain discharges to.

Unanimous

PV070) BOSTON SCIENTIFIC CORP. – 500 COMMANDER SHEA BOULEVARD - QUINCY

Mr. Kevin S. Hastings from R. W. Sullivan Engineering is requesting a variance from 248 CMR Section 10.10 to allow the existing toilet facilities located more than 300 feet away in portions of a distribution warehouse. The Quincy Board of Health after consulting with the plumbing inspector, is not opposed to the variance request.

Meeting Notes: This is an existing warehouse and distribution center. The part of the distribution center they are remodeling falls outside the 300' requirement of the code.

A motion was made by Mr. Harold and seconded by Ms. Alfasso to allow the renovations to occur without requiring the installation of additional rest rooms to satisfy the 300' requirement.

Mr. Kaldas recused (RW Sullivan)

Unanimous

**BOARD OF STATE EXAMINERS OF PLUMBERS AND GASFITTERS SEPTEMBER 30, 2015
PV071) HANNA ANDERSON CLOTHING– 760 LEGACY PLACE - DEDHAM**

Mr. David Heidtke from is requesting a variance from 248 CMR Section 10.10 (18) to allow the installation of one unisex employee with rough plumbing installation for a future second rest room. The applicant properly petitioned the Dedham Board of Health.

Meeting Notes: This is a 1600 square foot space.

A motion was made by Mr. Hanley and seconded by Ms. Alfasso to allow the installation of one unisex employee rest room with rough plumbing installed for a future rest room.

Unanimous

PV072) CUTTY FOOD ESTABLISHMENT – 280-284 WASHINGTON STREET - BROOKLINE,
Mr. Charles Kelsey, the owner is requesting a variance from 248 CMR Section 10.10 (18) to allow a single unisex handicapped accessible restroom.. The Brookline Board of Health has no objection to this variance request.

Meeting Notes: The total square footage is just above 1200 with 18 seats.

A motion was made by Mr. Kaldas and seconded by Mr. McNamee to allow the installation of one unisex handicap rest room.

Unanimous

PV074) ICE HOUSE SKATING RINK – 55 NORTH STREET - CANTON

Mr. Gregory L. Pando is requesting a variance from 248 CMR Section 10.10 (18) to allow a reduction in the fixture requirements. Seating capacity for the rink is 1,350 which would only be occurring once or twice per year. The Petitioner proposes a toilet count of 12 toilets for women and 4 toilets and urinals form men will support a capacity for 360 women and 480 men. The Canton Board of Health supports this variance request.

Meeting Notes:

A motion was made by Mr. Hanley and seconded by Mr. McNamee to table this request as the applicant did not appear.

Unanimous

PV077) GLSD – NEW COGENERATION BUILDING–240 CHARLES STREET NORTH - ANDOVER

Mr. John Sheehan is requesting a variance from 248 CMR Section 10.10 (18) to allow the installation of one unisex restroom in the new Cogeneration building in lieu of separate women’s and men’s toilet rooms. The applicant properly petitioned the North Andover Board of Health.

Meeting Notes: This is a waste water treatment facility. There will be people walking through to check on the operation on a daily basis but no one working in the building.

A motion was made by Mr. Knight and seconded by Mr. Kilburn to allow the installation of one unisex employee rest room.

Unanimous

PV078) CAREWELL URGENT CARE – 603 CONCORD AVENUE - CAMBRIDGE

Mr. Dan Cellucci, from Dan-Cel Company is requesting a variance from 248 CMR Section 10.10 to allow a single unisex employee restroom. The Cambridge Board of Health after reviewing the plans and request with the plumbing inspector) and taking into consideration the number of staff and the timeframe that patients will be in the facility, gives its support to granting the variance.

Meeting Notes: The project is regulated by DPH. They are requesting a unisex rest room for the staff and a unisex handicap rest room for the patients.

A motion was made by Mr. Kaldas and seconded by Ms. Alfasso to allow the installation of one unisex rest room for the staff and a unisex handicap rest room for the patients and visitors.

Unanimous

**BOARD OF STATE EXAMINERS OF PLUMBERS AND GASFITTERS SEPTEMBER 30, 2015
PV079) THE COUNTRY CLUB – 191 CLYDE STREET – CHESTNUT HILL / BROOKLINE**

Mr. Brendan White, from RW Sullivan is requesting a variance from 248 CMR Section 10.15. The Petitioner notes the existing 4' drain in below the floor cannot be connected by gravity because of elevations and existing utilities. The pump discharge will be connected to the 4" gravity pipe at the ceiling. The local Plumbing Inspector is in favor of the request. The applicant properly petitioned the Brookline Board of Health.

Meeting Notes: The 4" waste

The Board took no action. The determination was that there was no variance necessary as the applicant stated there was no gravity drain available.

Mr. Kaldas recused (RW Sullivan)

Unanimous

PV080) THE COUNTRY CLUB – 191 CLYDE STREET – CHESTNUT HILL / BROOKLINE

Mr. Brendan White, from RW Sullivan is requesting a variance from 248 CMR Section 10.16. The Petitioner notes the owner requested installing a bar sink and floor drains in the in the existing library, which requires a 3" drain. The existing vent is 1-1/2 inches. The building is historical. Mr. White believes the existing vent will be adequate to protect the seal in the traps. The applicant properly petitioned the Brookline Board of Health.

Meeting Notes: The existing 3 drains would require a 2" vent and there is only an existing 1-1/2" vent line available. Where it's a historic building, it would be very difficult to get a 2" vent put in.

A motion was made by Mr. McNamee and seconded by Mr. Knight to deny this request.

Mr. Kaldas recused (RW Sullivan)

Unanimous

PV083) CHIPOTLE MEXICAN GRILL – 12 CHARLES ST – CITY PLAZA - BOSTON

Mr. Keith Bettencourt is requesting a variance from 248 CMR Section 10.10 to allow the installation of one unisex handicap accessible rest room in lieu of the required two. As this is a State project, no Board of Health petition is required.

Meeting Notes: There will be 8 to 10 employees at this location. The common area where rest rooms are located is about 150' away and will be available whenever the restaurant is open.

A motion was made by Mr. Kilburn and seconded by Mr. MacDonald to allow the installation of one unisex handicap rest room for patrons.

Unanimous

PV085) DUNKIN DONUTS – 550 ADAMS STREET - QUINCY

Mr. David Horton is requesting a variance from 248 CMR Section 10.10. The Petitioner notes the existing establishment was demolished due to structural damage following the past winter. The old building was 1,200 sf., with one unisex handicap restroom. The new building is 1,500 sf. The occupant load is 32 people. The petitioner seeks relief to allow the installation of one unisex handicapped accessible restroom for patrons and employees The Quincy Board of Health after consulting with the plumbing inspector, does not object to this variance request.

Meeting Notes: This building is part of a strip mall. They are moving to an end unit to accommodate a drive-thru. There will be 14 seats. The total square footage is 1500 square feet.

A motion was made by Mr. Harold and seconded by Mr. Hanley to allow the installation of a unisex handicap rest room for patrons and employees.

Unanimous

PV086) FEATHER & WEDGE – 3-5 MAIN STREET - ROCKPORT

Mr. Stephen Smit is requesting a variance from 248 CMR Section 10.10 (18) to allow the installation of two single fixture unisex restrooms, one of which is handicapped accessible.. The Rockport Board of Health does not oppose the granting of the variance request. In an email, Rockport Inspector Joseph Guzzo noted that considering the size of this space, he does not have any objection to this request.

Meeting Notes:

A motion was made by Mr. Hanley and seconded by Mr. Harold to allow the installation of one unisex handicap accessible rest room and one unisex non handicap rest room.

Unanimous

PV089) TD BANK – BUILDING E – NEW ENGLAND EXECUTIVE OFFICE PARK BURLINGTON

Mr. Doug Anderson is requesting a variance from 248 CMR Section 10.10 to allow the installation of one unisex restroom in lieu of the required two designated restrooms. The applicant properly petitioned the Burlington Board of Health.

Meeting Notes: This is a new bank branch with approx. 2000 square feet with 8-10 employees at one time.

The access will be only through the employee lounge

A motion was made by Ms. Alfasso and seconded by Mr. Hanley to allow the installation of one unisex handicap accessible rest room

Unanimous

PV091) PAUL WELCH – 31 HOLCOM ROAD - DENNIS

Mr. Mike Hansen, Estimator is requesting a variance from 248 CMR Section 10.06 (2) to allow PVC as a connection between two tanks underground outside. The Dennis Board of Health was properly petitioned.

Meeting Notes: The tight tank and the safety tank are too close. The individual stated that the owner put this equipment in and it's not a DEP approved tight tank.

A motion was made by Mr. MacDonald and seconded by Mr. McNamee to deny the request

Unanimous

FYI – Staff Approvals per Board Delegation – Board Vote Not Required

Shower requirements waiver in medical and dental office buildings.

DA PV076 – CAREWELL URGENT CARE – 603 CONCOD AVENUE CAMBRIDGE

DA PV058 – OLD YELLOW DOG CHIROPRACTIC – 165 ELM STREET - SALISBURY

Drinking fountain requirements waiver in medical and office buildings.

DA PV090 – MBS, INC. – 100 MAIN STREET – FLORENCE

Floor drains and gas/oil/sand separator waiver when installing permanent bollard(s).

DA PV073 – TUDOR GLEN VILLAGE-RENTAL OFFICE – 111 LOCUST STREET – WOBURN

Full Authorization for operation of unlisted gas equipment.

DA GV316 (SHARE COFFEE – 220 RUSSEL STREET, SUOITE 201 – HADLEY)

DA GV208 (PHILLIPS ACADEMY KILN – 19 SALEM STREET – ANDOVER)

The Board recessed at 11:10am.

EXECUTIVE SESSION

CHARACTER REVIEW(S)

CR1) LLG – 2nd Notice

QUASI-JUDICIAL SESSION

BOARD OF STATE EXAMINERS OF PLUMBERS AND GASFITTERS SEPTEMBER 30, 2015
A motion was made by Mr. McNamee and seconded by Mr. Knight to adjourn the meeting at 10:50am

LIST OF DOCUMENTS USED:

1. Meeting agenda
2. Minutes from prior meeting
3. Variance applications for above referenced agenda items

Respectfully Submitted By;

Wayne E. Thomas

Wayne E. Thomas, Executive Director
Board of Examiners of Plumbers and Gasfitters

Respectfully Authorized by;

Paul Kennedy, Sr.

Paul Kennedy Sr., Chairman
Board of Examiners of Plumbers and Gasfitters