Request No. AG-3-4 (Electric)
In JLH-3, have you included only distribution investment designed to increase capacity or is all distribution plant investment, i.e. including reliability-related investment, reflected?

Response:
In Schedule JLH-3 Electric page 4 (Table 2, page 2), only the portion of the distribution plant investment related to load growth is used to calculate the marginal cost. As described in note 3 and line 25, the percent related to load growth is applied to all distribution plant additions adjusted by the Handy-Whitman index. Specific reliability-related investments are not included.

Person Responsible: James L. Harrison