Request No. AG-3-5 (Electric)
Are the peak demands that are used to compute marginal capacity costs (p.73 JLH-3) weather normalized?

Response:
The peak demands used to compute the marginal capacity costs in Schedule JLH-3 Electric Workpapers page 73 are ACTUAL peak demands and are not weather normalized.

Person Responsible: James L. Harrison