CUSTOMER OUTAGE REPORTS

FITCHBURG GAS AND ELECTRIC LIGHT COMPANY
285 JOHN FITCH HIGHWAY
FITCHBURG, MA

SUBMITTED TO THE DEPARTMENT OF PUBLIC UTILITIES

REPORTED BY:_____
ROGER ABEL
MANAGER-ELECTRIC SYSTEMS

DATE	SUPERVISOR	VOLT.	STREET	CITY/TOWN	CODE	CAUSE	EFFECT	#CUST.	CIRC.#	TIME OUT	TIME IN	DURA.	CUST/HRS	WEATHER
06/25/01	DEE	15KV	WESTMINSTER ST	FITCHBURG	61	SQUIRREL	TRANS	2657	25W28	06:57	09:16	2.32	6155.38	SUNNY
06/25/01	DEE	15KV	RIVER ST/DEPOT ST	FITCHBURG	61	SQUIRREL	TRANS	866	25W27	06:57	09:16	2.32	2006.23	SUNNY
06/25/01	DEE	15KV	WESTMINSTER ST	FITCHBURG	61	SQUIRREL	TRANS	137	50W51	06:57	07:20	0.38	52.52	SUNNY
06/26/01	DEE	15KV	EDWARDS ST	FITCHBURG	22	DIST.TRF.OVERL	O/H CSP	5	01W02	21:42	12:01	14.32	71.58	WARM