780 CMR: MASSACHUSETTS AMENDMENTS TO THE INTERNATIONAL BUILDING CODE 2021

CHAPTER 22: STEEL

2205.1.1 Add subsection as follows:

2205.1.1 Shop Drawings. Complete shop drawings shall be prepared in a manner consistent with industry practice and in advance of the actual fabrication. Such drawings shall clearly distinguish between shop and field connections for bolts and welds, and shall also clearly identify steel grades, bolt types and sizes, weld types and sizes, locations and dimensions and all information necessary for proper fabrication and installation of the steel members.

2211.1.1.3 Add subsection as follows:

2211.1.1.3 Limitations on Cold-formed Steel Framed Shear Walls. The only sheathing materials permitted for cold-formed framed shear walls are steel sheets, wood structural panels, gypsum board panels, and fiberboard panels.

2211.1.1.3.1 Limitations on Gypsum Board Panel and Fiberboard Panel Sheathed Cold Formed Steel Framed Shear Walls. Gypsum board and fiberboard sheathed cold-formed steel framed shear walls are limited as follows:

- 1. The building shall not be more than 35 feet in height as measured from mean grade plane to mean roof plane.
- 2. The location of the shear walls shall be limited to exterior walls, fire walls, fire barriers, or fire partitions.
- 3. The building is not in Risk Category IV.
- 4. The seismic weight of each level (floor or roof), supported laterally by the shear walls, shall not be more than 25 psf. Where attics are not habitable, the seismic weight of a pitched roof shall include the dead load of the attic floor.

2211.6.1 Add subsection as follows:

2211.6.1 Limitations on Cold-formed Steel Framed Shear Walls. The only sheathing materials permitted for cold-formed framed shear walls are steel sheets, wood structural panels, gypsum board panels, and fiberboard panels.

2211.6.1.1 Limitations on Gypsum Board Panel and Fiberboard Panel Sheathed Cold Formed Steel Framed Shear Walls. Gypsum board and fiberboard sheathed cold-formed steel framed shear walls are limited as follows:

- 1. The building shall not be more than 35 feet in height as measured from mean grade plane to mean roof plane.
- 2. The location of the shear walls shall be limited to exterior walls, fire walls, fire barriers, or fire partitions.
- 3. The building is not in Risk Category IV.
- 4. The seismic weight of each level (floor or roof), supported laterally by the shear walls, shall not be more than 25 psf. Where attics are not habitable, the seismic weight of a pitched roof shall include the dead load of the attic floor.