



MAURA T. HEALEY  
GOVERNOR

KIMBERLEY DRISCOLL  
LIEUTENANT GOVERNOR

TERRENCE M. REIDY  
SECRETARY

*The Commonwealth of Massachusetts*  
*Executive Office of Public Safety and Security*  
*Department of Fire Services*

*P.O. Box 1025 ~ State Road*

*Stow, Massachusetts 01775*

*Telephone (978) 567~3100*

*[www.mass.gov/dfs](http://www.mass.gov/dfs)*



LARRY S. FISHER  
CHAIRMAN

December 5, 2024

**Official use Only**

527 CMR 12.00

Board of Fire Prevention Regulations  
527 CMR 12:00 Interpretation Committee  
Department of Fire Services  
PO Box 1025, State Road  
Stow, MA 01775

527 CMR 12.00 received from [REDACTED] on November 14, 2024.

**Background:**

Request for Interpretation Relative to 527 CMR 12.00

**Question 1:** What is the required separation, if any between underground electrical conduit serving a pool heater or a generator, from underground gas piping?

**Response:** No Response, no distance specified.

If you have any questions or need any additional information, please contact me.

Sincerely,

Larry S. Fisher, Chairman  
Board of Fire Prevention Regulations