



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY

The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Department of Fire Services

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100

www.mass.gov/dfs



ANTHONY P. CAPUTO
CHAIRMAN

February 1, 2024

Official use Only

527 CMR 12.00

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Background:

Request for Interpretation Relative to 527 CMR 12.00

Question # 1 Is there anything in the MA electrical code that would prevent an electric induction stove from working with a GFCI?

Response: No.

If you have any questions or need any additional information, please contact me.

Sincerely,

Anthony P. Caputo, Chairman
Board of Fire Prevention Regulations