



MAURA T. HEALEY  
GOVERNOR

KIMBERLEY DRISCOLL  
LIEUTENANT GOVERNOR

TERRENCE M. REIDY  
SECRETARY

*The Commonwealth of Massachusetts*  
*Executive Office of Public Safety and Security*  
*Department of Fire Services*

*P.O. Box 1025 ~ State Road*

*Stow, Massachusetts 01775*

*Telephone (978) 567~3100*

*[www.mass.gov/dfs](http://www.mass.gov/dfs)*



LARRY S. FISHER  
CHAIRMAN

March 7, 2024

**Official use Only**

527 CMR 12.00

Board of Fire Prevention Regulations  
527 CMR 12:00 Interpretation Committee  
Department of Fire Services  
PO Box 1025, State Road  
Stow, MA 01775

**Background:**

Request for Interpretation Relative to 527 CMR 12.00

**Question # 1:** I have provided a letter from a modular company stating that the structure met 527 CMR. I have attached the letter. I do not have any other documentation on the permits or posted in the structure like I am use to. Can I accept that letter for approval?

**Response:** No

If you have any questions or need any additional information, please contact me.

Sincerely,

Larry S. Fisher, Chairman  
Board of Fire Prevention Regulations