

## Massachusetts Department of Environmental Protection

RTCR-2

6.0	<b>Hydropneumatic and Pressure Storage Tanks</b> Complete one form for each tank. One form may be completed for multiple hydropneumatic storage tanks in the same location.				
	Source Name/Location:				
	Assessment Elements	Issue and/or Description			
	For any <u>shaded box</u> checked, it should be considered an issue and a description must be included.	*If any element has not been reviewed, you must include an explanation.	Yes	No	Not Reviewed*
6.1	Is the facility secured to prevent unauthorized access?				
6.2	Is there any evidence of intentional contamination at the storage tank? IMMEDIATELY Contact MA State Police and MassDEP				
6.3	Were there any observed leaks?				
6.4	Was there any observed physical deterioration of the tank? If yes, could the physical condition of the tank be a potential source of contamination?				
6.5	Is the pressure tank maintaining an appropriate minimum pressure (per manufacturer's specifications)?				
6.6	Has there been any recent tank maintenance (i.e. painting/coating)? If yes, when? Was disinfection performed?				
6.7	Is there evidence of the tank being waterlogged?				
6.8	Were samples representative of the water from this tank collected? If so, what were the results?				
6.9	What was the measured chlorine residual (total/free) of the water exiting the storage tank on the date of the assessment?				
6.10	Other comments on the storage tank?				
	List all hydropneumatic tank corrective actions taken (including date). Include assessment element number.				