

D.T.E. 02-08

Sprint's Analysis of Additional Collocation Security Incidents at Verizon-MA Central Offices

	<b>DATE</b>	<b>Location</b>	<b>Issue</b>
1	2/17/00	Lexington	CLEC replaced fuse on VZ's BDFB
2	3/07/00	Boston/Belvedere	CLEC propping CO doors open to give access to others
3	3/10/00	Brockton	CLEC OC48 cards missing from cage
4	3/16/00	Taunton	CLEC propping CO doors open to give access to others
5	4/13/00	Lexington	CLEC replaced fuse on VZ's BDFB
6	4/18/00	Malden	CLEC ran incorrect cables on VZ's rack
7	5/08/00	Burlington	CLEC left 56K modem plugged into AC outlet
8	5/15/00	Burlington	CLEC had equip. plugged into AC outlet across CO floor
9	5/23/00	Newton	CLEC has modem plugged into AC outlet
10	6/22/00	Worcester	CLEC's in CO without ID
11	8/02/00	Lawrence	Another CLEC using this CLEC's phone lines
12	8/04/00	Malden	Another CLEC using this CLEC's phone lines
13	8/07/00	Malden	Strike Incident
14	8/15/00	Marlboro	CLEC found lock to their cage lying on floor
15	8/29/00	Fall River	CLEC drilling disturbs business offices below them
16	11/06/00	Revere	CLEC advises equip. stolen from locked cabinet
17	3/10/00	Brockton	OC48 Cards stolen from CLEC cage.
18	8/07/00	Worcester	Strike Incident
19	8/07/00	Boston/ Harrison Ave.	Strike Incident
20	8/09/00	Malden	Strike Incident
21	8/09/00	Quincy	CLEC's multiple cards unseated in equipment bays.
22	9/24/00	Framingham	CLEC's PC stolen from locked cage.
23	11/06/00	Revere	Theft of CLEC equipment
24	11/03/00	Revere	Theft of CLEC equipment
25	11/07/00	New Bedford	Cut of an inactive cable in an unoccupied collo. cage.

D.T.E. 02-8

Sprint's Analysis of Additional Collocation Security Incidents at Verizon-MA Central Offices

Type of Incident	Quantity of Occurrences Noted at Tab 2 of Fox Rebuttal Testimony	Additional 2000 Security Events	% of Occurrences
Break Ins/Theft/Violations and service interruptions to CLEC	17	12	44%
CLECs wandering/rummaging	3	2	7%
No ID/Entry Problems/CO Door Open	7	3	15%
Messy Collo Area	2	0	3%
Cell Phone Use	1	0	2%
CLEC working on/with VZ equipment	5	0	7%
Collo door open/not locked	2	0	3%
CLEC caused service outage	1	0	2%
CLEC not meeting VZ installation specifications	1	5	9%
CLEC in other CLEC's space or equipment use.	3	2	8%
<b>Total</b>	<b>42</b>	<b>24</b>	<b>100%</b>