

## 780 CMR 73.00

### SOLAR SYSTEMS

#### 780 CMR 7301 SOLAR ENERGY SYSTEMS

**7301.1 General.** 780 CMR 7301 provides for the design, construction, installation, alteration, and repair of equipment and systems utilizing solar energy to provide space heating or cooling, hot water heating, and swimming pool heating.

**7301.2 Installation.** Installation of solar energy systems shall comply with 780 CMR 7301.2.1 through 7301.2.9.

**7301.2.1 Access.** Solar energy collectors, controls, dampers, fans, blowers and pumps shall be accessible for inspection, maintenance, repair and replacement.

**7301.2.2 Roof-mounted Collectors.** The roof shall be constructed to support the loads imposed by roof-mounted solar collectors. Roof-mounted solar collectors that serve as a roof covering shall conform to the requirements for roof coverings in 780 CMR 59.00. Where mounted on or above the roof coverings, the collectors and supporting structure shall be constructed of noncombustible materials or fire-retardant-treated wood equivalent to that required for the roof construction.

**7301.2.3 Pressure and Temperature Relief.** System components containing fluids shall be protected with pressure-and temperature-relief valves. Relief devices shall be installed in sections of the system so that a section cannot be valved off or isolated from a relief device. *Where applicable, the pressure and temperature relief requirements of 522 CMR shall apply.*

**7301.2.4 Vacuum Relief.** System components that might be subjected to pressure drops below atmospheric pressure during operation or shutdown shall be protected by a vacuum-relief valve. *Where applicable, the vacuum relief requirements of 522 CMR shall apply.*

**7301.2.5 Protection from Freezing.** System components shall be protected from damage resulting from freezing of heat-transfer liquids utilized. Freeze protection shall be provided by heating, insulation, thermal mass and heat transfer fluids with freeze points lower than the winter design temperature, heat tape or other approved methods, or combinations thereof.

**7301.2.6 Expansion Tanks.** Expansion tanks in solar energy systems shall be installed in accordance with 780 CMR 70.00 in closed fluid loops that contain heat transfer fluid. *Where applicable, the pressure and temperature relief requirements of 522 CMR shall apply.*

**7301.2.7 Roof and Wall Penetrations.** Roof and

wall penetrations shall be flashed and sealed to prevent entry of water, rodents and insects in accordance with 780 CMR 59.00.

**7301.2.8 Solar Loop Isolation.** Valves shall be installed to allow the solar collectors to be isolated from the remainder of the system. Each isolation valve shall be labeled with the open and closed position.

**7301.2.9 Maximum Temperature Limitation.** Systems shall be equipped with means to limit the maximum water temperature of the system fluid entering or exchanging heat with any pressurized vessel inside the dwelling to 180°F (82°C). This protection is in addition to the required temperature-and pressure-relief valves required by 780 CMR 7301.2.3.

**7301.3 Labeling.** Labeling shall comply with 780 CMR 7301.3.1 and 7301.3.2. *Where applicable, the labeling requirements of 522 CMR shall apply.*

**7301.3.1 Collectors.** Collectors shall be listed and labeled to show the manufacturer's name, model number, serial number, collector weight, collector maximum allowable temperatures and pressures, and the type of heat transfer fluids that are compatible with the collector. The label shall clarify that these specifications apply only to the collector. *Where solar systems are custom built by the homeowner or agent and are not a manufacturer's packaged system, the requirement still exists that any pressure vessels be labeled in accordance with the requirements of 522 CMR and otherwise the collector labeling requirements relative to collector maximum allowable temperatures and pressures, and the type of heat transfer fluids that are compatible with the collector shall be provided by label or in the form of a report to the Building Department as part of the building permit requirements (such report may include reference to recognized plans utilized to construct such collectors or may consist of a report from a qualified Massachusetts professional engineer).*

**7301.3.2 Thermal Storage Units.** Pressurized thermal storage units shall be listed and labeled to show the manufacturer's name, model number, serial number, storage unit maximum and minimum allowable operating temperatures and pressures, and the type of heat transfer fluids that are compatible with the storage unit. The label shall clarify that these specifications apply only to the thermal storage unit. *Where thermal storage units are custom built by the homeowner or*

*agent and are not a manufacturer’s packaged system, the requirement still exists that any pressure vessels be labeled in accordance with the requirements of 522 CMR and otherwise the thermal storage unit labeling requirements relative to storage unit maximum and minimum allowable operating temperatures and pressures, and the type of heat transfer fluids that are compatible with the storage unit shall be provided in the form of a report to the Building Department as part of the building permit requirements (such report may include reference*

*to recognized plans utilized to construct such collectors or may consist of a report from a qualified Massachusetts professional engineer).*

**7301.4 Prohibited Heat Transfer Fluids.** Flammable gases and liquids shall not be used as heat transfer fluids.

**7301.5 Backflow Protection.** All connections from the potable water supply to solar systems shall comply with applicable requirements of 310 CMR.