



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY

The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Department of Fire Services

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100

www.mass.gov/dfs



LARRY S. FISHER
CHAIRMAN

April 4, 2024

Official use Only

10.23.1

[REDACTED]

Board of Fire Prevention Regulations
527 CMR 1:00
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Request for Interpretation submitted by [REDACTED] on March 15, 2024.

Question #1: Where 527 CMR 1.00: 10.23.1 states “or any room used for similar purposes wherein corrosives or flammable liquids are handled,” is it intended that this apply to rooms only within schools, colleges, and universities based on the preceding language?

Response: Yes

If you have any questions or need any additional information, please contact me.

Sincerely,

Larry S. Fisher

Larry S. Fisher, Chairman
Board of Fire Prevention Regulations