



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY

The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Department of Fire Services

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100

www.mass.gov/dfs



LARRY S. FISHER
CHAIRMAN

April 3, 2025

Official use Only

100-110.26(a)(3)

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Request for Interpretation submitted by [REDACTED] on February 26, 2026.

Background:

Request for Interpretation Relative to 527 CMR 12.00, NEC 690.47(A)

Question #1: Is Busway/busduct with multiple plug openings for disconnecting means/devices considered to be electrical equipment according to the definition in article 100 Equipment?

Response: No Response, this question requires more clarification to be answered as Yes/No.

Question #2: If Busway/busduct is electrical equipment as article 100 states and is rated at 2500amps with 2-400amp disconnects and is located in an electrical room would the personnel doors need to open in the direction of egress with listed fire exit hardware.

Response: No Response

If you have any questions or need any additional information, please contact me.

Sincerely,

Larry S. Fisher

Larry S. Fisher, Chairman
Board of Fire Prevention Regulations