



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY

The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Department of Fire Services

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100

www.mass.gov/dfs



LARRY S. FISHER
CHAIRMAN

December 5, 2024

Official use Only

110.22A

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Request for Interpretation Relative 527 CMR 12.00, NEC 110.22A submitted by [REDACTED] on October 17, 2024.

Background:

Request for Interpretation Relative to 527 CMR 12.00, NEC 110.22A

Question 1: Where duplex receptacle(s) are installed above a ceiling adjacent to an access panel in a commercial setting, is the junction box required to be labeled to satisfy the requirements of Article 110.22A? For reference, the receptacle(s) in question serve cord and plug connected low voltage power supplies.

Response: No

If you have any questions or need any additional information, please contact me.

Sincerely,

Larry S. Fisher

Larry S. Fisher, Chairman
Board of Fire Prevention Regulations