

MAURA T. HEALEY GOVERNOR

KIMBERLEY DRISCOLL LIEUTENANT GOVERNOR

TERRENCE M. REIDY SECRETARY The Commonwealth of Massachusetts Executive Office of Public Safety and Security Department of Fire Services P.O. Box 1025 ~ State Road Stow, Massachusetts 01775 Telephone (978) 567~3100 www.mass.gov/dfs



ANTHONY P. CAPUTO CHAIRMAN

December 7, 2023



Board of Fire Prevention Regulations 527 CMR 12:00 Interpretation Committee Department of Fire Services PO Box 1025, State Road Stow, MA 01775

Background:

Request for Interpretation Relative to 527 CMR 12.00, 110.26(A)(1), Table 110.26(A)(1)

Question # 1: Does the equipment installed per Fig #1 meet the working depth requirements of 110.26(A)(1) & Table 110.26(A)(1) Condition 1? Equipment is 120V to ground (240V/208V single phase.

Response: No. 36" required working on live part.

Question # 2: Does the equipment installed per Fig #2 meet the working depth requirements of 110.26(A)(1) & Table 110.26(A)(1) Condition 1? Equipment is 120V to ground (240V/208V single phase.

Response: Yes

If you have any questions or need any additional information, please contact me.

Official use Only
Article: 110.26(A)(1)

Sincerely,

a. Paputo

Anthony P. Caputo, Chairman Board of Fire Prevention Regulations