



*The Commonwealth of Massachusetts*  
*Executive Office of Public Safety and Security*  
*Department of Fire Services*

*P.O. Box 1025 ~ State Road*

*Stow, Massachusetts 01775*

*Telephone (978) 567~3100*

*[www.mass.gov/dfs](http://www.mass.gov/dfs)*

MAURA T. HEALEY  
GOVERNOR

KIMBERLEY DRISCOLL  
LIEUTENANT GOVERNOR

TERRENCE M. REIDY  
SECRETARY



LARRY S. FISHER  
CHAIRMAN

June 6, 2024

**Official use Only**

11.12.3.2

Board of Fire Prevention Regulations  
527 CMR 12:00 Interpretation Committee  
Department of Fire Services  
PO Box 1025, State Road  
Stow, MA 01775

Code Change Proposal submitted by Hebert G. Corliss on February 15, 2024.

**Background:**

Request for Interpretation Relative to 527 CMR 12.00, NEC 501

**Question 1:** Is the cord and 5-15 plug acceptable power connection for the Diesel and Gasoline Fuel pumps?

**Response:** No Response.

**Question 2:** Is a 20 amp Weather Proof FCI in a FS box with a In-use cover acceptable power receptical?


**Response:** No Response.

**Question 3:** Under ground Conduit to building with EYS sealed and explosion proof hub with 2 EYSsealed before FS Box acceptable?

**Response:** No Response.

If you have any questions or need any additional information, please contact me.

Sincerely,

A handwritten signature in cursive script that reads "Larry S. Fisher".

Larry S. Fisher, Chairman  
Board of Fire Prevention Regulations