

MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY

The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Department of Fire Services

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100


www.mass.gov/dfs



ANTHONY P. CAPUTO
CHAIRMAN

8/3/2023

Joseph McElhinney



Official use Only

Article 210.52(C)

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Background:

Request for Interpretation Relative to Article 210.52(C)

Question # 1: We need an interpretation of 527CMR 12:00 210.52 (C) calls for counter top 12 Inches or more to require a receptacle outlet, Does this mean the 24" rule has been removed intentionally because of current wording in revised sections.

Response: No

If you have any questions or need any additional information, please contact me.

Sincerely,

Anthony P. Caputo, Chairman
Board of Fire Prevention Regulations