



The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Department of Fire Services

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100

www.mass.gov/dfs

MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY



LARRY S. FISHER
CHAIRMAN

June 6, 2024

Official use Only

210.53(C)(2)

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Request for Interpretation submitted by Paul Raposo on March 5, 2024.

Background:

Request for Interpretation Relative to 527 CMR 12.00, 210.53(C)(2)

Question # 1: In the MEC Article 210.53(C)(2) Massachusetts Amendments requires at least one receptacle in an island. In the event that there is a range, counter-mounted cooking unit, or a sink in the island would the requirements of figure 210.52(C)(1) apply?

Response: No

If you have any questions or need any additional information, please contact me.

Sincerely,

Larry S. Fisher

Larry S. Fisher, Chairman
Board of Fire Prevention Regulations