



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY

The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Department of Fire Services

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100

www.mass.gov/dfs



LARRY S. FISHER
CHAIRMAN

April 4, 2024

[REDACTED]

[REDACTED]

[REDACTED]

Official use Only

210.8(A)(D)

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Background:

Code Change Proposal submitted by [REDACTED], on March 5, 2024.

Question # 1: 210.8A states All 125v through 250v RECEPTACLES require GFCI protection. If an appliance (Stove or Oven) is hardwired, does it require GFCI protection?

Response: Yes

Question # 2: 210.8D Specific Appliances – Is this for other than Dwelling units only?

Response: No

If you have any questions or need any additional information, please contact me.

Sincerely,

Larry S. Fisher

Larry S. Fisher, Chairman
Board of Fire Prevention Regulations