



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY

The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Department of Fire Services

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100

www.mass.gov/dfs



LARRY S. FISHER
CHAIRMAN

February 6, 2025

[REDACTED]

[REDACTED]

[REDACTED]

Official use Only

225.30(F), 225.31

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Request for Interpretation submitted by [REDACTED] on December 18, 2024.

Background:

Request for Interpretation Relative to 527 CMR 12.00, NEC 225.30(F), 225.31

Question 1: Does Harvard University qualify as an "institution" under single management for the purposes of Massachusetts Electrical Code 527 CMR 12.00 article 225.30 (F)?

Response: Yes

Question 2: Does Harvard University qualify as an "institution" under single management for the purposes of Massachusetts Electrical Code 527 CMR 12.00 article 225.31 Exception 1?

Response: Yes

If you have any questions or need any additional information, please contact me.

Sincerely,

Larry S. Fisher

Larry S. Fisher, Chairman
Board of Fire Prevention Regulations