



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY

The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Department of Fire Services

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100

www.mass.gov/dfs



ANTHONY P. CAPUTO
CHAIRMAN

May 9, 2023

Patrick Walsh



<i>Official use Only</i>
230.2

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Background:
527 CMR 12.00, 230.2

Question # 1 Is a single overhead drop considered one service?

Response: Yes

If you have any questions or need any additional information, please contact me.

Sincerely,

Anthony P. Caputo, Chairman
Board of Fire Prevention Regulations