



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LT. GOVERNOR

TERRENCE M. REIDY
SECRETARY

The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Board of Fire Prevention Regulations

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100

www.mass.gov/dfs



ANTHONY P. CAPUTO
CHAIRMAN

February 2, 2023

Steve Connolly



Official use Only

Article 230.82

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Background:

Request for Interpretation Relative to 230.82

Question # 1:

Is this secondary meter socket allowed to be installed per 230.82(2) ahead of the service disconnect?

Question #2

Is the Back-up switch allowed to be installed on the line side of the service disconnect as allowed in 230.82(4) as a load management device is?

Response: Interpretation will be delayed in providing a response until the next scheduled meeting when more information can be gathered.

If you have any questions or need any additional information, please contact me.

Sincerely,

Anthony P. Caputo, Chairman
Board of Fire Prevention Regulations