



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY

The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Department of Fire Services

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100

www.mass.gov/dfs



LARRY S. FISHER
CHAIRMAN

June 6, 2024

Official use Only

230.85(A)(1)

[REDACTED]

[REDACTED]

[REDACTED]

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Request for interpretation submitted by John S. Warren on April 6, 2024.

Background:

Request for Interpretation Relative to 527 CMR 12.00, 230.85(A)(1).

Question # 1: Can the disconnecting means exceed 50' if within site of the dwelling unit?

Response: No

If you have any questions or need any additional information, please contact me.

Sincerely,

Larry S. Fisher

Larry S. Fisher, Chairman
Board of Fire Prevention Regulations