



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY

The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Department of Fire Services

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100

www.mass.gov/dfs



LARRY S. FISHER
CHAIRMAN

February 6, 2025



Official use Only

230.85(B)(3)
230.85(E)(1)(3)
230.85(E)(2)

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Request for Interpretation submitted by [REDACTED] on December 18, 2024.

Background:

Request for Interpretation Relative to 527 CMR 12.00, NEC 230.85(B)(3), 230.85(E)(1)(3) and 230.85(E)(2)

Question 1: On an existing dwelling when installing a listed switch or circuit breaker separate from a utility meter and marked "Suitable for use as service equipment" is the enclosure permitted to be labeled Emergency Disconnect-Not Service Equipment as per 230.85(B)(3), 230.85(E)(1)(3) and 230.85(E)(2)

Response: Yes

If you have any questions or need any additional information, please contact me.

Sincerely,

Larry S. Fisher

Larry S. Fisher, Chairman
Board of Fire Prevention Regulations