



MAURA T. HEALEY  
GOVERNOR

KIMBERLEY DRISCOLL  
LIEUTENANT GOVERNOR

TERRENCE M. REIDY  
SECRETARY

*The Commonwealth of Massachusetts*  
*Executive Office of Public Safety and Security*  
*Department of Fire Services*

*P.O. Box 1025 ~ State Road*

*Stow, Massachusetts 01775*

*Telephone (978) 567~3100*

*www.mass.gov/dfs*



ANTHONY P. CAPUTO  
CHAIRMAN

6/2/2023

**Official use Only**

Article 250.34

Bryce Fedder



Board of Fire Prevention Regulations  
527 CMR 12:00 Interpretation Committee  
Department of Fire Services  
PO Box 1025, State Road  
Stow, MA 01775

**Background:**

Request for Interpretation Relative to Article 250.34

**Question # 1:**

Do I or my customer need an electrical permit for a portable or trailer mounted generator that meets 250.34?

**Response:** Yes

If you have any questions or need any additional information, please contact me.

Sincerely,

Anthony P. Caputo, Chairman  
Board of Fire Prevention Regulations