



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY

The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Department of Fire Services
P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100

www.mass.gov/dfs



LARRY S. FISHER
CHAIRMAN

March 6, 2025

[REDACTED]

[REDACTED]

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Official use Only

250.50

Request for Interpretation submitted by [REDACTED], received January 16, 2025.

Background:

Request for Interpretation Relative to 527 CMR 12.00, 250.50

Question #1 On a new construction single family residence where the steel reinforcing bars or rods were not left accessible for use without disturbing the concrete, will a concrete encased electrode be required to be apart of the grounding electrode system?

Response: No

If you have any questions or need any additional information, please contact me.

Sincerely,

Larry S. Fisher

Larry S. Fisher, Chairman
Board of Fire Prevention Regulations