



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY

The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Department of Fire Services

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100

www.mass.gov/dfs



LARRY S. FISHER
CHAIRMAN

December 5, 2024

Official use Only

445.19(A)

[REDACTED]

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Request for Interpretation Relative to 527 CMR 12.00, NEC 445.19(A) submitted by [REDACTED] on March 27, 2024.

Background:

Request for Interpretation Relative to 527 CMR 12.00, 445.19(A)

Question 1: The last section of the section listed above states “The provisions to shut down the prime mover shall be permitted to satisfy the requirements of 445.18(A) where it is capable of being locked in the open position...” If I satisfy the requirements of 445.18(A) (1) & (2) the Emergency Shutdown of the Prime Mover does not need to be “lockable open” also?

Response: No

If you have any questions or need any additional information, please contact me.

Sincerely,

Larry S. Fisher

Larry S. Fisher, Chairman
Board of Fire Prevention Regulations