



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY

The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Department of Fire Services

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

Telephone (978) 567~3100

www.mass.gov/dfs



ANTHONY P. CAPUTO
CHAIRMAN

8/3/2023

Chip Servant

[REDACTED]

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Official use Only

Article 555.36(C)

Background:

Request for Interpretation Relative to Article 555.36(C):

Question # 1: Is Article 555.36(C) asking for all seven circuits to be de-energized from each individual E-stop located at the docking areas?

Response: No

If you have any questions or need any additional information, please contact me.

Sincerely,

Anthony P. Caputo, Chairman
Board of Fire Prevention Regulations