



The Commonwealth of Massachusetts
Executive Office of Public Safety and
Security
Department of Fire Services



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LIEUTENANT GOVERNOR

TERRENCE M. REIDY
SECRETARY

P.O. Box 1025 ~State Road
Stow, Massachusetts 01775
Telephone (978) 567~3100
www.mass.gov/dfs

LARRY S. FISHER
CHAIRMAN

November 7, 2024

Official use Only

690.47(A)

[REDACTED]

[REDACTED]

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
PO Box 1025, State Road
Stow, MA 01775

Request for Interpretation submitted by [REDACTED] on September 22, 2024.

Background:

Request for Interpretation Relative to 527 CMR 12.00, NEC 690.47(A)

Question 1: Is a building or structure supporting a PV system required to utilize a grounding electrode system installed in accordance with Part III of Article 250?

Response: No

If you have any questions or need any additional information, please contact me.

Sincerely,

Larry S. Fisher

Larry S. Fisher, Chairman
Board of Fire Prevention Regulations