

**MAIN OFFICE:**

50 Salem Street, Ste. 103B
Lynnfield, MA 01940
(781) 213-9198

BRANCH OFFICES:

46 Watergate Lane
W. Barnstable, MA 02668
(508) 274-5703

10 Diamond Drive
Derry, NH 03038
(603) 434-5245

www.axiomenv.com

December 22, 2021

Mr. Michael Lane
Environmental Health & Safety Manager
Office of Court Management/
Facilities Management & Court Capital
Massachusetts Superior Courts
Lowell Justice Center
370 Jackson Street
Lowell, MA 01852

VIA EMAIL

AXIOM Project 01275.007

RE: Indoor Air Quality Testing, Springfield District Courthouse, 50 State Street, Springfield, MA

Dear Mr. Lane,

At your request, Axiom Partners, Inc. (AXIOM) performed indoor air quality (IAQ) testing at the referenced courthouse building. The testing was performed on November 30, 2021, by AXIOM Industrial Hygienist, Michael Keady. The IAQ survey consisted of the following:

I. INDOOR AIR TESTING AND OBSERVATIONS**1. Visual Assessment of Interior Spaces**

AXIOM performed a general inspection of the interior spaces for visible signs of potential water damage or mold/fungal growth. This did not include above ceiling spaces and HVAC equipment.

2. General Air Quality Testing Parameters

AXIOM performed testing of IAQ parameters throughout the building using a direct reading Q-Trak® IAQ Monitor which continuously measures and records levels of carbon monoxide (CO), carbon dioxide (CO₂), temperature and relative humidity (rH).

AXIOM positioned the Q-Trak in 27 locations over the course of the day, with run times in each location ranging between 10 and 20 minutes. Locations were chosen to represent general air quality and the locations are documented on the attached floor plans.

Results are compared with established indoor air quality guidelines which are used to assess the adequacy of IAQ and ventilation.

3. Air Testing for Volatile Organic Compounds (VOCs)

A calibrated TSI GM460 Gas Monitor was used to take real-time spot readings for VOCs¹ in multiple locations throughout the building. The GM460 is a hand-held device that detects and measures more than 600 of the most common VOCs and has a lower detection limit of 1.0 ppb.

¹ Includes a library of over 600 common VOCs



The screening locations and associated Gas Monitor responses were recorded on an indoor air sampling form. The locations mimicked the Q-Trak sampling locations.

4. Air Testing for Total Dust

AXIOM performed continuous dust monitoring throughout the building using a direct-reading TSI SidePak™ AM520i dust monitor unit. This portable unit measured and recorded total dust concentrations.

The SidePak™ Personal Aerosol Monitor AM520i is a portable, battery-operated, data-logging, device that provides real-time aerosol mass concentration readings of dusts, fumes, mists, smoke and fog.

AXIOM periodically moved the SidePak units throughout the building mimicking the Q-Trak and VOC sampling locations.

5. Air Testing for Non-Culturable Mold (Fungi)

AXIOM also collect air samples for direct optical examination for mold and fungal spores using Allergenco-D air sampling cassettes which are used for the rapid collection and analysis of a wide range of airborne aerosols, including fungal spores, pollen, insect parts, skin cell fragments, fibers, and inorganic particulates. AXIOM collected 10 air samples from inside the building and 2 outdoor baseline/control samples (12 total samples).

The air samples were analyzed by EMSL Analytical, inc. (EMSL) located in Woburn, MA. EMSL is accredited under the American Industrial Hygiene Association (AIHA) for fungal analysis. A chain-of-custody form was used to document sample handling and to specify analytical requirements.

II. SUMMARY OF INDOOR AIR TESTING

1. Observations

During the course of performing the air testing, AXIOM inspected interior spaces in the building and made the following observations:

1. There were numerous areas with dirty HVAC diffusers and adjacent ceiling tiles;
2. No visible signs and no odors associated with mold/fungi were noted in the building;
3. There were water-stained ceiling tiles by the windows in the Law Library;
4. Most areas in the building appeared to be relatively clean; and,
5. Some unidentified stains were observed on carpets in some offices (possibly from drink/coffee spills).

2. General Air Quality Testing Parameters, VOCs and Total Dust

Table 1 provides a summary of the Q-Trak, SidePak and GM460 indoor air quality testing. In addition to our IH taking regular measurements and recording them on a field form, the Q-Trak and SidePak units operated in the data logging mode where they recorded and logged readings every 60 seconds throughout the sampling period. The GM460 is an automatic datalogging device that collects readings every 5 minutes when operational. The Q-Trak experienced some issues in data logging and did not capture data after 10:44 am.

TABLE 1
SUMMARY OF Q-TRAK, SIDEPAK AND GM460 TESTING RESULTS

AIR QUALITY PARAMETER	MINIMUM / MAXIMUM OF MEASURED VALUES	AVERAGE OF MEASURED VALUES	GUIDELINES
Temperature (T)	48.4 / 80.7 °F	71.2 °F	68 – 75 °F ^{a,b} 73 – 79 °F (summer)
Relative Humidity (rH)	15.3 / 27.9 %	18.6 %	30 – 60% ^{a,b}
Carbon Dioxide (CO ₂)	489 / 773 ppm	592 ppm	≤ 800 ppm ^{b,c}
Carbon Monoxide (CO)	0.0 / 0.1 ppm	0.0 ppm	9 ppm ^{a,b} /50 ppm ^d
Volatile Organic Compounds (VOC)	0 / 63 ppb	11.8 ppb	300 ppb ^{b, e}
Total Airborne Particulate	0 / 0.016 mg/m ³	0.002 mg/m ³	15.0 mg/m ³ ^d

^a ASHRAE 55-2013 Std. (American Society of Heating, Refrigerating & Air Conditioning Engineers).

^b ≤ means less than or equal to, °F = degrees Fahrenheit, % = percent, ppm = parts per million, ppb = parts per billion, mg/m³ = milligrams per cubic meter; TWA = Time Weighted Average over 8-hours

^c Occupational Safety & Health Administration (OSHA) proposed indoor air quality (IAQ) rule (59 FR 15968).

^d OSHA (Occupational Safety and Health Administration) Permissible Exposure Limit.

^e Refer to attached Total VOC summary table in Attachment 6.

Attachment 1 includes the field recording forms. The Q-Trak, SidePak and GM460 data summaries and graphs are provided in Attachment 2.

4. Air Testing for Non-Culturable Mold (Fungi)

Table 4 provides a summary of the spore trap air sampling results. The complete laboratory report is provided in Attachment 4.

TABLE 4
SUMMARY OF AIRBORNE FUNGAL SPORE TESTING RESULTS

SAMPLE NUMBER	LOCATION	TOTAL FUNGI (S/m ³) ¹	MOLD SPORE TYPE
4480488	Basement, Hall by Mechanical Room G42	100	Basidiospores
4480484	Basement, Mechanical Room G42	0	None Detected
4480512	Plaza, Elevator Lobby	230	Aspergillus/Penicillium, Basidiospores, Myxomycetes
4480498	Hall by Parking Ticket Office	80	Cladosporium, Myxomycetes
4480478	Hall by District Court 6	200	Aspergillus/Penicillium
4480483	Room 242	0	None Detected
4480542	Hall by Superior Court 1	130	Basidiospores, Aspergillus/Penicillium
4480476	Law Library	40	Myxomycetes
4480463	4 th Floor, Elevator Lobby	40	Basidiospores
4480456	Hall by Probate Court 1	0	None Detected

SAMPLE NUMBER	LOCATION	TOTAL FUNGI (S/m ³) ¹	MOLD SPORE TYPE
4480457	Building Exterior by Main Entrance	320	Basidiospores, Fusarium, Myxomycetes
4480454	Building Exterior by Next to State St.	90	Myxomycetes

¹S/m³ = spore counts per cubic meter of air

Airborne fungi below 250 S/m³ are normally not a concern for indoor environments². Airborne levels outdoors are normally between 500 and 1,000 S/m³, but, can easily exceed 10,000 S/m³ during the spring and summer months. Indoor airborne levels between 250 and 1,000 S/m³ are typically considered to be moderate and levels that exceed 1,000 S/m³ are often considered elevated³ and may result in active mold growth.

It is important to note that bioaerosols (fungi/mold) are always present and it is the excess quantity of microorganisms that can be of concern. By comparing the microbiological profiles of indoor sample results to outside samples, it is often possible to determine if amplification of microorganisms is occurring within the building.

III. CONCLUSIONS

In review of the testing and investigation performed in the target area, the following summarizes the results:

1. Dirty HVAC diffusers and adjacent ceiling tiles were observed in numerous areas throughout the building;
2. There were water-stained ceiling tiles by the windows in the Law Library;
3. No odors associated with mold/fungi were noted in the building; and
4. General air quality measurements were all within acceptable limits.

The following, additional steps may be taken should complaints continue:

- Investigate fresh air intake vents for proximity to potential sources of contaminants;
- Visually inspect ductwork and HVAC air handler units for signs of mold or moisture;
- Perform a more detailed investigation of the affected spaces for mold, including an infrared survey and moisture testing; and,
- Perform a thorough cleaning of dirty and stained carpets.

Although the TVOC levels are considered acceptable, it should be noted that as a result of increased cleaning and sanitizing inside building due to Covid-19, reports of higher-than-normal levels of VOCs inside buildings have been on the rise.

Please do not hesitate to contact us if you have any questions.

Sincerely,



Evan MacArthur
Project Manager/Sr.
Industrial Hygienist



Stephen E. Minassian
Principal



Edward K. Kearney, CIH
Principal

² New York Committee for Occupational Safety and Health

³ Occupational Safety and Health Administration Technical Manual, Section III, Chapter 2, § IV (c)

Mr. Michael Lane
December 22, 2021
Page 5 of 5

Indoor Air Quality Testing
Massachusetts Superior Courthouse
50 State St., Springfield, MA

Attachments: A1, Field data forms
A2, Direct Read Instrument Reports
A3, Fungi/mold testing report
A4, Sample location floor plans
A5, TVOC reference table

ATTACHMENT 1

FIELD DATA FORMS

IAQ READINGS

Date: 11/30/21
 Project No.: 01275.007
 Industrial Hygienist(s): Michael Keady

Location: 50 State St, Springfield MA
 Project Name: Air Quality Investigation,
 Springfield Hall of Justice

TIME	LOCATION	TEMP (°F)	RH (%)	CO ₂ (PPM)	CO (PPM)	VOCs (PPB)	PART. (MG/M ³)
0924	Basement, Snack Bar G54	66.9	21.1	623	0.1	0	0.001
0939	Basement, Facilities Office G48	68.7	20.1	535	0.1	0	0.003
0951	Basement, Hallway Outside Mechanical Room G42	70.0	18.0	570	0.0	0	0
1003	Basement, Mechanical Room G42	73.1	16.9	566	0.1	0	0.006
1014	Garage, Between Stair and Ramp Entrances	48.8	27.9	489	0.0	1	0.016
1027	1 st Floor, Main Elevator Lobby	67.4	20.9	661	0.1	13	0
1040	1 st Floor, Next To Security Counter 144A	67.2	20.4	773	0.1	10	0.006
1052	1 st Floor, Hallway Outside District Court 1	69.2	19.0	596	0.0	10	0.002
1104	1 st Floor, Hallway Outside Stairwell 1 and Forensic Health Office 140	72.4	17.4	586	0.1	11	0
1116	1 st Floor, Hallway Outside Clerk of District Court Criminal Office 110B	68.7	18.3	548	0.0	8	0
1127	1 st Floor, Outside Parking Ticket Office 100	67.8	19.0	557	0.0	9	0
1138	2 nd Floor, Main Elevator Lobby	72.2	18.4	646	0.1	13	0
1149	2 nd Floor, Hallway Outside District Court 6	73.4	18.5	677	0.1	14	0
1200	2 nd Floor, Hallway Outside District Court 3	73.7	16.6	599	0.1	13	0
1211	2 nd Floor, Room 242	71.1	18.0	586	0.0	11	0
1222	2 nd Floor, Hallway Outside Stairwell 1 and Room 223A	72.9	17.6	543	0.0	13	0
1233	3 rd Floor, Hallway Outside Superior Court 2	73.7	17.8	631	0.0	20	0
1244	3 rd Floor, Outside Superior Court 6	73.7	17.6	608	0.1	15	0
1256	3 rd Floor, Law Library Stacks 25-26	80.7	15.3	562	0.1	19	0.012
1307	3 rd Floor, Hallway Outside Superior Court 4	75.4	16.5	563	0.1	17	0
1319	3 rd Floor, Clerk Of Superior Court Office	75.9	16.4	550	0.0	17	0
1329	4 th Floor, Main Elevator Lobby	73.2	18.2	592	0.1	16	0
1340	4 th Floor, Hallway Outside Probate Court 2	73.2	18.5	595	0.0	17	0
1351	4 th Floor, Registry Of Probate Office	73.9	18.1	597	0.0	18	0

°F = degrees Fahrenheit; % = percent; ppm = parts per million, mg/m³ = milligrams per cubic meter

IAQ READINGS

Date:	11/30/21
Project No.:	01275.007
Industrial Hygienist(s):	Michael Keady

Location: 50 State St, Springfield MA
Project Name: Air Quality Investigation,
Springfield Hall of Justice

[illegible]

°F = degrees Fahrenheit; % = percent; ppm = parts per million, mg/m³ = milligrams per cubic meter

ATTACHMENT 2

**Q-TRAK SUMMARY REPORT & GRAPH,
SIDEPAK PARTICULATE REPORT & GRAPH
GM460 SUMMARY REPORT & GRAPH**

Instrument		Data Properties	
Model	VelociCalc/Q-Trak 7575	Start Date	11/30/2021
Meter S/N	7575X1910009	Start Time	9:21:19
Probe Model	982	Stop Date	11/30/2021
Probe S/N	P19140039	Stop Time	14:22:40
Meter Cal Date	03/10/2021	Total Time	5:01:21
CO2 Cal	03/10/2021	Logging Interval	10 seconds
Temperature Cal	03/10/2021		
Humidity Cal	03/10/2021		
CO Cal	03/10/2021		

	CO2 ppm	T deg F	H %rh	CO ppm	BP inHg
Max	767	73.1	30.6	1.1	29.94
Min	474	48.2	16.9	0	29.82
Avg.	578	66.3	20.7	0.1	29.87

Q-Trak Test Data							
Sample	Date	Time	CO2 ppm	T deg F	H %rh	CO ppm	BP inHg
1	11/30/2021	9:22:19	669	64.4	23.6	0	29.9
2	11/30/2021	9:23:19	635	65.5	22.2	0	29.9
3	11/30/2021	9:24:19	607	66.3	21.5	0.1	29.9
4	11/30/2021	9:25:19	624	67	21.2	0.1	29.9
5	11/30/2021	9:26:19	632	67.6	20.4	0.1	29.9
6	11/30/2021	9:27:19	597	68.3	22.2	0.1	29.91
7	11/30/2021	9:28:19	545	67.4	19.9	0.1	29.91
8	11/30/2021	9:29:19	538	67.7	20.9	0.1	29.91
9	11/30/2021	9:30:19	539	68	20.8	0.1	29.91



UNDERSTANDING, ACCELERATED

Test 1 Report

Name: Test 1**Description:** None**Location:** Unknown**Instrument Name:** SidePak Aerosol Monitor**Device Model Number:** AM520**Device Serial Number:** 5201912003**Firmware Version:** A.08**Last Factory Calibration:** 3/12/2021

Data Properties	
Start Date	11/30/2021
Start Time	12:58 PM
End Date	11/30/2021
End Time	3:26 PM
Test Length	00:02:28:00
Logging Interval	60 second(s)
Number of Data Points	148


Additional Information
There is no metadata related to this test

Test Statistics					
Channel	Average	Minimum	Maximum	Cal Factor	TWA
Aerosol (mg/m ³)	0.001	0 11/30/2021 03:23:52	0.006 11/30/2021 02:10:52	1 Factory 06/27/2021	0

Date	Time	Aerosol (mg/m ³)	Alarms
11/30/2021	12:59:52 PM	0.002	None
11/30/2021	1:00:52 PM	0.002	None
11/30/2021	1:01:52 PM	0.001	None
11/30/2021	1:02:52 PM	0.001	None
11/30/2021	1:03:52 PM	0.001	None
11/30/2021	1:04:52 PM	0.002	None
11/30/2021	1:05:52 PM	0	None
11/30/2021	1:06:52 PM	0	None
11/30/2021	1:07:52 PM	0	None
11/30/2021	1:08:52 PM	0	None
11/30/2021	1:09:52 PM	0	None
11/30/2021	1:10:52 PM	0.002	None
11/30/2021	1:11:52 PM	0	None
11/30/2021	1:12:52 PM	0	None
11/30/2021	1:13:52 PM	0.001	None
11/30/2021	1:14:52 PM	0	None
11/30/2021	1:15:52 PM	0	None
11/30/2021	1:16:52 PM	0.001	None
11/30/2021	1:17:52 PM	0.001	None
11/30/2021	1:18:52 PM	0	None
11/30/2021	1:19:52 PM	0.001	None
11/30/2021	1:20:52 PM	0	None
11/30/2021	1:21:52 PM	0.001	None
11/30/2021	1:22:52 PM	0	None
11/30/2021	1:23:52 PM	0.001	None
11/30/2021	1:24:52 PM	0.001	None
11/30/2021	1:25:52 PM	0.001	None
11/30/2021	1:26:52 PM	0	None
11/30/2021	1:27:52 PM	0.002	None
11/30/2021	1:28:52 PM	0.001	None
11/30/2021	1:29:52 PM	0.001	None

GM460 VOCs 11/30/21

Gas(FullScale)	Avg	Max	Max Date/Time	Min	Min Date/Time	Warning	Alarm	STEL	TWA
CH4(100%LEL)	0 %LEL	0 %LEL	11/30/2021 10:18	*****	*****	10 %LEL	50 %LEL	*****	*****
O2(40.0%)	20.80%	20.90%	11/30/2021 10:18	20.40%	11/30/2021 15:23	19.50%	23.50%	*****	*****
H2S(100.0ppm)	0.0 ppm	0.0 ppm	11/30/2021 10:18	*****	*****	5.0 ppm	30.0 ppm	5.0 ppm	1.0 ppm
CO(500ppm)	0 ppm	1 ppm	11/30/2021 11:12	*****	*****	25 ppm	50 ppm	200 ppm	25 ppm
VOC(50000ppb)	11 ppb	412 ppb	11/30/2021 10:18	*****	*****	5000 ppb	10000 ppb	*****	*****



ATTACHMENT 3

**EMSL MOLD AIR SAMPLING
LABORATORY REPORT**



EMSL Analytical, Inc.

5 Constitution Way, Unit A Woburn, MA 01801

Tel/Fax: (781) 933-8411 / (781) 933-8412

<http://www.EMSL.com> / bostonlab@emsl.com

EMSL Order: 132109229

Customer ID: AXIO80

Customer PO:

Project ID:

Attention: Evan MacArthur
Axiom Partners, Inc.
50B Salem Street, Suite 103
Lynnfield, MA 01940

Phone: (781) 213-9198

Fax: (781) 213-6992

Collected Date: 11/30/2021

Received Date: 12/02/2021

Analyzed Date: 12/09/2021

Project: 01275.007 - 50 State Street

Test Report: Allergenco-D(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	132109229-0001 4480488 75 Basement, Hall Outside Mech Room			132109229-0002 4480484 75 Basement, Mech Room G42			132109229-0003 4480512 75 Plaza, Elevator Lobby		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	-	-	-	2	90	39.1
Basidiospores	3	100	100	-	-	-	1	40	17.4
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	3	100	43.5
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-
Total Fungi	3	100	100	-	None Detected		6	230	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	43	-	-	43	-	-	43	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Woburn, MA AIHA-LAP, LLC-EMLAP Accredited #180179

Initial report from: 12/09/2021 08:29 AM

Steve Grise, Laboratory Manager
or other Approved Signatory

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

5 Constitution Way, Unit A Woburn, MA 01801
 Tel/Fax: (781) 933-8411 / (781) 933-8412
<http://www.EMSL.com> / bostonlab@emsl.com

EMSL Order: 132109229
 Customer ID: AXIO80
 Customer PO:
 Project ID:

Attention: Evan MacArthur
 Axiom Partners, Inc.
 50B Salem Street, Suite 103
 Lynnfield, MA 01940

Phone: (781) 213-9198
Fax: (781) 213-6992
Collected Date: 11/30/2021
Received Date: 12/02/2021
Analyzed Date: 12/09/2021

Project: 01275.007 - 50 State Street

Test Report: Allergenco-D(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	132109229-0004			132109229-0005			132109229-0006		
Client Sample ID:	4480498			4480478			4480483		
Volume (L):	75			75			75		
Sample Location:	Parking Ticket Office, Outside			Outside District Court 6			Room 242		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	4	200	100	-	-	-
Basidiospores	-	-	-	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-
Cladosporium	1	40	50	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	1	40	50	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-
Total Fungi	2	80	100	4	200	100	-	None Detected	-
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	43	-	-	43	-	-	43	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

No discernable field blank was submitted with this group of samples.

Steve Grise, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Woburn, MA AIHA-LAP, LLC-EMLAP Accredited #180179

Initial report from: 12/09/2021 08:29 AM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

5 Constitution Way, Unit A Woburn, MA 01801

Tel/Fax: (781) 933-8411 / (781) 933-8412

<http://www.EMSL.com> / bostonlab@emsl.com

EMSL Order: 132109229

Customer ID: AXIO80

Customer PO:

Project ID:

Attention: Evan MacArthur
Axiom Partners, Inc.
50B Salem Street, Suite 103
Lynnfield, MA 01940

Phone: (781) 213-9198

Fax: (781) 213-6992

Collected Date: 11/30/2021

Received Date: 12/02/2021

Analyzed Date: 12/09/2021

Project: 01275.007 - 50 State Street

Test Report: Allergenco-D(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	132109229-0007 4480542 75 Outside Superior Court #1			132109229-0008 4480476 75 Law Library			132109229-0009 4480463 75 4th Floor Elevator Lobby		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	2	90	69.2	-	-	-	-	-	-
Basidiospores	1	40	30.8	-	-	-	1	40	100
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	1	40	100	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-
Total Fungi	3	130	100	1	40	100	1	40	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	43	-	-	43	-	-	43	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	-	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	-	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

No discernable field blank was submitted with this group of samples.

Steve Grise, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Woburn, MA AIHA-LAP, LLC-EMLAP Accredited #180179

Initial report from: 12/09/2021 08:29 AM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

5 Constitution Way, Unit A Woburn, MA 01801

Tel/Fax: (781) 933-8411 / (781) 933-8412

<http://www.EMSL.com> / bostonlab@emsl.com

EMSL Order: 132109229

Customer ID: AXIO80

Customer PO:

Project ID:

Attention: Evan MacArthur
Axiom Partners, Inc.
50B Salem Street, Suite 103
Lynnfield, MA 01940

Phone: (781) 213-9198

Fax: (781) 213-6992

Collected Date: 11/30/2021

Received Date: 12/02/2021

Analyzed Date: 12/09/2021

Project: 01275.007 - 50 State Street

Test Report: Allergenco-D(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	132109229-0010 4480456 75 Outside Probate Court #1			132109229-0011 4480457 75 Outside Building			132109229-0012 4480454 75 Outside Building		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	-	-	-	-	-	-
Basidiospores	-	-	-	1	40	12.5	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	1	40	12.5	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	5	200	62.5	2	90	100
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	1	40	12.5	-	-	-
Total Fungi	-	None Detected	-	8	320	100	2	90	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	43	-	-	43	-	-	43	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Woburn, MA AIHA-LAP, LLC-EMLAP Accredited #180179

Initial report from: 12/09/2021 08:29 AM

Steve Grise, Laboratory Manager
or other Approved Signatory

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com

ATTACHMENT 4

SAMPLE LOCATION FLOOR PLANS

LEGEND


● IAQ Sample Location

M01 Mold Sample Location

Bi-Weekly IAQ Survey
Round 3 of 6
November 30, 2021

1 SPRINGFIELD HOJ BASEMENT PLAN

PLAN NOT FOR CONSTRUCTION



50 State Street, Springfield MA

AXIOM PARTNERS, INC.
50 B Salem St., Suite 103
Lynnfield, MA 01940
(781) 213-9198
www.axiomenv.com

DRAWING TITLE
Springfield HOJ Basement Plan

APPROVED:
APPROVED:

PROJECT TITLE
SHOJ IAQ Survey
50 State St, Springfield MA

BUILDING NUMBER
CHECKED
DRAWN
LOCATION

DATE
11/30/21
PROJECT NO.
01275.007

DRAWING NO.
IAQ 1
DWG. 1 OF 5



LEGEND

IAQ Sample Location

Mold Sample Location

Bi-Weekly IAQ Survey
Round 3 of 6
November 30, 2021

2 SPRINGFIELD HOJ
FIRST FLOOR PLAN

M12


M03

M04

M11

PLAZA LEVEL FLOOR PLAN
NOT TO SCALE

PLAN NOT FOR
CONSTRUCTION



50 State Street, Springfield MA

AXIOM PARTNERS, INC.
50 B Salem St., Suite 103
Lynnfield, MA 01940
(781) 213-9198
www.axiomenv.com


Springfield HOJ
First Floor Plan

SHOJ IAQ Survey
50 State St, Springfield MA

11/30/21
PROJECT NO.
01275.007

IAQ 2
DWG. 2 OF 5






- LEGEND
- IAQ Sample Location
 - M05 Mold Sample Location

Bi-Weekly IAQ Survey
Round 3 of 6
November 30, 2021

3 SPRINGFIELD HOJ
SECOND FLOOR PLAN



LEVEL 3 FLOOR PLAN

LEGEND


● IAQ Sample Location

M03 Mold Sample Location

Bi-Weekly IAQ Survey
Round 3 of 6
November 30, 2021

4 **SPRINGFIELD HOJ**
THIRD FLOOR PLAN

PLAN NOT FOR
CONSTRUCTION



50 State Street, Springfield MA

AXIOM PARTNERS, INC.
50 B Salem St., Suite 103
Lynnfield, MA 01940
(781) 213-9198
www.axiomenv.com

DRAWING TITLE
Springfield HOJ
Third Floor Plan

APPROVED:

APPROVED:

PROJECT TITLE
SHOJ IAQ Survey
50 State St, Springfield MA


BUILDING NUMBER

LOCATION

DATE
11/30/21
PROJECT NO.
01275.007

DRAWING NO.
IAQ 4
DWG. 4 OF 5





LEGEND

● IAQ Sample Location

M01 Mold Sample Location

Bi-Weekly IAQ Survey
Round 3 of 6
November 30, 2021

5 **SPRINGFIELD HOJ**
FOURTH FLOOR PLAN

ATTACHMENT 5

TVOC CONCENTRATION REFERENCE TABLE

TVOC INDOOR AIR CONCENTRATION REFERENCE GUIDE

TVOC Level ug/m3	Level of Concern	Symptoms	Comments
<300 (0.3 ppm)	Low	No irritation or discomfort is expected	There is a low likelihood that specific VOC sources are present
300 to 500 (0.3 to 0.5 ppm)	Acceptable	Occasional irritation or discomfort may be possible with sensitive individuals	There is a low to moderate likelihood that specific VOC sources are present
500 to 1,000 (0.5 to 1.0 ppm)	Marginal	Complaints about irritation and discomfort are possible in sensitive individuals	A moderate likelihood that specific VOC sources are it is recommended that steps be taken to identify the sources
1,000 to 3,000 (1.0 to 3.0 ppm)	High	Irritation and discomfort are very likely	A high likelihood that specific VOC sources are present and it is highly recommended that steps be taken to identify them
>3,000 (>3.0 ppm)	Very High	Irritation and discomfort are very possible	These levels are usually found in an industrial environment where workers are exposed to chemicals