


Average TN by System for Advantex with General Use Approval for Systems <2,000 Gallons Per Day



***Notes**

MassDEP reviews performance data for nitrogen reducing technologies approved for use in Massachusetts on a yearly basis to maintain the Best Available Nitrogen Reducing Technology (BANRT) list in accordance with 310 CMR 15.215(2)(g).

In 2024, the BANRT analysis for the Advantex system with General Use approval included 97 systems with 62 systems that had an average TN that met the 19 mg/L effluent TN standard established in the technology approval. This correlated to 64% performance.

In 2025, the BANRT analysis for the Advantex system with General Use approval includes 156 systems with 104 systems that have an average TN meeting the 19 mg/L effluent TN standard established in the technology approval. This correlates to 67% performance.