

Advantex Treatment System Performance

Data includes samples from 2018 – 2024.
Minimum of 6 samples per site.
97 sites included in analysis, with 62 sites meeting
the performance standard of 19 mg/L or less.
63.92% performance rate.

