

Bioclere System Performance

Data includes samples from 2018 – 2024.
Minimum of 4 samples per site.
32 sites included in analysis, with 25 sites meeting
the performance standard of 25 mg/L or less.
78.13% performance rate.

