

MAURA HEALEY GOVERNOR

KIM DRISCOLL LIEUTENANT GOVERNOR

YVONNE HAO
SECRETARY, EXECUTIVE OFFICE
OF ECONOMIC DEVELOPMENT

Commonwealth of Massachusetts Division of Occupational Licensure Office of Public Safety and Inspections

1000 Washington Street, Suite 710 Boston, Massachusetts 02118

LAYLA R. D'EMILIA UNDERSECRETARY, CONSUMER AFFAIRS AND BUSINESS REGULATION

SARAH R. WILKINSON COMMISSIONER, DIVISION OF OCCUPATIONAL LICENSURE

Minutes

BBRS Building Code Appeals Board (BCAB) Meeting Location: Virtual Microsoft Teams-Meeting September 7, 2023

Meeting Called to order by the Chairman Michael McDowell, at 9:30 a.m. followed by Roll call:

Board Members Present:

David Riquinha (Jeffrey Clemons-1 case) Michael McDowell, Chairman Jacob Nunnemacher

Guests Present:

See sign-in sheet for each case:

1. Case Number: 23-0071

Appellant: Christopher Andrade

Property Address: 24 Pamela Drive, New Bedford, MA. 02740

Summary of Case: Appellants sought relief from 780 CMR Section 51.00, R305.1.1, with

respect to an existing building.

Jacob Nunnemacher made a **MOTION** that was **SECONDED** by David Riquinha, to **GRANT** a variance from **780 CMR Section 51.00**, **R305.1.1**, to allow the finished beam to be at a height of not less than 6 feet. The Motion was approved by unanimous vote.

2. Case Number: 23-0073

Appellant: Joseph Davey (Owner-Ileana Berman) Property Address: 118 High Street, Wareham, MA. 02571

Summary of Case: Appellants sought relief from 780 CMR 903.2, Note A#1, with respect

to an existing building.

Jacob Nunnemacher made a MOTION that was SECONDED by Jeffrey Clemons, to: (1)UPHOLD the Building Inspector's determination that the building is a mixed-use occupancy and not owner-occupied, home-office building; (2) OVERTURN the Building Inspector's determination that installation of an automatic fire sprinkler system is required by 780 CMR 903.2, Note A #1. The BCAB overturned the Building Inspector's determination about 780 CMR 903.2, Note A #1 because an evaluation in accordance with 780 CMR 34.00 has not been provided, including a method of

TELEPHONE: (617) 701-8600 FAX: (617) TTY/TDD: (617) 701-8645 http://www.mass.gov/dpl



compliance in accordance with **780 CMR 34.00** that might/might not require installation of an automatic fire sprinkler system. The Motion was approved by unanimous vote.

3. Case Number: 23-0074

Appellant: Charles Fuller

Property Address: 24 Park Street, Rockland, MA. 02370

Summary of Case: Appellants sought relief from 780 CMR 1011.10, with respect

to an existing building.

David Riquinha made a **MOTION** that was **SECONDED** by Jacob Nunnemacher, to **OVERTURN** the Local Building Inspector's determination about the application of **780 CMR 1011.10** to the staircase on condition that Appellant continuously maintains the spiral staircase in accordance with **780 CMR.** The Motion was approved by unanimous vote.

4. Case Number: 23-0075

Appellant: Chen Jay Xuedong

Property Address: 75 Greenwood Road, Andover, MA. 01810

Summary of Case: Appellants sought relief from 2021 IECC Table R402.1.3, with respect

to an existing building.

Jacob Nunnemacher made a **MOTION** that was **SECONDED** by David Riquinha, to **UPHOLD** the Local Inspector's determination and requirements in his August 4, 2023 letter. The Motion was approved by unanimous vote.

The meeting adjourned at 1:30 p.m.