room.

CHARLES D. BAKER GOVERNOR

KARYN E. POLITO LIEUTENANT GOVERNOR

MIKE KENNEALY SECRETARY OF HOUSING AND ECONOMIC DEVELOPMENT

Commonwealth of Massachusetts Division of Occupational Licensure Office of Public Safety and Inspections

1000 Washington Street, Suite 710 Boston, Massachusetts 02118

Agenda

Meeting of the **Board of Elevator Regulations** December 20, 2022 at 1:00 p.m.

Microsoft Teams meeting Join on your computer or mobile app Click here to join the meeting

Or call in (audio only)

+1 857-327-9245,,144252712# United States, Boston Phone Conference ID: 144 252 712#

1. Roll Call by Chair Eric Morse (pending new governor appointment or further Board action):

Petitioner is requesting a variance from 524 CMR 35:00 § 2.8.3.3 "Sprinklers shall not be

permitted in power passenger or freight elevator hoistways pits, machine rooms or control spaces.", to allow the installation of sprinkler coverage in the elevator machine

- Eric Morse
- Thomas McDermott .
- David Gaudet
- David Morgan •
- Brian Ronan •
- Christopher Towski •
- Neil Mullane •
- Vacancy
- Vacancy

2. 8 Colonial Drive Westborough State IDs: 328-P-6 and 327-F-7

- **p**resent □ absent
- □ present
- **p**resent □ absent
- □ present □ absent
- **p**resent □ absent





EDWARD A. PALLESCHI UNDERSECRETARY OF CONSUMER AFFAIRS AND BUSINESS REGULATION

LAYLA R. D'EMILIA COMMISSIONER, DIVISION OF OCCUPATIONAL LICENSURE

3. 44 North Road, Bedford State ID: 24-P-163

Petitioner is requesting a variance from A17.1-1987,1989, 1996 § 211.3c(1)(c) – Firefighter Phase II Emergency In-Car Operation.

4. 26 Court Street, Boston

State IDs: 1-P-3014, 1-P-3015, and 1-P-3016

Petitioner is requesting a variance from 524 CMR to keep the same three elevators out of service for an additional six months until June 6, 2023.

5. 7-9 Newbury Street, Boston State ID: TBD

Petitioner is seeking a variance from 524 CMR 35:00 – Shallow pit, ASME A17.1-2013 § 3.4: Bottom and top clearances and runbys for car and counterweights, and ASME A17.1-2013 § 2.15: Car frames and platforms.

6. 37 Temple Place, Boston

State ID: 1-P-7108

Petitioner is seeking a variance from 524 CMR due to not having enough clearance for the controller if a door is added.

- 7. Continued discussion regarding FS90 repairs and permit filing.
- 8. Approval of meeting minutes from October 5, 2022, October 18, 2022 and October 25, 2022
- 9. <u>Old business (The Board may or may not discuss)</u>:

• 21 North Main Street, Uxbridge

Petitioner was in front of the Board requesting a variance to allow the elevator to return to service in compliance with the code under which it was originally installed and not subject to any changes to code for such LULA units that may have come into effect since the original installation in 1996. Placed on hold for 60 days to come back in front of the Board with additional information. **Deadline: July 16, 2022**

• 5 Sabrina Farm Road, Wellesley

New Installation

Petitioner is seeking a variance from 524 CMR 35.00 Section 2.1.5 – Windows and Skylights. Placed on hold to come back in front of the Board with additional information.

• 129 Sturbridge Road, Charlton State ID: 54-V-21318

Petitioner is seeking a variance from an inspector's report from August 18, 2022, citing "Operating Protective Safety Switch – § 32.08 no SOS". Placed on hold for 90 days to allow the petitioner additional time to for compliance. **Deadline: February 13, 2022**

• Continued discussion and review of 524 CMR Section 26.00: Certain Elevator Equipment Used as Motor Vehicle Parking Devices.

10. Matters not reasonably anticipated 48 hours in advance of meeting.