



**CHARLES D.  
BAKER**  
GOVERNOR

**KARYN E. POLITO**  
LIEUTENANT GOVERNOR

**MIKE KENNEALY**  
SECRETARY OF HOUSING AND  
ECONOMIC DEVELOPMENT

**Commonwealth of Massachusetts**  
**Division of Occupational Licensure**  
**Office of Public Safety and Inspections**  
1000 Washington Street, Suite 710  
Boston, Massachusetts 02118

**EDWARD A. PALLESCHI**  
UNDERSECRETARY OF CONSUMER  
AFFAIRS AND BUSINESS  
REGULATION

**LAYLA R. D'EMILIA**  
COMMISSIONER, DIVISION OF  
OCCUPATIONAL LICENSURE

**NOTICE OF MEETING**

In accordance with the provisions of M.G.L.c. 30A, §20 notice is hereby given that a meeting of the Board of Elevator Regulations will be held on **Wednesday, October 18, 2022 at 1:00 p.m.**, at **1000 Washington Street, Boston, MA 02118** on the **1<sup>st</sup> Floor – Room 1D**. It is anticipated that the following will be discussed at the aforementioned meeting:

1. Roll Call
2. **75 Federal Street, Boston**  
**State IDs: 1-P-3563, 1-P-3564, 1-P-3565, 1-P-3566, 1-P-3567, 1-P-3568, 1-P-3569 and 1-P-3570**  
Petitioner is seeking to appeal an Inspector's report citing, "5.9.14.1 A permanent mounted emergency stop switch shall be provided for the top of car emergency exit."
3. **44 North Road, Bedford**  
**State ID: 24-P-163**  
Petitioner is seeking a variance from the FS90 requirement.
4. **408 Newbury Street, Boston**  
**New Installation**  
Petitioner is seeking a variance from A17.1-2013 Section 2.11.10.1.1, metal fascia requirement.
5. Continued discussion regarding the operation of the in car stop switch during Firefighters Emergency Operation.
6. Discussion of requirement of written statement of compliance with § 2.1.4 in elevator permit applications, dating from 12/2/18.
7. Approval of meeting minutes from August 2, 2022, August 16, 2022, and August 30, 2022.
8. Old business (The Board may or may not discuss):

- **21 North Main Street, Uxbridge**

Petitioner was in front of the Board requesting a variance to allow the elevator to return to service in compliance with the code under which it was originally installed and not subject to any changes to code for such LULA units that may have come into effect since the original installation in 1996. Placed on hold for 60 days to come back in front of the Board with additional information.

**Deadline: July 16, 2022**

- **5 Sabrina Farm Road, Wellesley**

**New Installation**

Petitioner is requesting a variance from 524 CMR 35.00 Section 2.1.5 – Windows and Skylights. Placed on hold for 60 days to come back in front of the Board with additional information.

**Deadline: October 29, 2022**

- Continued discussion and review of 524 CMR Section 26.00: Certain Elevator Equipment Used as Motor Vehicle Parking Devices.

9. Matters not reasonably anticipated 48 hours in advance of meeting.