



CHARLES D. BAKER
GOVERNOR

KARYN E. POLITO
LIEUTENANT GOVERNOR

MIKE KENNEALY
SECRETARY OF HOUSING AND
ECONOMIC DEVELOPMENT

Commonwealth of Massachusetts
Division of Occupational Licensure
Office of Public Safety and Inspections

1000 Washington Street, Suite 710
Boston, Massachusetts 02118

EDWARD A. PALLESCHI
UNDERSECRETARY OF CONSUMER
AFFAIRS AND BUSINESS
REGULATION

LAYLA R. D'EMILIA
COMMISSIONER, DIVISION OF
OCCUPATIONAL LICENSURE

NOTICE OF MEETING

In accordance with the provisions of M.G.L.c. 30A, §20 notice is hereby given that a meeting of the Board of Elevator Regulations will be held on **Tuesday, October 26, 2021 at 1:00 p.m.**, at **1000 Washington Street, Boston, MA 02118** on the **1st Floor – Room 1D**. It is anticipated that the following will be discussed at the aforementioned meeting:

1. Roll Call
2. **57 Washington Avenue, Northampton**
New Installation
Petitioner is seeking a site-specific product variance to furnish and install a two-stop Stiltz Lift Model Trio Alta, residential vertical platform lift, per 524 CMR 38:00 and the Safety Standard for Platform Lifts and Stairway Chairlifts (ASME A18.1-2014).
3. **33 Massachusetts Avenue, Cambridge**
New Installation
Continuation of hearing. Petitioner provided additional information to the Board for further review.
4. Continued discussion of 524 CMR Section 10.00: Requirements for Permits and Inspections of Existing Elevators Undergoing Alterations and Replacements, and Section 11.00: Elevators Placed Out of Service or Decommissioned.
5. Investigatory conference pursuant to G. L. c. 112, § 65C. Closed Session.
6. Continued discussion regarding a possible safety/code issue for emergency services utilizing Fireman's Service Phase II.
7. Approval of meeting minutes from July 6, 2021, July 20, 2021, and August 10, 2021.
8. Old business (The Board may or may not discuss):
 - **184 Marlborough Street, Boston**
State ID: 1-P-5251
Petitioner was in front of the Board seeking to appeal an Inspector's Report citing "Machine Room is not vented 17.02". Placed on hold for 30 days to come back in front of the Board with additional information.

Deadline: November 18, 2021

- **859 Willard Street, Quincy**

State ID: 243-P-409

Petitioner was in front of the Board seeking a variance for the TOC handrail and the machine room vent – Inspector’s report citing 524 CMR §5.03 (8). Placed on hold for 30 days to come back in front of the Board with additional information.

Deadline: November 18, 2021

- **25 Fidelis Way, Boston**

Product Variance

Petitioner was in front of the Board seeking a variance to not have 42” rails or gates on the parking platforms. Placed on hold for 60 days to come back in front of the Board with additional information.

Deadline: December 18, 2021

9. Matters not reasonably anticipated 48 hours in advance of meeting.