



**CHARLES D.  
BAKER**  
GOVERNOR

**KARYN E. POLITO**  
LIEUTENANT GOVERNOR

**MIKE KENNEALY**  
SECRETARY OF HOUSING AND  
ECONOMIC DEVELOPMENT

**Commonwealth of Massachusetts  
Division of Occupational Licensure  
Office of Public Safety and Inspections**

1000 Washington Street, Suite 710  
Boston, Massachusetts 02118

**EDWARD A. PALLESCHI**  
UNDERSECRETARY OF CONSUMER  
AFFAIRS AND BUSINESS  
REGULATION

**LAYLA R. D'EMILIA**  
COMMISSIONER, DIVISION OF  
OCCUPATIONAL LICENSURE

**NOTICE OF MEETING**

In accordance with the provisions of M.G.L.c. 30A, §20 notice is hereby given that a meeting of the Board of Elevator Regulations will be held on **Tuesday, November 15, 2022 at 1:00 p.m.**, at **1000 Washington Street, Boston, MA 02118** on the **1<sup>st</sup> Floor – Room 1D**. It is anticipated that the following will be discussed at the aforementioned meeting:

1. Roll Call
2. Continued discussion of requirement of written statement of compliance with § 2.1.4 in elevator permit applications, dating from 12/2/18.
3. Discussion of car locking devices, manufacturers, and § 2.7.5.1 of elevator code.
4. **7 Newbury Street, Boston**  
**New Installation**  
Petitioner is seeking a variance from 524 CMR § 5.2.1.4.1, to allow the use of a LULA with a 14” deep pit, while code states the depth of the pit shall be no less than 35”.
5. **39 Lafayette Street, Marblehead**  
**State ID: 168-P-22**  
Petitioner is seeking a variance from 524 CMR 35:00 § 2.8.3.3, to allow the installation of sprinklers into the hoist ways, pits, machine rooms and control spaces.
6. **466 River Street, Mattapan**  
**State ID: 1-P-23353**  
Petitioner is seeking an interpretation from 524 CMR § 2.27.2 of ASME A17.1-2013 – Emergency or Standby Power System.
7. **129 Sturbridge Road, Charlton**  
**State ID: 54-V-21318**  
Petitioner is seeking a variance from an inspector’s report from August 18, 2022, citing “Operating Protective Safety Switch – § 32.08 no SOS”.
8. Approval of meeting minutes from August 2, 2022, August 16, 2022, and August 30, 2022.

9. Discussion of the Chair's proposal for scheduling future BER meetings.

10. Old business (The Board may or may not discuss):

- **21 North Main Street, Uxbridge**

Petitioner was in front of the Board requesting a variance to allow the elevator to return to service in compliance with the code under which it was originally installed and not subject to any changes to code for such LULA units that may have come into effect since the original installation in 1996. Placed on hold for 60 days to come back in front of the Board with additional information. **Deadline: July 16, 2022**

- **5 Sabrina Farm Road, Wellesley**

New Installation

Petitioner is seeking a variance from 524 CMR 35.00 Section 2.1.5 – Windows and Skylights. Placed on hold to come back in front of the Board with additional information.

- Continued discussion regarding the operation of the in car stop switch during Firefighters Emergency Operation.
- Continued discussion and review of 524 CMR Section 26.00: Certain Elevator Equipment Used as Motor Vehicle Parking Devices.

11. Matters not reasonably anticipated 48 hours in advance of meeting.