

DEVAL L. PATRICK GOVERNOR

TIMOTHY P. MURRAY LIEUTENANT GOVERNOR

JUDYANN BIGBY, MD SECRETARY

JOHN AUERBACH COMMISSIONER The Commonwealth of Massachusetts

Executive Office of Health and Human Services Department of Public Health Bureau for Environmental Health Community Sanitation Program 23 Service Center Northampton, MA 01060 Telephone: 413-586-7525 / (800) 445-1255 Facsimile: 413-784-1037/ (800) 769-9991 peter.wheeler@state.ma.us

May 4, 2011

Thomas Bowler, Sheriff Berkshire County Jail and House of Corrections 467 Cheshire Road Pittsfield, MA 01201

**Re: Facility Inspection** 

Dear Sheriff Bowler:

In accordance with M.G.L. c. 111, §§ 5, 20, and 21, and Department of Public Health Regulations 105 CMR 451.000: Minimum Health and Sanitation Standards and Inspection Procedures for Correctional Facilities; 105 CMR 480.000: Storage and Disposal of Infectious or Physically Dangerous Medical or Biological Waste (State Sanitary Code, Chapter VIII); 105 CMR 590.000: Minimum Sanitation Standards for Food Establishments (State Sanitary Code Chapter X); the 1999 Food Code; and 105 CMR 205.000 Minimum Standards Governing Medical Records and the Conduct of Physical Examinations in Correctional Facilities; I conducted an inspection of the Berkshire County Jail and House of Corrections on May 3, 2011 accompanied by Officer Ron Snyder and Lieutenant Katherine Sonsini, Compliance Officer. Violations noted are listed below (\* *indicates conditions documented on previous inspection reports*).

## **KITCHEN**

FC 4.501.11*	Good Repair: "A" line reach-in has three ripped gaskets
FC 4.501.11	Good Repair: Light bulbs not working on 2, 3 and 4 hood vents
FC 4.501.11	Good Repair: Light bulbs not working in walk-in 1
FC 3-305.11(3)	Food Storage: Food stored on floor
LAUNDRY	
	No Violations Noted
MEDICAL	
	No Violations Noted
MEDICAL SUITE	
MEDICAL SUITE	No Violations Noted
<u>COMMISSARY</u>	
	No Violations Noted

## <u>A POD</u>

Cells	
105 CMR 451.353	Interior Maintenance: Walls not easily cleanable in cell # 111 and 112
105 CMR 451.353	Interior Maintenance: Broken floor tile by cell # 107
105 CMR 451.353	Interior Maintenance: Debris on lights in cell # 103 and 105
105 CMR 451.353	Interior Maintenance: Rusted air vents in cell # 105 and 105 Interior Maintenance: Rusted air vents in cell # 102, 103, 105, 106 and 118
105 CMR 451.555	Interior Maintenance: Rusted air vents in cen # 102, 103, 103, 106 and 118
Showers	
	No Violations Noted
<u>B POD</u>	
Cells	
105 CMR 451.353	Interior Maintenance: Rusted air vents in cell # 106, 108, 111, 203, 209 and 217
105 CMR 451.353	Interior Maintenance: Cracked wall in cell # 117
Showers	
Showers	No Violations Noted
Sub Day Room	
105 CMR 451.353*	Interior Maintenance: Cracked chairs
<u>C POD</u>	
Cell	
105 CMR 451.353	Interior Maintenance: Floor drains clogged
FC 3 501.12(A)	Potentially Hazardous Foods: Milk stored in cell # 206
105 CMR 451.353	Interior Maintenance: Rusted air vents in cell # 205, 217 and 218
105 CIVIR 451.555	Interior Wantenance. Rusted an vents in cen # 200, 217 and 210
Showers	
	No Violations Noted
<u>D POD</u>	
Cells	
105 CMR 451.353	Interior Maintenance: Rusted air vents in cell # 108, 114, 206 and 216
105 CMR 451.113	Toilet and Handwash Sink: No hot water in cell # 209
Sub Day Room	
105 CMR 451.353	Interior Maintenance: Cracked chairs
Chauran	
Showers 105 CMR 451.123	Maintenance: Cracked floor tile by sub-day shower
105 CIVIR 451.125	Maintenance. Cracked noor the by sub-day shower
<u>E POD</u>	
Showers	
	No Violations Noted
Cells	
00110	No Violations Noted
Day Room	NT X7' 1 /' NT / 1
	No Violations Noted

## F POD

<i>Cells</i> 105 CMR 451.353 105 CMR 451.353 105 CMR 451.353	Interior Maintenance: Floor drains clogged Interior Maintenance: Rusted air vents in cell # 107, 108, 112, 116, 205 and 208 Interior Maintenance: Wall paint peeling in cell # 110
Shower	No Violations Noted
Day Room 105 CMR 451.353*	Interior Maintenance: Cracked chairs
<u>G POD</u>	
<i>Cells</i> 105 CMR 451.353	Interior Maintenance: Rusted air vents in cell # 112
Shower 105 CMR 451.123	Maintenance: Shower # 7 is out of order
Day Room 105 CMR 451.125	Drinking Water: Water fountain does not drain properly
<u>H POD</u>	
<i>Cells</i> 105 CMR 451.353	Interior Maintenance: Rusted air vents in cell # 107, 116, 117, 204 and 208
<u>WAREHOUSE</u>	

No Violations Noted

## **Observations and Recommendations**

> The inmate population was 287 at the time of inspection

This facility does not comply with the Department's Regulations cited above. In accordance with 105 CMR 451.404, please indicate next to each entry on the inspection report a plan of correction. Said plan of correction must be submitted within ten working days of receiving this report and should detail the specific steps that will be taken and the date of expected compliance. The plan of correction should be submitted to my attention, at the address listed above.

To review the specific regulatory requirements please visit our website at <u>www.mass.gov/dph/dcs</u> and click on "Community Sanitation Regulations" (available in both PDF and RTF formats).

To review the Food Establishment regulations please visit the Food Protection website at <u>www.mass.gov/dph/fpp</u> and click on "Food Protection Regulations". Then under "Retail" click "105 CMR 590.000 - State Sanitary Code Chapter X – Minimum Sanitation Standards for Food Establishments" and "<u>1999 Food Code</u>".

This inspection report is signed and certified under the pains and penalties of perjury.

Sincerely,

Peter Wheeler Environmental Health Inspector, CSP, BEH

 cc: Suzanne K. Condon, Associate Commissioner, Director, BEH Steven Hughes, Director, CSP, BEH JudyAnn Bigby, MD, Secretary, Executive Office of Health and Human Services Luis S. Spencer, Acting Commissioner, DOC Lieutenant Katherine Sonsini, Compliance Officer Pittsfield Board of Health Clerk, Massachusetts House of Representatives Clerk, Massachusetts Senate Mary Elizabeth Heffernan, EOPS