

Department of Environmental Protection

Northeast Regional Office • 205B Lowell Street, Wilmington MA 01887 • 978-694-3200

Charles D. Baker Governor

Karyn E. Polito Lieutenant Governor Matthew A. Beaton Secretary

> Martin Suuberg Commissioner

FINAL AIR QUALITY OPERATING PERMIT

(Administrative Amendment to MBR-95-OPP-095R2M, Transmittal X262995)

Issued by the Massachusetts Department of Environmental Protection ("MassDEP") pursuant to its authority under M.G.L. c. 111, §142B and §142D, 310 CMR 7.00 et seq., and in accordance with the provisions of 310 CMR 7.00: Appendix C.

ISSUED TO ["the Permittee"]:

Northeastern University 360 Huntington Avenue Boston, Massachusetts 02115

FACILITY LOCATION:

Northeastern University 360 Huntington Avenue Boston, Massachusetts 02115

NATURE OF BUSINESS:

Educational Institution - College

RESPONSIBLE OFFICIAL:

Name: Catherine Walsh Title: Associate Vice President Fiscal

INFORMATION RELIED UPON:

Application No. MBR-95-OPP-095R2MA Transmittal No. X272541

FACILITY IDENTIFYING NUMBERS:

AQ ID No.	1190054
FMF FAC No.	10831
FMF RO No.	161706

Standard Industrial Classification (SIC): 8221

North American Industrial Classification System: 611310

FACILITY CONTACT PERSON:

Name: Gerald Ziola Title: Associate Director, Sustainability & Energy Management Phone/Fax: 617-590-3070/617-373-8680 Email: g.ziola@neu.edu

This Operating Permit shall expire on June 24, 2019.

For MassDEP, Bureau of Air and Waste

This final document copy is being provided to you electronically by the Department of Environmental Protection. A signed copy of this document is on file at the DEP office listed on the letterhead.

Susan Ruch Acting Permit Chief and Deputy Regional Director February 2, 2017 Date

This information is available in alternate format. Contact Michelle Waters-Ekanem, Director of Diversity/Civil Rights at 617-292-5751. TTY# MassRelay Service 1-800-439-2370 MassDEP Website: www.mass.gov/dep

Printed on Recycled Paper

TABLE OF CONTENTS

Section	Special Conditions for Operating Permit	Page No.				
1	Permitted Activities and Description of Facility and Operations	3				
2	Emission Unit Identification – Table 1	4				
3	Identification of Exempt Activities – Table 2	6				
4	Applicable Requirements					
	A. Operational and/or Production Emission Limits and Restrictions – Table 3	6				
	B. Compliance Demonstration					
	- Monitoring and Testing Requirements – Table 4	13				
	- Record Keeping Requirements - Table 5	17				
	- Reporting Requirements – Table 6	20				
	C. General Applicable Requirements	22				
	D. Requirements Not Currently Applicable -Table 7	22				
5	Special Terms and Conditions – Table 8	23				
6	Alternative Operating Scenarios – Table 9	24				
7	Emissions Trading – Table 10	25				
8	Compliance Schedule 25					
Section	General Conditions for Operating Permit	Page No.				
9	Fees	25				
10	Compliance Certification	25				
11	Noncompliance	27				
12	Permit Shield	27				
13	Enforcement	27				
14	Permit Term	28				
15	Permit Renewal	28				
16	Reopening for Cause	28				
17	Duty to Provide Information	28				
18	Duty to Supplement	29				
19	Transfer of Ownership or Operation	29				
20	Property Rights	29				
21	Inspection and Entry	29				
22	Permit Availability	30				
23	Severability Clause	30				
24	Emergency Conditions	30				
25	Permit Deviation	31				
26	Operational Flexibility	31				
27	Modifications	32				
28	Ozone Depleting Substances	32				
20	Prevention of Accidental Releases	33				
29	Trevention of Accidental Releases	33				

SPECIAL CONDITIONS FOR OPERATING PERMIT

1. <u>PERMITTED ACTIVITIES</u>

In accordance with the provisions of 310 CMR 7.00:Appendix C and applicable rules and regulations, the Permittee is authorized to operate air emission units as shown in Table 1 and exempt, and insignificant activities as described in 310 CMR 7.00:Appendix C(5)(h) and (i). The units described in Table 1 are subject to the terms and conditions shown in Sections 4, 5, and 6 and to other terms and conditions as specified in this Permit. Emissions from the exempt activities shall be included in the total facility emissions for the emission-based portion of the fee calculation described in 310 CMR 4.00 and this Permit.

DESCRIPTION OF FACILITY AND OPERATIONS

Northeastern University ("the Permittee") is an educational institution, located at 360 Huntington Avenue, in Boston ("Facility"). The Permittee is authorized to operate twenty-eight (28) boilers and twenty-one (21) emergency generators that are subject to and regulated by the initial Operating Permit, an Operating Permit Renewal, and subsequent Operating Permit Minor Modifications. All twenty-eight (28) boilers were installed prior to June 4, 2010.

As described in the original Operating Permit Application (MBR-95-OPP-095) and the prior Operating Permit Renewal (MBR-95-OPP-095R), the Permittee states that it is not potentially major for single hazardous air pollutants (HAPs) nor total HAPs.

The previous Minor Modification to the Operating Permit involved the inclusion of fossil fuel utilization equipment that was being added to the Operating Permit due to the purchase of a new building known as Hastings Hall. This equipment consists of two existing boilers which are listed in Table 1 as EU107 and EU108. In addition, the Permittee has replaced the existing burners on EU66 and EU67 so that each new burner is capable of firing natural gas as a maximum firing rate of 5,866 cubic feet per hour as the primary fuel and distillate fuel oil with a maximum sulfur content of less than or equal to 0.3 percent by weight at a maximum firing rate of 41.9 gallons per hours as the secondary fuel. The Permittee shall comply with the requirements from the NESHAPs for Industrial, Commercial, and Institutional Boilers Area Sources (40 CFR Part 63, Subpart JJJJJJ) regarding EU107 and EU108, as is required for all other applicable boilers at the Facility.

The current Minor Modification to the Operating Permit involves the inclusion of fossil fuel utilization equipment that is being added to the Operating Permit due to a new leased building known as East Village. This equipment consists of a new emergency generator which is listed in Table 1 as EU36.

There are a total of twenty-three (23) boilers that are subject to 40 CFR Part 63, Subpart JJJJJJ and eight (8) emergency generators that are subject to 40 CFR Part 63, Subpart ZZZZ, National Emission Standards for Hazardous Air Pollutants (NESHAPs) for Stationary Reciprocating Internal Combustion Engines. Since the Permittee's Facility is an area source for HAPs and is defined as an institution, compliance with 40 CFR Part 63, Subpart ZZZZ shall be met by complying with the requirements of 40 CFR Part 60, Subpart IIII, "Standards of Performance for Stationary

Compression Ignition Internal Combustion Engines" and 40 CFR Part 60, Subpart JJJJ, "Standards of Performance for Stationary Spark Ignition Internal Combustion Engines". In addition, since the Permittee is defined as an institution, the existing engines (EU9, EU11, EU12, EU15, EU16, EU17, EU18, EU19, EU32, EU33, EU34, EU35, and EU52) that were installed prior to June 12, 2006 are not subject to 40 CFR Part 63, Subpart ZZZZ due to an exemption specified under 40 CFR 63.6585(f)(3). The emergency generators, EU50, EU51, EU53, EU54, EU55, EU56, EU60, and EU36 were installed after June 12, 2006, and therefore, are subject to 40 CFR Part 63, Subpart ZZZZ. In addition, seven of these eight emergency generators are subject to 40 CFR Part 60, Subpart IIII while EU60 is subject to 40 CFR Part 60, Subpart JJJJ.

This Operating Permit includes all the Minor Modifications to the Operating Permit that have been incorporated to date since the previous Operating Permit Renewal was issued on July 20, 2009. The most recent Minor Modification to the Operating Permit was issued on March 20, 2013. No other modifications have been made at the Facility.

Facility requirements for applicable emission units are listed in the following tables:

Table 3 states the emission limits and restrictions; Table 4 states the monitoring and testing requirements; Table 5 states the record keeping requirements; Table 6 states the reporting requirements; and Table 7 states regulations to which the facility is not subject.

2. <u>EMISSION UNIT IDENTIFICATION</u>

	Table 1		
	DESCRIPTION OF EMISSION UNIT	EU DESIGN CAPACITY	POLLUTION CONTROL DEVICE (PCD)
EU1	Cleaver Brooks Model No. CB-500 Boiler	20.925 MMBtu/hour	
EU2	Johnston Model No. PFTA-800-3H-150 Boiler	32.426 MMBtu/hour	
EU3	Johnston Model No. PFTA-800-3H-150 Boiler	32.426 MMBtu/hour	
EU4	Johnston Model No. PFTA-1000-4G-150S Boiler	41.85 MMBtu/hour	
EU5	Johnston Model No. PFTA-1000-4G-150S Boiler	41.85 MMBtu/hour	
EU6	Hurst Boiler	42.00 MMBtu/hour	
EU9	Onan 600 kW emergency generator	6.1 MMBtu/hour	
EU11	Onan 500 kW emergency generator	5.3 MMBtu/hour	NTana
EU12	Caterpillar 350 kW emergency generator	3.3 MMBtu/hour	None
EU13	Buderus boiler	3.1 MMBtu/hour	
EU14	Buderus boiler	3.1 MMBtu/hour	
EU15	Caterpillar 800 kW emergency generator	8.0 MMBtu/hour	
EU16	Cummins 400 kW emergency generator	3.8 MMBtu/hour	
EU17	Kohler 600 kW emergency generator	6.1 MMBtu/hour	
EU18	Caterpillar 1000 kW emergency generator	9.6 MMBtu/hour	
EU19	Onan 400 kW emergency generator	4.0 MMBtu/hour	
EU20	HB Smith #350 boiler	3.2 MMBtu/hour	
EU22	Weil McLain H-1088-WS boiler	3.1 MMBtu/hour	

The following emission units (Table 1) are subject to and regulated by this Operating Permit:

	Table 1		
(EU#)	DESCRIPTION OF EMISSION UNIT	EU DESIGN CAPACITY	POLLUTION CONTROL DEVICE (PCD)
EU24	Weil McLain 2094 boiler	6.9 MMBtu/hour	
EU25	Weil McLain H-1094-S-W boiler	3.3 MMBtu/hour	None
EU26	Weil McLain H-1494-S boiler	4.7 MMBtu/hour	
EU27	Weil McLain H-1194-S boiler	3.3 MMBtu/hour	
EU29	Weil McLain H-1292SN boiler	3.6 MMBtu/hour	
EU30	Weil McLain #1488 boiler	3.3 MMBtu/hour	
EU31	Weil McLain #1488 boiler	4.2 MMBtu/hour	
EU32	Caterpillar 500 kW emergency generator	5.1 MMBtu/hour	
EU33	Caterpillar 550 kW emergency generator	5.7 MMBtu/hour	
EU34	Kohler 750 kW emergency generator	6.5 MMBtu/hour	
EU35	Onan 400 kW emergency generator	3.8 MMBtu/hour	
EU36	Cummins 500 kW emergency generator	4.9 MMBtu/hour	
EU50	Caterpillar 750 kW emergency generator	7.5 MMBtu/hour	
EU51	Cummins 400 kW emergency generator	3.82 MMBtu/hour	
EU52	Caterpillar 300 kW emergency generator	3.2 MMBtu/hour	None
EU53	Katolight 200 kW emergency generator	2.17 MMBtu/hour	TONE
EU54	Katolight 50 kW emergency generator	0.62 MMBtu/hour	
EU55	Cummins 175 kW emergency generator	2.1 MMBtu/hour	
EU56	Cummins 100 kW emergency generator	1.2 MMBtu/hour	
EU60	Kohler 18 kW emergency generator	0.28 MMBtu/hour	
EU66	Burnham 3L175LBSPL boiler	8.4 MMBtu/hour	
EU67	Burnham 3L175LBSPL boiler	8.4 MMBtu/hour	
EU100	Weil McLain boiler	0.765 MMBtu/hour	
EU101	Mills boiler	0.695 MMBtu/hour	
EU102	Weil McLain boiler	0.382 MMBtu/hour	
EU103	Mills boiler	0.765 MMBtu/hour	
EU104	Weil McLain boiler	2.4 MMBtu/hour	
EU105	Weil McLain boiler	0.3 MMBtu/hour	
EU106	Weil McLain boiler	0.75 MMBtu/hour	
EU107	Burnham boiler	4.9 MMBtu/hour	
EU108	HB Smith boiler	4.9 MMBtu/hour	1

Legend to Abbreviated Terms within Table 1: EU# = Emission Unit Number MMBtu/hr = million British thermal units per hour kW = kilowatt

3. <u>IDENTIFICATION OF EXEMPT ACTIVITIES</u>

The following are considered exempt activities in accordance with the criteria contained in 310 CMR 7.00: Appendix C(5)(h):

Table 2				
Description of Current Exempt Activities	Reason			
The list of current exempt activities is contained in the Operating Permit application and shall be updated by the Permittee to reflect changes at the facility over the Permit term. An up-to- date copy of exempt activities list shall be kept on-site at the facility and a copy shall be submitted to MassDEP's Regional Office. Emissions from these activities shall be reported on the annual emissions statement pursuant to 310 CMR 7.12.	310 CMR 7.00:Appendix C(5)(h)			

4. <u>APPLICABLE REQUIREMENTS</u>

A. OPERATIONAL AND/OR PRODUCTION EMISSION LIMITS AND RESTRICTIONS

The Permittee is subject to the emission limits/restrictions as contained in Table 3 below:

	Table 3					
EU#	FUEL	RESTRICTIONS	POLLUTANT	EMISSION LIMIT/STANDARD ¹	APPLICABLE REGULATION AND/OR APPROVAL NO.	
EU1, EU2, EU3	natural gas	NA	NOx CO	≤30 ppmvd, corrected to 3% O ₂ ≤0.04 lb/MMBtu	MBR-91-COM-017B	
			PM	≤0.10 lb/MMBtu	MBR-83-COM-090 (EU1) MBR-88-COM-033 (EU2,EU3) 310 CMR 7.02(8)	
	No.2 fuel oil ≤0.05% S by wt.		NOx	\leq 150 ppmvd, corrected to 3% O_2	MBR-91-COM-017B	
			CO	<u><</u> 0.04 lb/MMBtu		
			РМ	≤0.10 lb/MMBtu	MBR-83-COM-090 (EU1) MBR-88-COM-033 (EU2,EU3) 310 CMR 7.02(8)	
			Sulfur in Fuel	≤0.05% S by wt. ≤0.0015% S by wt. on and after July 1, 2018	MBR-91-COM-017B 310 CMR 7.05(1)(a)(1), Table 1	

	Table 3					
EU#	FUEL	RESTRICTIONS	POLLUTANT	EMISSION LIMIT/STANDARD ¹	APPLICABLE REGULATION AND/OR APPROVAL NO.	
EU4, EU5	natural gas	NA	NOx	\leq 30 ppmvd, corrected to 3% O_2	MBR-91-COM-017B	
			СО	≤0.04 lb/MMBtu		
			PM	<u>≤</u> 0.10 lb/MMBtu	310 CMR 7.02(8)(h)	
	No.2 fuel oil ≤0.05% S by wt.	\leq 442,760 gallons of usage (\leq 730 hours	NOx	\leq 150 ppmvd, corrected to 3% O_2	MBR-91-COM-017B	
		of operation) in any consecutive 12 month period	СО	<u>≤</u> 0.04 lb/MMBtu		
		montin period	PM	<u><</u> 0.10 lb/MMBtu	310 CMR 7.02(8)(h)	
			Opacity	20%, except for one 6-minute period per hour < <u>27%</u>	40 CFR Part 60, Subpart Dc	
			Sulfur in Fuel	<u>≤</u> 0.05% S by wt.	MBR-91-COM-017B	
				≤0.0015% S by wt. on and after July 1, 2018	310 CMR 7.05(1)(a)(1), Table 1	
EU6	natural gas	NA	NOx	<u>≤</u> 0.011 lb/MMBtu	MBR-04-COM-005	
			CO	<u><</u> 0.0185 lb/MMBtu		
			PM	<u><</u> 0.0033 lb/MMBtu	40 CFR Part 60, Subpart Dc	
			VOC	<u><</u> 0.0012 lb/MMBtu		
			SO_2	<u><</u> 0.001 lb/MMBtu		
			Opacity	\leq 10% at any given time		
	No.2 fuel oil	<u><</u> 323,244 gallons of	NOx	<u><</u> 0.10 lb/MMBtu	MBR-04-COM-005	
	<u><</u> 0.003% S by wt.	usage in any	СО	<u><</u> 0.117 lb/MMBtu		
		consecutive 12	PM	≤ 0.014 lb/MMBtu	40 CFR Part 60, Subpart Dc	
		month period	VOC	<u><0.004 lb/MMBtu</u>		
			SO ₂	<u>≤</u> 0.008 lb/MMBtu		
			Opacity	$\leq 10\%$ at any given time		
			Sulfur in Fuel	<u>≤</u> 0.003% S by wt.	MBR-04-COM-005	
				≤0.0015% S by wt. on and after July 1, 2018	310 CMR 7.05(1)(a)(1), Table 1	
EU1, EU2, EU3, EU4, EU5, EU6	natural gas	NA	HAPs	As required in § 63.11205, at all times operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions.	40 CFR Part 63, Subpart JJJJJJ	

	Table 3					
EU#	FUEL	RESTRICTIONS	POLLUTANT	EMISSION LIMIT/STANDARD ¹	APPLICABLE REGULATION AND/OR APPROVAL NO.	
EU1, EU2, EU3, EU4, EU5, EU6	See above for fuel oil requirements	NA	HAPs	As required in § 63.11201, §63.11214 and Table 2 to Subpart JJJJJJ, conduct tune-up of boiler biennially as specified in § 63.11223(b)(1) through (7)	40 CFR Part 63, Subpart JJJJJJ	
				As required in § 63.11201 and Table 2 to Subpart JJJJJJ, conduct an energy assessment audit	40 CFR Part 63, Subpart JJJJJJ Compliance date: March 21, 2014	
EU9, EU11, EU12, EU15, EU16, EU17,	ULSD ≤0.0015% S by wt.	\leq 300 operating hours each unit in any consecutive 12	NA	NA	310 CMR 7.03(10)(a)	
EU18, EU19, EU32, EU33, EU34, EU35, EU52		month period	Sulfur in Fuel	<u>≤</u> 0.0015% S by wt.	310 CMR 7.03(10)(b) 310 CMR 7.05(1)(a)3	
EU36, EU50, EU51, EU53, EU54, EU55, EU56	ULSD ≤0.0015% S by wt.	≤300 operating hours each unit in any consecutive 12 month period	Sulfur in Fuel	<u>≤</u> 0.0015% S by wt.	310 CMR 7.26(42) 310 CMR 7.05(1)(a)3	
			NO _x	9.2 g/KW-hr	40 CFR 60.4209(a) 40 CFR 89.112(a)	
EU36, EU50, EU51, EU53, EU55		≤300 operating hours each unit in any consecutive 12	НС	1.3 g/KW-hr	40 CFR 63.6590(c), 40 CFR 60.4202(a), 40 CFR 89.112(a), 40 CFR 60.4211(f), 40 CFR	
EU53, EU55, EU56		month period	$\mathrm{NMHC} + \mathrm{NO}_{\mathrm{X}}$	4.0 g/KW-hr	60.4207(b), 40 CFR 80.510(b)	
EU54			$NMHC + NO_X$	4.7 g/KW-hr		
EU36, EU50, EU51				6.4 g/KW-hr		
EU36, EU50, EU51, EU53, EU55			СО	3.5 g/KW-hr		
EU54, EU56				5.0 g/KW-hr		
EU36, EU50, EU51, EU53,			PM	0.2 g/KW-hr		
EU55, EU56				0.3 g/KW-hr		
EU54				0.4 g/KW-hr		

	Table 3					
EU#	FUEL	RESTRICTIONS	POLLUTANT	EMISSION LIMIT/STANDARD ¹	APPLICABLE REGULATION AND/OR APPROVAL NO.	
EU60	natural gas only	≤300 operating hours each unit in any consecutive 12 month period	NA	NA	40 CFR 63.6590(c), 40 CFR 90.103 MBR-95-OPP-095RM2	
EU20, EU24, EU25, EU26, EU27	natural gas only	NA	PM	≤0.10 lb/MMBtu	310 CMR 7.02(8)(h) 310 CMR 7.04(4)(a)	
EU13, EU14, EU22	natural gas (primary fuel)	NA	РМ	<u><</u> 0.10 lb/MMBtu	310 CMR 7.02(8)(h) 310 CMR 7.04(4)(a)	
EU13, EU14, EU22, EU29, EU104, EU105, EU106	No.2 fuel oil ≤0.3% S by wt. (secondary fuel)	NA	Sulfur in Fuel	 ≤0.3% S by wt. ≤0.05% S by wt. July 1, 2014 through June 30. 2018 ≤0.0015% S by wt. on and after July 1, 2018 	310 CMR 7.05(1)(a)(1), Table 1	
EU13, EU14, EU22, EU29, EU104, EU105, EU106	natural gas (primary fuel) No.2 fuel oil ≤0.3% S by wt. (secondary fuel)	NA	HAPs	As required in § 63.11205, at all times operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. As required in § 63.11201, §63.11214 and Table 2 to Subpart JJJJJJ, conduct tune-up of boiler at least once every five years as specified in § 63.11223(b)(1) through (7)	40 CFR Part 63, Subpart JJJJJJ	
			All	Conduct a tune-up of the boiler at least once every five years as specified in section 63.11223 ^{3,} ⁴ . Each five-year tune-up must be conducted no more than 61 months after the previous tune- up.	40 CFR 63.11201(b)	
EU30, EU31, EU107, EU108	No.2 fuel oil only ≤0.3% S by wt.	NA	РМ	≤0.10 lb/MMBtu	310 CMR 7.02(8)(h) 310 CMR 7.04(4)(a)	

	Table 3					
EU#	FUEL	RESTRICTIONS	POLLUTANT	EMISSION LIMIT/STANDARD ¹	APPLICABLE REGULATION AND/OR APPROVAL NO.	
EU30, EU31, EU100, EU101, EU102, EU103,	No.2 fuel oil only ≤0.3% S by wt.	NA	Sulfur in Fuel	≤0.3% S by wt. ≤0.05% S by wt. July 1, 2014 through June 30, 2018 ≤0.0015% S by wt. on and after	310 CMR 7.05(1)(a)1, Table 1	
EU107, EU108			HAPs	July 1, 2018 As required in § 63.11205, at all times operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. As required in § 63.11201, §63.11214 and Table 2 to Subpart JJJJJJ, conduct tune-up of boiler at least once every five years as specified in § 63.11223(b)(1) through (7)	40 CFR Part 63, Subpart JJJJJJ	
			All	Conduct a tune-up of the boiler at least once every five years as specified in section 63.11223 ^{3, 4} . Each five-year tune-up must be conducted no more than 61 months after the previous tune- up.	40 CFR 63.11201(b)	
EU66, EU67	natural gas (primary fuel) No.2 fuel oil $\leq 0.3\%$ S by wt. (secondary fuel)	NA	РМ	≤0.10 lb/MMBtu	310 CMR 7.02(8)(h) 310 CMR 7.04(4)(a)	
	No.2 fuel oil <u><</u> 0.3% S by wt. (secondary fuel)		Sulfur in Fuel	 ≤0.3% S by wt. ≤0.05% S by wt. July 1, 2014 through June 30. 2018 ≤0.0015% S by wt. on and after July 1, 2018 	310 CMR 7.05(1)(a)1, Table 1	

	Table 3					
EU#	FUEL	RESTRICTIONS	POLLUTANT	EMISSION LIMIT/STANDARD ¹	APPLICABLE REGULATION AND/OR APPROVAL NO.	
EU66, EU67	No.2 fuel oil ≤0.3% S by wt. (secondary fuel)	NA	HAPs	As required in § 63.11205, at all times operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. As required in § 63.11201, §63.11214 and Table 2 to Subpart JJJJJJ, conduct tune-up of boiler biennially as specified in § 63.11223(b)(1) through (7)	40 CFR Part 63, Subpart JJJJJJ 40 CFP (2 11201/h)	
			All	Conduct a tune-up of the boiler biennially as specified in section 63.11223 ^{3,4} . Each biennial tune-up must be conducted no more than 25 months after the previous tune- up.	40 CFR 63.11201(b)	
Facility-wide	NA	NA	Single HAP	< 3.0 tons per month and < 9.0 tons per twelve month rolling period	Operating Permit Renewal Application Transmittal No. W059861	
			Total HAPs	< 8.0 tons per month and < 24 tons per twelve month rolling period		
			Visible	< No. 1 of Chart ² , except No. 1 to < No. 2 of Chart for <u>< 6</u> minutes during any one hour	310 CMR 7.06(1)(a)	
			Opacity	\leq 20%, except 20% to \leq 40% for \leq 2 minutes during any one hour		
			Greenhouse Gas ⁵	NA	310 CMR 7.71	
			Gas		(state only)	

Table 3 Key:

EU# = Emission Unit number S by wt. = sulfur by weight lb/MMBtu = pound per million British thermal units lb/hr = pound per hour ppm = parts per million ppmvd = parts per million, dry volume g/bhp-hr = grams per brake horse power hour g/KW-hr = grams per kilowatt hour kg/hr = kilograms per hour O₂ = oxygen NOx = oxides of nitrogen CO = carbon monoxide PM = particulate matter SO₂ = sulfur dioxide VOC = volatile organic compounds HC = hydrocarbons NMHC + NO_x = non-methane hydrocarbons plus oxides of nitrogen % = percent < = less than \leq = less than or equal to NA = not applicable ULSD = ultra-low sulfur transportation diesel No. 2 fuel oil HAP = hazardous air pollutant HAPs = hazardous air pollutants

Table 3 Notes:

- 1 Compliance with emission limits/standards shall be based on a 1 hour block averaging time.
- 2 Chart means the Ringelmann Scale for grading the density of smoke, as published by the United States Bureau of Mines and as referred to in the Bureau of Mines Information Circular No. 8333, or any smoke inspection guide approved by MassDEP.
- 3 40 CFR 63.11223(b) states; You must conduct a tune-up of the boiler biennially to demonstrate continuous compliance as specified in paragraphs (b)(1) through (5) and (7) of this section.

(1) As applicable, inspect the burner, and clean or replace any components of the burner as necessary (you may delay the burner inspection until the next scheduled unit shutdown, but you must inspect each burner at least once every 36 months).

(2) Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern. The adjustment should be consistent with the manufacturer's specifications, if available.

(3)Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure that it is correctly calibrated and functioning properly.

(4) Optimize total emissions of carbon monoxide. This optimization should be consistent with the manufacturer's specifications, if available.

(5) Measure the concentrations in the effluent stream of carbon monoxide in parts per million, by volume, and oxygen in volume percent, before and after the adjustments are made (measurement may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made).

(7) If the unit is not operating on the required date for a tune-up, the tune-up must be conducted within one week of startup.

- 4 In accordance with 40 CFR 63.11205(a), you must operate and maintain any affected source at all times, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator that may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.
- 5 <u>Greenhouse Gas</u> means any chemical or physical substance that is emitted into the air and that the Department may reasonably anticipate will cause or contribute to climate change including, but not limited to, CO₂, CH₄, N₂O, SF₆, hydrofluorocarbons (HFCs), and perfluorocarbons (PFCs).

B. COMPLIANCE DEMONSTRATION

The Permittee is subject to the monitoring/testing, record keeping, and reporting requirements as contained in Tables 4, 5, and 6 below and 310 CMR 7.00 Appendix C (9) and (10) and applicable requirements contained in Table 3:

	Table 4
EMISSION UNIT	MONITORING/TESTING REQUIREMENTS
EU4, EU5	 Monitor No.2 transportation diesel fuel oil (≤ 0.05% S by weight) usage as fired to verify compliance with the applicable fuel restriction of less than 442,760 gallons per twelve month period as referenced in Conditional Approval MBR-91-COM-017B, dated June 30, 1993. Calibrate, maintain, and operate a fuel oil metering device for each subject boiler so that fuel oil
EU6	usage can be recorded for each subject boiler, as referenced in Conditional Approval MBR-91- COM-017B, dated June 30, 1993. 3) Monitor ultra-low sulfur transportation diesel (ULSD) No.2 fuel oil (< 0.003% S by weight) usage
	as fired to verify compliance with this fuel restriction of less than 323,244 gallons per twelve month period as referenced in Conditional Approval MBR-04-COM-005, dated June 16, 2004.
	4) Calibrate, maintain, and operate a fuel-metering device and recorder for each fuel of use for the subject boiler so that fuel usage can be recorded for the subject boiler, as referenced in Approval MBR-04-COM-005, Proviso No. B.4.a).
	5) In accordance with Approval MBR-04-COM-005, monitor fuel purchases receipts and fuel usage logs which reflect actual fuel usage on a weekly basis as well as the amount of time and the monthly totals of fuel usage and resulting emissions from each type of fuel burned, the actual sulfur content of the fuel oil used, and the total fuel usage and resulting emissions from each type of fuel burned for the previous twelve months. As referenced in Approval MBR-04-COM-005, Proviso No. B.5, for the purposes of calculating emissions resulting from each fuel burned, the following values shall be used: Natural Gas: 1,000 Btu per cubic foot
	ULSD: 140,000 Btu per gallon 6) As referenced in Approval MBR-04-COM-005, monitor when this EU switches to No. 2 fuel oil,
	 including the date and time of the fuel switch, the duration of the fuel switch, the amount of No. 2 fuel oil consumed during each fuel switch, and the date and time for return to natural gas firing. 7) Conduct NOx/CO optimization and tune the boiler according to procedures contained in EPA
	340/1-83-023 "Combustion Efficiency Optimization Manual for Operators of Oil and Gas Fired Boilers" with the goal of reducing air pollutant emissions to optimum levels. In addition, NU shall tune the boiler in accordance with said procedures and inspect and maintain said boiler per manufacturer recommendations as well as test for efficient operation on an annual basis, as referenced in Approval MBR-04-COM-005, Proviso B.4.e). The results of said inspection, maintenance, and testing and the date upon which it was performed shall be recorded and posted conspicuously on or near the subject equipment. Allow MassDEP to witness tuning of the boiler if and when requested by MassDEP as referenced in Approval MBR-04-COM-005, Proviso B.11. 8) Install, calibrate, maintain, and operate a fuel-metering device for each fuel of use for the
	subject boiler so that its total fuel usage can be recorded; as referenced in Approval MBR-04-COM-005, Proviso B.4.a).
	9) That for compliance testing purposes, the subject boiler shall be constructed so as to accommodate the emissions testing requirements as stipulated in 40 CFR Part 60, Appendix A. The two outlet sampling ports (90 degrees apart from each other) for the subject boiler must be located at a minimum of one duct diameter upstream and two duct diameters downstream of any flow disturbance, as referenced in Approval MBR-04-COM-005, Proviso B.6.

Table 4		
EMISSION	N MONITORING/TESTING REQUIREMENTS	
UNIT		
EU4, EU5,	10) Measure for each unit the amounts of each fuel combusted during each month as provided in 40	
EU6	CFR 60.48c(g)(2) incorporated herein by reference.	
	11) Compliance with the fuel oil sulfur limits under 40 CFR 60.42c may be determined based on a	
	certification from the fuel supplier as provided in 40 CFR 60.42c(h) incorporated herein by	
	reference. As provided by 40 CFR $60.48c(e)(11)$, said certification shall include the name of the oil	
	supplier and a statement from the oil supplier that the oil complies with the specifications for fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D396-	
	78, 89, 90, 92, 96, 98, "Standard Specification for Fuel Oils" incorporated herein by reference.	
	12) In accordance with 40 CFR 60.42c(h), compliance with the SO ₂ emission limits or fuel oil	
	sulfur limits under 40 CFR 60.42c(d) and 40 CFR 60.42c(i) may be demonstrated based on a	
	certification from the fuel supplier. The performance test as required under 40 CFR 60.8 shall	
	consist of the certification from the fuel supplier as described under 40 CFR 60.48c(f). As stated	
	under 40 CFR 60.48c(f)(1) for affected facilities that combust distillate oil, said certification shall	
	include the name of the oil supplier and a statement from the oil supplier that the oil complies with	
	the specifications under the definition of distillate oil in 40 CFR 60.41c; more specifically, that the	
	oil complies with specifications for Fuel Oil No. 1 or 2, as defined by the American Society for	
	Testing and Materials in ASTM D396-78, 89, 90, 92, 96, and 98 "Standard Specification for Fuel Oils" (incomposited hencin by reference and 40 CEP 60.17). Comply with applicable monitoring	
	Oils" (incorporated herein by reference-see 40 CFR 60.17). Comply with applicable monitoring requirements in 40 CFR 60.48c(e)2 through (10).	
EU1, EU2,	13) Monitor smoke density equipment data in accordance with 310 CMR 7.04(2).	
EU3, EU4,	14) Demonstrate compliance with 310 CMR 7.19 by monitoring all data relevant to 310 CMR	
EU5, EU6	7.19(6)(a). This monitoring shall include, but not be limited to tune-ups, adjustments, and	
,	verification of set-points.	
	15) Monitor at least once per month that settings determined during the tune-up have not changed as	
	per 310 CMR 7.19(6)(b)2.g.	
	16) As required in § 63.11201, §63.11214 and Table 2 to Subpart JJJJJJ, perform a one-time energy	
	assessment by a qualified energy assessor. An energy assessment completed on or after January 1,	
	2008, that meets or is amended to meet the energy assessment requirements herein satisfies the	
	energy assessment requirement. The energy assessment must include: (1) A visual inspection of the boiler system,	
	(1) A visual inspection of the bond system,(2) An evaluation of operating characteristics of the facility, specifications of energy using	
	systems, operating and maintenance procedures, and unusual operating constraints,	
	(3) Inventory of major systems consuming energy from affected boiler(s),	
	(4) A review of available architectural and engineering plans, facility operation and	
	maintenance procedures and logs, and fuel usage,	
	 (5) A list of major energy conservation measures, (6) A list of the energy equipse potential of the energy concernation measures identified 	
	(6) A list of the energy savings potential of the energy conservation measures identified,(7) A comprehensive report detailing the ways to improve efficiency, the cost of specific	
	(7) A completensive report detailing the ways to improve enciency, the cost of specific improvements, benefits, and the time frame for recouping those investments.	
	The energy assessment must be completed by March 21, 2014.	
<u> </u>	The energy approximate mast be completed by Match 21, 2011.	

	Table 4	
EMISSION UNIT	MONITORING/TESTING REQUIREMENTS	
EU13, EU14, EU22, EU29,	17) As required in § 63.11201, §63.11214 and Table 2 to Subpart JJJJJJ, conduct tune-up of boiler at least once every five years as specified in § 63.11223(b)(1) through (7). Also in accordance with 40 CFR Part 63, Subpart JJJJJJ, §63.11223(b)(5), measure the concentration in the effluent stream of carbon monoxide in parts per million, by volume, and oxygen in volume percent, before and after the required biennial tune-up.	
EU108		
EU1, EU2, EU3, EU4, EU5, EU6, EU66, EU67	18) As required in § 63.11201, §63.11214 and Table 2 to Subpart JJJJJJ, conduct tune-up of boiler biennially as specified in § 63.11223(b)(1) through (7). Also in accordance with 40 CFR Part 63, Subpart JJJJJJ, §63.11223(b)(5), measure the concentration in the effluent stream of carbon monoxide in parts per million, by volume, and oxygen in volume percent, before and after the required biennial tune-up. Each biennial tune-up must be conducted no more than 25 months after the previous tune-up.	
EU1, EU2,	19) In accordance with 310 CMR 7.04(4)(a), inspect and maintain fuel utilization facility in	
EU3, EU4,	accordance with manufacturer's recommendations and test for efficient operation at least annually.	
EU5, EU6,		
EU13, EU14,		
EU20, EU22,		
EU24, EU25,		
EU26, EU27,		
EU29, EU30,		
EU31, EU66,		
EU67,		
EU107,		
EU108		
	20) In accordance with 310 CMR 7.03(10), monitor the consumption of diesel fuel oil ($\leq 0.0015\%$ S	
	by weight) and the hours of operation for each EU to verify compliance with the restriction of less	
	than 300 hours per twelve month period.	
EU18, EU19,		
EU32, EU33,		
EU34, EU35, EU52		
EU52	21) In accordance with 310 CMR 7.26(42), monitor the consumption of diesel fuel oil ($\leq 0.0015\%$ S	
	by weight) and the hours of operation for each EU to verify compliance with the restriction of less than 300 hours per twelve month period.	
EU34, EU33, EU56	22) A non-turnback hour counter shall be installed, operated, and maintained in good working order	
L030		
	to monitor operating hours as referenced in Regulation 310 CMR 7.26(42)(d)1. 23) In accordance with 310 CMP 7.26(42)(a)2. Mass DEP may require a mission or other monitoring	
	23) In accordance with 310 CMR 7.26(42)(e)2., MassDEP may require emission or other monitoring	

23) In accordance with 310 CMR 7.26(42)(e)2., MassDEP may require emission or other monitoring to assure compliance with the requirements of 310 CMR 7.26(42).

	Table 4	
EMISSION	MONITORING/TESTING REQUIREMENTS	
UNIT		
EU36, EU50,	24)In accordance with 310 CMR 7.26(42)(e)3., any testing when required shall comply with the	
EU51, EU53,	6	
EU54, EU55,	a. Tests to certify compliance with emission limitations must be performed in accordance with	
EU56	EPA Reference Methods, California Air Resources Board Methods approved by EPA, or equivalent methods as approved by MassDEP and EPA.	
	 b. Particulate matter from liquid fuel reciprocating engines shall be determined using Method 8178 D2 of the International Organization of Standardization. 	
	c. Testing shall be conducted at the full design load of the emergency engine.	
	MassDEP may require emission or other testing to assure compliance with the emission limitations or fuel requirements.	
	25) Monitor facility operations such that compliance with the restrictions and emission	
-	limitations/standards contained in Table 3 of this Permit can be determined in accordance with 310	
	CMR 7.00 Appendix C(9)(b)2.	
	26) Conduct Emissions Compliance Testing (Stack Testing), in accordance with 310 CMR 7.13, 310 CMR 7.19(13)(c), 40 CFR Part 60, Appendix A (Method 7E for NOx, Methods 1 to 5 for PM, Method 3A for Oxygen (O_2)), and Conditional Approval MBR-91-COM-017B, dated June 30, 1993,	
	or any other testing if and when requested by MassDEP or EPA.	
	27) In accordance with 310 CMR 7.00: Appendix C(9)(b)2., monitor sulfur content of each new shipment of No.2 Fuel Oil received. Compliance with sulfur content can be demonstrated through testing or maintaining a shipping receipt from the fuel supplier. The shipment certification or testing of sulfur content of No.2 Fuel Oil shall be in accordance with the applicable American Society for Testing Materials (ASTM) test methods or any other method approved by MassDEP and EPA.	
	28) Opacity shall be determined in accordance with EPA Test Method 9, as specified in 40 CFR Part 60, Appendix A, if and when requested by MassDEP or EPA. This method shall also apply to any detached plumes.	
	29) Monitor operations such that information may be compiled for the annual preparation of a Source Registration/Emission Statement Form as required by 310 CMR 7.12.	
	30) In accordance with 310 CMR 7.71(1) and Appendix C(9) establish and maintain data systems or record keeping practices (e.g. fuel use records, SF6 usage documentation, Continuous Emissions	
	Monitoring System) for greenhouse gas emissions to ensure compliance with the reporting provisions of M.G.L. c. 21N, the Climate Protection and Green Economy Act, St. 2008, c. 298 §6. (state only)	

	Table 5
EMISSION	RECORD KEEPING REQUIREMENTS
UNIT	
EU4, EU5	1) Maintain monthly reports that list No.2 transportation diesel fuel oil ($\leq 0.05\%$ S by weight) usage
	as fired to verify compliance with the fuel restriction as referenced in Conditional Approval MBR-
	91-COM-017B, dated June 30, 1993.
	2) Maintain records, for a period of the five most recent years, of the amounts of each fuel combusted
	in each emission unit (EU4 and EU5) each month as provided in 40 CFR 60.48c(g)(2) incorporated
	herein by reference.
EU6	3) Monitor and record No.2 transportation diesel fuel oil ($\leq 0.003\%$ S by weight) usage as fired to
	verify compliance with the fuel restriction as referenced in Conditional Approval MBR-04-COM-
	005, dated June 16, 2004.
	4) Maintain records, for a period of the five most recent years, of the amounts of each fuel combusted in EUG and month as provided in 40 CEP 60.48 $\alpha(g)(2)$ incorrected herein by reference
	in EU6 each month as provided in 40 CFR 60.48c(g)(2) incorporated herein by reference. 5) Keep ongoing records for the boiler that include the amount of time the subject boiler is
	operated and fuel purchases receipts and fuel usage logs which reflect actual fuel usage on a
	weekly basis. Said fuel usage logs shall also contain: monthly totals of fuel usage and resulting
	emissions from each type of fuel burned, the actual sulfur content of the fuel oil used, and the total
	fuel usage and resulting emissions from each type of fuel burned for the previous twelve months,
	as referenced in Approval MBR-04-COM-005, Proviso No. B.4.f).
	6) Maintain adequate records on site, which document the number of gallons of No. 2 fuel oil that this
	EU has utilized in each twelve month rolling calendar period, as referenced in Approval MBR-04-
	COM-005, Proviso No. B.4.g).
	7) As referenced in Approval MBR-04-COM-005, record when this EU switches to No. 2 fuel oil,
	including the date and time of the fuel switch, the duration of the fuel switch, the amount of No. 2 fuel
	oil consumed during each fuel switch, and the date and time for return to natural gas firing. 8) Documentation from the equipment manufacturer shall be maintained on site that the subject
	boiler and its appurtenances as designed and installed shall comply with the pounds per million Btu
	emission limits in Table 3 of this Permit when operated in accordance with the manufacturer's
	instructions as referenced in Approval MBR-04-COM-005, Proviso No. B.4.d).
EU1, EU2,	9) In accordance with 310 CMR 7.04(4)(a), maintain results of fuel utilization facility inspection,
EU3, EU4,	maintenance, and testing and the date upon which it was performed.
EU5, EU6,	
EU13, EU14,	
EU20, EU22,	
EU24, EU25,	
EU26, EU27,	
EU29, EU30,	
EU31, EU66,	
EU67, EU107, EU108	
EU107, EU108 EU1, EU2,	10) Maintain records of smoke density equipment data in accordance with 310 CMR 7.04(2). For
EU1, EU2, EU3, EU4,	each period of excess opacity, the Permittee shall record the duration, cause, the response taken, and
EU5, EU4, EU5, EU6	the amount of excess opacity.
200, 200	11) Maintain records of all monitoring data relevant to 310 CMR 7.19(6)(b), including but not
	limited to, tune-ups, adjustments, and verification of set points.
	12) Maintain a copy of the Notification of Compliance Status that was submitted in accordance with
	40 CFR 63.11225(a)(4) and in accordance with §63.9(h). In addition to the information required in
	§63.9(h)(2), your notification must include the following certification of compliance, and signed by a
	responsible official: "This facility complies with the requirements in §63.11214 to conduct an initial
	tune-up of the boiler." and "This facility has had an energy assessment performed according to
	§63.11214(c)".

Table 5	
EMISSION UNIT	RECORD KEEPING REQUIREMENTS
EU4, EU5, EU6	 13) In accordance with 40 CFR 60.48c(b), maintain records of COMS data, performance tests under 40 CFR 60.8, any subsequent performance tests as requested by EPA, and performance evaluations of the COMS using applicable Performance Specifications of 40 CFR 60, Appendix B. 14) In accordance with 40 CFR 60.48c(e)(11) and 40 CFR 60.48c(f)(1), maintain records of fuel supplier certifications to demonstrate compliance with the SO₂ emission limits or fuel oil sulfur limits under 40 CFR 60.42c(d) and 40 CFR 60.42c(i). Said certifications shall include the name of the oil supplier and a statement from the oil supplier that the oil complies with the specifications under the definition of distillate oil in 40 CFR 60.41c; more specifically, that the oil complies with specifications for Fuel Oil No. 1 or 2, as defined by the American Society for Testing and Materials in ASTM D396-78, 89, 90, 92, 96, and 98 "Standard Specification for Fuel Oils" (incorporated herein by reference-see 40 CFR 60.17). Comply with applicable record keeping requirements in 40 CFR 60.48c(e)2 through (10). 15) In accordance with 40 CFR 60.48c(g)(2), maintain records of the amounts of each fuel combusted.
EU1, EU2, EU3, EU4, EU5, EU6, EU13, EU14, EU22, EU29, EU30, EU31, EU66, EU67, EU100, EU101, EU102, EU102, EU103, EU104, EU105, EU106, EU107, EU108	 16) In accordance with 40 CFR Part 63.11223(b)(6), maintain on-site reports containing the following: (i) the concentrations of the CO in the effluent stream in parts per million, by volume, and oxygen in volume percent, measured before and after the tune-up of the boiler (ii) a description of any corrective actions taken as a part of the tune-up of the boiler, and (iii) the type and amount of fuel used over the 12 months prior to the tune-up of the boiler, but only if the unit was physically and legally capable of using more than one type of fuel during that period. 17) In accordance with 40 CFR §63.11225(b), maintain adequate records so that the Permittee shall prepare an applicable compliance report including (1) company name and address, (2) statement by a responsible official, with the official's name, title, phone number, e-mail address, and signature, certifying the truth, accuracy and completeness of the notification and a statement of whether the source has complied with all the relevant standards and other requirements during the reporting period, including a description of deviations, the time periods during which the deviations occurred, and the corrective actions taken. Maintain adequate records such that the first Compliance Certification Report shall be prepared by March 1, 2015 with subsequent reports prepared by March 1st of each applicable year.
	 18) In accordance with 40 CFR Part 63.11225(c)(1) and as required in §63.10(b)(2)(xiv), keep a copy of each notification and report that you submitted to comply with this subpart and all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted. 19) In accordance with 40 CFR Part 63.11225(c)(2)(i), keep records to document conformance with the work practices, emission reduction measures, and management practices required by §63.11214. Records must identify each boiler, the date of tune-up, the procedures followed for
	tune-up, and the manufacturer's specifications to which the boiler was tuned. 20) In accordance with 40 CFR Part 63.11225(c)(4), keep records of the occurrence and duration of each malfunction of the boiler, or of the associated air pollution control and monitoring equipment.

	Table 5
EMISSION UNIT	RECORD KEEPING REQUIREMENTS
EU1, EU2, EU3, EU4, EU5, EU6, EU13, EU14, EU22, EU29, EU30, EU31, EU66, EU67, EU100,	 21) In accordance with 40 CFR Part 63.11225(c)(5), keep records of actions taken during periods of malfunction to minimize emissions in accordance with the general duty to minimize emissions in §63.11205(a), including corrective actions to restore the malfunctioning boiler, air pollution control, or monitoring equipment to its normal or usual manner of operation. 22) Maintain records of the performance tune-up required by 40 CFR 63.11214(b), such that compliance with this regulation may be demonstrated and the required reporting may be submitted.
EU101, EU102, EU103, EU104, EU105, EU106, EU107, EU108	 23) In accordance with 40 CFR 63.11223(a), keep records as required in §63.11225(c). 24) In accordance with 40 CFR 63.11225(d), your records must be in a form suitable and readily available for expeditious review, according to §63.10(b)(1). As specified in §63.10(b)(1), you must keep each record for 5 years following the date of each recorded action.
EU9, EU11, EU12, EU15, EU16, EU17, EU18, EU19, EU32, EU33, EU34, EU35, EU52	25) In accordance with 310 CMR 7.03(10), maintain records on the consumption of diesel fuel oil (\leq 0.0015% S by weight) and the hours of operation for each EU to verify compliance with the restriction of less than 300 hours per twelve month period.
EU36, EU50, EU51, EU53, EU54, EU55, EU56	 26) In accordance with 310 CMR 7.26(42), monitor the consumption of diesel fuel oil (≤ 0.0015% S by weight) and the hours of operation for each EU to verify compliance with the restriction of less than 300 hours per twelve month period. 27) In accordance with 310 CMR 7.26(42)(f), maintain the following records;
	 Information on equipment type, make and model, and rated power output; and A monthly log of hours of operation, fuel type, heating value and sulfur content for fuel oil. A monthly calculation of the total hours operated in the previous 12 months; and Purchase orders, invoices, and other documentation to substantiate information in the monthly log; and
	4. Copies of certificates and documents from the manufacturer related to certificates. Such records shall be maintained on site or for remote locations, at the closest facility where records can be maintained and shall be made available to MassDEP or its designee upon request. The owner or operator shall certify that records are accurate and true in accordance with 310 CMR 7.01(2)(a) through (c). These records may be stored electronically as considered acceptable by MassDEP.
Facility-wide	 28) In accordance with 310 CMR 7.00: Appendix C(10)(b), maintain records of all monitoring data and supporting information required by this Operating Permit on site for five (5) years from the date of the monitoring sample, measurement, report or initial Operating Permit Application. 29) Pursuant to MassDEP's authority through 310 CMR 7.00: Appendix C(9)(b)2., maintain records to verify that compliance with the emission limitations in Table 3 of this Permit is maintained. 30) The results of the required inspection, maintenance, and testing and the date upon which it was
	performed shall be recorded and posted conspicuously on or near each fuel utilization facility having an energy input capacity of \geq 3 MMBtu/hr, as provided in 310 CMR 7.04(4)(a) incorporated herein by reference. Said records shall be maintained on site for a period of the five most recent years. Note: 310 CMR 7.04(4)(a) does not apply to emergency engines.

	Table 5	
EMISSION UNIT	RECORD KEEPING REQUIREMENTS	
Facility-wide	31) Maintain the test results of any Emissions Compliance Testing (Stack Testing) performed in accordance with 310 CMR 7.13, 310 CMR 7.19(13)(c), and 40 CFR Part 60, Appendix A (Method 7E for NOx, Methods 1 to 5 for PM, Method 3A for Oxygen (O_2)) or of any other testing required by MassDEP or EPA.	
	 32) Maintain No.2 Fuel Oil testing results and/or purchase receipts in order to demonstrate compliance with fuel sulfur content requirements as provided in 310 CMR 7.05(1)(a). 33) Maintain records of any EPA Test Method 9 opacity determinations performed according to 40 CFR Part 60, Appendix A, including detached plumes, required by MassDEP or EPA. 34) Maintain records of facility operations such that information may be reported as required for compliance with 310 CMR 7.12. Keep copies of all information supplied to MassDEP pursuant to 310 CMR 7.12 on site for five (5) years after the date the report is submitted. 35) In accordance with 310 CMR 7.71(6)b. and c. retain at the facility for five years and make available to the Department upon request copies of the documentation of the methodology and data used to quantify emission. (state only) 	

	Table 6	
EMISSION UNIT	REPORTING REQUIREMENTS	
EU4, EU5	1) Submit to MassDEP an annual written report by January 15th of the year following the year of record, which states the usage of No.2 transportation diesel fuel oil as referenced in Conditional Approval MBR-91-COM-017B, dated June 30, 1993.	
EU4, EU5, EU6	2) In accordance with 40 CFR 60.48c(b), an affected facility subject to the opacity standards under 40 CFR 60.43c(c) and 40 CFR 60.43c(d) shall submit to EPA the COMS performance data from the initial performance test as required under 40 CFR 60.8 and any subsequent performance tests as requested by EPA, including performance evaluations of the COMS using applicable Performance Specifications of 40 CFR 60, Appendix B.	
	 3) In accordance with 40 CFR 60.48c(d), an affected facility subject to the SO₂ emission limits or fuel oil sulfur limits under 40 CFR 60.42c(d) and 40 CFR 60.42c(i) shall submit to EPA and to MassDEP semi-annual reports in accordance with 40 CFR 60.48(j). Each report shall be postmarked by the 30th day following the end of the reporting period. The report shall contain calendar dates covered in the reporting period as per 40 CFR 60.48c(e)(1) and records of fuel supplier certifications as per 40 CFR 60.48c(e)(11) and 40 CFR 60.48c(f)(1). In addition to records of fuel supplier certifications, the semi-annual reports shall include a certified statement signed by the responsible official of the affected facility that the records of fuel supplier certifications submitted represent all of the fuel combusted during the previous six month period. Said certifically, that the oil complies with specifications for Fuel Oil No. 1 or 2, as defined by the American Society for Testing and Materials in ASTM D396-78, 89, 90, 92, 96, 98, "Standard Specification for Fuel Oils" (incorporated herein by reference-see 40 CFR 60.17). 	
EU1, EU2, EU3, EU4,	5) In accordance with 310 CMR 7.19(13)(d)9., submit compliance records within ten (10) days of written request by MassDEP or EPA.	
EU5, EU6	6) Submit Emissions Compliance Testing (Stack Testing) reports in accordance with 310 CMR 7.19(13)(c).	

Table 6	
EMISSION UNIT	REPORTING REQUIREMENTS
EU5, EU6, EU13, EU14, EU22, EU29,	7) In accordance with 40 CFR 63.11214(b), submit a signed statement in the Notification of Compliance Status report that indicates that you conducted a tune-up of each boiler. NOCS shall be submitted electronically using the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's central data exchange (<u>www.epa.gov/cdx</u>) under Section 63.11225(a)(4)(vi).
EU100, EU101, EU102, EU103, EU104,	8) In accordance with 40 CFR 63.11225(a)(2), as specified in §63.9(b)(2), submit the Initial Notification by January 20, 2014 or within 120 days after the source becomes subject to the standard. In accordance with 40 CFR 63.9(b)(2), the notification shall include the following information: (i) the name and address of the owner or operator; (ii) the address (i.e., physical location) of the affected source; (iii) an identification of the relevant standard, or other requirement, that is the basis of the notification and the source's compliance date; (iv) a brief description of the nature, size, design and method of operation of the source and an identification of the types of hazardous air pollutants
EU107,	 emitted; and (v) a statement of whether the affected source is a major source or area source. 9) In accordance with 40 CFR 63.11225(a)(4), you must submit the Notification of Compliance Status in accordance with \$63.0(b) no later than July 10, 2012. In addition to the information
	Status in accordance with §63.9(h) no later than July 19, 2012. In addition to the information required in §63.9(h)(2), your notification must include the following certification of compliance, and signed by a responsible official: "This facility complies with the requirements in §63.11214 to conduct an initial tune-up of the boiler." And, for any energy assessment applicable emission unit, notification must be given no later than July 19, 2014 and the notification must include the following certification of compliance, and signed by a responsible official: "This facility has had an energy assessment performed according to §63.11214(c).". NOCS shall be submitted electronically using the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's central data exchange (www.epa.gov/cdx) under Section 63.11225(a)(4)(vi).
	10) In accordance with 40 CFR 63.11223(b)(6), submit, if requested by the Administrator, a report containing the following information; (i) the concentrations of CO in the effluent stream in parts per million, by volume, and oxygen in volume percent, measured before and after the tune-up of the boiler, (ii) a description of any corrective actions taken as a part of the tune-up of each boiler, and (iii) the type and amount of fuel used over the 12 months prior to the tune-up of the boiler, but only if the unit was physically and legally capable of using more than one type of fuel during that period.
	11) In accordance with 40 CFR 63.11225(g), if you intend to switch fuels, and this fuel switch may result in the applicability of a different subcategory or a switch out of subpart JJJJJJ due to a switch to 100 percent natural gas, you must provide 30 days prior notice of the date upon which you will switch fuels. The notification must identify: (1) the name of the owner or operator of the affected source, the location of the source, the boiler(s) that have switched fuels, were physically changed, or took a permit limit, and the date of the notice. The date upon which the fuel switch, physical change, or permit limit occurred.
	12) In accordance with 40 CFR §63.11225(b), submit to the delegated authority upon request, a compliance report including (1) company name and address, (2) statement by a responsible official, with the official's name, title, phone number, e-mail address, and signature, certifying the truth, accuracy and completeness of the notification and a statement of whether the source has complied with all the relevant standards and other requirements of this subpart, and (3) if the source experiences any deviations from the applicable requirements during the reporting period, including a description of deviations, the time periods during which the deviations occurred, and the corrective actions taken. Prepare the first Compliance Certification Report by March 1, 2015 with subsequent reports prepared by March 1 st of each applicable year.

Table 6	
EMISSION	REPORTING REQUIREMENTS
UNIT	$12) 0 1 \cdot (\cdot, 0) = \mathbf{D} \cdot (\cdot, \cdot) \cdot \mathbf{D} \cdot (\cdot, \cdot) \cdot \mathbf{C} \cdot (\cdot, \cdot) \cdot \mathbf{C} \cdot (\cdot, \cdot) \cdot \mathbf{M} = \mathbf{D} \cdot \mathbf{D} \cdot (\cdot, \cdot) \cdot \mathbf{D} \cdot (\cdot, \cdot) \cdot \mathbf{C} \cdot (\cdot, \cdot) \cdot \mathbf{C} \cdot (\cdot, \cdot) \cdot \mathbf{M} = \mathbf{D} \cdot \mathbf{D} \cdot (\cdot, \cdot) \cdot \mathbf{M} = \mathbf{D} \cdot \mathbf{D} \cdot (\cdot, \cdot) \cdot \mathbf{M} = \mathbf{D} \cdot \mathbf{D} \cdot (\cdot, \cdot) \cdot \mathbf{M} = \mathbf{D} \cdot \mathbf{D} \cdot (\cdot, \cdot) \cdot \mathbf{M} = \mathbf{D} \cdot \mathbf{D} \cdot (\cdot, \cdot) \cdot \mathbf{M} = \mathbf{D} \cdot \mathbf{D} \cdot (\cdot, \cdot) \cdot \mathbf{M} = \mathbf{D} \cdot \mathbf{D} \cdot (\cdot, \cdot) \cdot \mathbf{M} = \mathbf{D} \cdot \mathbf{D} \cdot \mathbf{D} \cdot \mathbf{D} \cdot \mathbf{D} \cdot \mathbf{M} = \mathbf{D} \cdot \mathbf{D} \cdot \mathbf{D} \cdot \mathbf{D} \cdot \mathbf{D} \cdot \mathbf{D} \cdot \mathbf{D} = \mathbf{D} \cdot \mathbf{D} = \mathbf{D} \cdot $
Facility-wide	13) Submit a Source Registration/Emission Statement form to MassDEP on an annual basis as required by 310 CMR 7.12.
	14) In accordance with 310 CMR 7.71(5), by April 15 th of each year report emissions of greenhouse
	gases from stationary emissions sources including, but not limited to, emissions from factory stacks,
	manufacturing processes and vents, fugitive emissions, and other process emissions; and owned or
	leased motor vehicles when stationary source greenhouse gas emissions are greater than 5,000 short
	ton CO2e. Report greenhouse gas emission electronically in a format that can be accommodated by
	the registry. (state only)
	15) In accordance with 310 CMR 7.71(6), certify greenhouse gas emissions reports using a form provided by the Department or the registry. (state only)
	provided by the Department of the registry. (state only)
	16) In accordance with 310 CMR 7.71(7), by December 31 st of the applicable year submit to the
	Department documentation of triennial verification of the greenhouse gas emissions reports. (state
	only)
	17) Upon MassDEP's request, any record relevant to the Operating Permit or to the emissions of any
	air contaminant from the facility shall be submitted to MassDEP within 30 days of the request by MassDEP or within a longer time period if approved by MassDEP, pursuant to 310 CMR 7.00
	Appendix C(10)(a) incorporated herein by reference.
	18) Submit by January 30 and July 30 for the previous six months respectively, a Semi-Annual
	Monitoring Summary and Certification with all monitoring data and related supporting information
	to MassDEP as required in 310 CMR 7.00 Appendix C(10)(c).
	19) Submit Annual Compliance report to MassDEP and EPA by January 30 of each year and as
	required in 310 CMR 7.00 Appendix C(10)(c).
	20) Promptly report to MassDEP all instances of deviations from permit requirements (including but
	not limited to testing for efficient operation, fuel sulfur and fuel ash content emission limitations/standards, Standard Operating and Maintenance Procedures) by telephone or fax, within
	three days of discovery of such deviation, as provided in 310 CMR 7.00: Appendix C(10)(f) (See
	General Condition 25).
	21) All required reports must be certified by a responsible official as provided in 310 CMR 7.00:
	Appendix C(10)(h).
<u> </u>	

C. GENERAL APPLICABLE REQUIREMENTS

The Permittee shall comply with all generally applicable requirements contained in 310 CMR 7.00 et. seq. and 310 CMR 8.00 et. seq., when subject.

D. REQUIREMENTS NOT CURRENTLY APPLICABLE

The Permittee is currently not subject to the following requirements:

Table 7	
Regulation	Reason
40 CFR Part 64	Not Applicable

5. <u>SPECIAL TERMS AND CONDITIONS</u>

The Permittee is subject to the following special terms and conditions that are not contained in Tables 3, 4, 5, and 6:

Table 8.	
	Special Terms and Conditions
EU1, EU2, EU3, EU4, EU5, EU6, EU13, EU14, EU22, EU29, EU30, EU31, EU66, EU67, EU100, EU101, EU102, EU103, EU104, EU105, EU106, EU107, EU108	1) Emission units are subject to the requirements of 40 CFR 63.1-16, Subpart A, "General Provisions" as indicated in Table"8" to Subpart JJJJJJ of 40 CFR 63. Compliance with all applicable provisions therein is required.
	 2) In accordance with 40 CFR 60.4211(c), if the Permittee is an owner or operator of a 2007 model year and later stationary compression ignition internal combustion engine and must comply with the emission standards specified in §60.4205(b), you must comply by purchasing an engine certified to the emission standards in §60.4205(b) for the same model year and maximum engine power. The engine must be installed and configured according to the manufacturer's emission-related specifications. 3) In accordance with 40 CFR 60.4211(a), the Permittee must operate and maintain each stationary compression ignition internal combustion engine according to the manufacturer's emission-related written instructions; change only those emission-related settings that are permitted by the manufacturer; and meet the requirements of 40 CFR parts 89, 94 and /or 1068, as they apply to you. 4) Pursuant to 40 CFR 63.6590(c), meet the requirements of 40 CFR 63 Subpart ZZZZ by meeting the requirements of 40 CFR 60 Subpart IIII, for compression ignition engines. No further requirements apply for such engines under 40 CFR 63 Subpart ZZZZ.
EU60	5) Pursuant to 40 CFR 63.6590(c), meet the requirements of 40 CFR 63 Subpart ZZZZ by meeting the requirements of 40 CFR 60 Subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under 40 CFR 63 Subpart ZZZZ.
EU6	 6) That the Permittee shall restrict air emissions from Boiler No. 6 (EU6) to less than or equal to 1.6 tons of NOx per month and 3.34 tons of NOx per twelve month rolling calendar period in accordance with Approval MBR-04-COM-005. 7) In order to verify that the Permittee does not exceed the emission limits listed in Condition No. 6 above, the Permittee shall maintain on-site adequate monthly records to document the above. These records shall list the actual amount of fuel used per month and the actual NOx emissions for the previous 12 months (the total of the current month's emissions plus the emissions from the 11 months preceding the current month)., Records of the above emission rates shall be maintained on-site for at least the five (5) most recent years, and shall be made available to MassDEP personnel upon request (See attached On-Site Record Keeping Form for an example of a format that is acceptable to MassDEP. An electronic version of this form in Microsoft Excel format can be obtained at http://www.mass.gov/dep/air/approvals/aqforms.htm) in accordance with Approval MBR-04-COM-005.

Table	8
	Ο.

	S	pecial Terms and Condi	itions		
8) That the Permittee shall install, calibrate, maintain, and operate opacity monitoring/recording				itoring/recording	
	equipment and alarms to service Boiler No. 6 (EU6) in sufficient manner to ensure continuous and				
EU6	accurate operation at all times in accordance with Approval MBR-04-COM-005.				
EUo	9) That the Permittee shall post copies of the Conditional Approval letter governing EU6 adjacent to				
	EU6 in accordance with Approval MBR-04-COM-005.				
	10) A copy of the Standard Operating and Maintenance Procedures for EU6 shall be located at or				
	nearby the subject equipment in accordance with Approval MBR-04-COM-005. 11) That the Permittee shall comply with the requirements of 40 CFR Part 60, Subpart Dc. Subpart				
EU4, EU5, EU6	60.48c, which requires that the owner or operator of boilers such as EU6 must keep records and submit				
	certain information to EPA New England Region I, 5 Post Office Square, Suite 100, Mail Code:				
	OES04-2, Boston MA 02109 - 3912 in accordance with Approval MBR-04-COM-005.				
Facility-wide	12) That should any nuisance condition(s) be generated by the operation of this facility, then appropriate				
	steps shall immediately be taken by the Permittee to abate said nuisance condition(s) (State Only 310				
	CMR 7.01(1)).				
	13) Any net NOx emissions increase occurring over a period of five consecutive calendar years which				
	equates to 25 or more tons of NOx shall become subject to Non-attainment Review, as per the				
	requirements of 310 CMR 7.00: Appendix A in accordance with Approval MBR-04-COM-005. 14) Per data as supplied through the Permittee's Operating Permit Application (MBR-95-OPP-095,				
	Transmittal No. 116190) and its Operating Permit Renewal Application (MBR-95-OPP-095R,				
	Transmittal No. W059861), the following EUs shall continue to emit products of combustion through				
	the following flue with the following parameters:				
		STACK HEIGHT	STACK EXIT		
	EMISSION UNIT	(Feet)	DIAMETER	STACK	
			(Feet)	MATERIAL	
	EU1, EU2, EU3, EU4,				
	EU5, EU6	138	5	Refractory Lined	
				the requirements of 310	
	CMR 7.16, U Reduction		nuter Vehicle Use. The F	Permittee shall continue to	
	comply with 310 CMR 7.		· · · · · · · · · · · · · · · · · · ·	11.1°	
	16) The Permittee shall a records at all reasonable t				
	obtaining data, and review				
	obuining data, and feview	ing records in accordance	with reprovativities -04-C		

6. <u>ALTERNATIVE OPERATING SCENARIOS</u>

Table 9.
Alternative Operating Scenarios
The Permittee did not request alternative operating scenarios in its Operating Permit application.

7. <u>EMISSIONS TRADING</u>

Table 10.
Emissions Trading
(a) Intra-facility emissions trading
The Permittee did not request intra-facility emissions trading in its Operating Permit application.
(b) Inter-facility emissions trading
The Permittee did not request inter-facility emissions trading in its Operating Permit application.

8. <u>COMPLIANCE SCHEDULE</u>

The Permittee has indicated that the facility is in compliance and shall remain in compliance with the applicable requirements contained in Sections 4 and 5. In addition, the Permittee shall comply with any applicable requirements that become effective during the permit term.

GENERAL CONDITIONS FOR OPERATING PERMIT

9. <u>FEES</u>

The Permittee has paid the Permit application processing fee and shall pay the annual compliance fee in accordance with the fee schedule pursuant to 310 CMR 4.00.

10. <u>COMPLIANCE CERTIFICATION</u>

All documents submitted to MassDEP shall contain certification by the responsible official of truth, accuracy, and completeness. Such certification shall be in compliance with 310 CMR 7.01 (2) and contain the following language:

"I certify that I have personally examined the foregoing and am familiar with the information contained in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possible fines and imprisonment."

The "Operating Permit Reporting Kit" contains instructions, and the Annual Compliance Report and Certification and the Semi-Annual Monitoring Summary Report and Certification. The "Operating Permit Reporting Kit" is available to the Permittee via MassDEP's web site, http://www.mass.gov/dep/air/approvals/aqforms.htm. (a) Annual Compliance Report and Certification

The Responsible Official shall certify, annually for the calendar year, that the facility is in compliance with the requirements of this Permit. The report shall be postmarked or delivered by January 30 to MassDEP and to the Regional Administrator, U.S. Environmental Protection Agency - New England Region. The report shall be submitted in compliance with the submission requirements below.

The compliance certification and report shall describe:

- i. the terms and conditions of the Permit that are the basis of the certification;
- ii. the current compliance status and whether compliance was continuous or intermittent during the reporting period;
- iii. the methods used for determining compliance, including a description of the monitoring, record keeping, and reporting requirements and test methods; and
- iv. any additional information required by MassDEP to determine the compliance status of the source.

(b) Semi-Annual Monitoring Summary Report and Certification

The Responsible Official shall certify, semi-annually on the calendar year, that the facility is in compliance with the requirements of this Permit. The report shall be postmarked or delivered by January 30 and July 30 to MassDEP. The report shall be submitted in compliance with the submission requirements below.

The compliance certification and report shall describe:

- i. the terms and conditions of the Permit that are the basis of the certification;
- ii. the current compliance status during the reporting period;
- iii. the methods used for determining compliance, including a description of the monitoring, record keeping, and reporting requirements and test methods;
- iv. whether there were any deviations during the reporting period;
- v. if there are any outstanding deviations at the time of reporting, and the Corrective Action Plan to remedy said deviation;
- vi. whether deviations in the reporting period were previously reported;
- vii. if there are any outstanding deviations at the time of reporting, the proposed date of return to compliance;
- viii. if the deviations in the reporting period have returned to compliance and date of such return to compliance; and
- ix. any additional information required by MassDEP to determine the compliance status of the source.

<u>11. NONCOMPLIANCE</u>

Any noncompliance with a Permit condition constitutes a violation of 310 CMR 7.00: Appendix C and the Clean Air Act, and is grounds for enforcement action, for Permit termination or revocation, or for denial of an Operating Permit Renewal application by MassDEP and/or EPA. Noncompliance may also be grounds for assessment of administrative or civil penalties under M.G.L. c.21A, §16 and 310 CMR 5.00; and civil penalties under M.G.L. c.111, §142A and 142B. This Permit does not relieve the Permittee from the obligation to comply with any other provisions of 310 CMR 7.00 or the Act, or to obtain any other necessary authorizations from other governmental agencies, or to comply with all other applicable Federal, State, or Local rules and regulations, not addressed in this Permit.

12. PERMIT SHIELD

(a) This facility has a permit shield provided that it operates in compliance with the terms and conditions of this Permit. Compliance with the terms and conditions of this Permit shall be deemed compliance with all applicable requirements specifically identified in Sections 4, 5, 6, and 7, for the emission units as described in the Permittee's application and as identified in this Permit.

Where there is a conflict between the terms and conditions of this Permit and any earlier Approval or Permit, the terms and conditions of this Permit control.

(b) MassDEP has determined that the Permittee is not currently subject to the requirements listed in Section 4, Table 7.

(c) Nothing in this Permit shall alter or affect the following:

- (i) the liability of the source for any violation of applicable requirements prior to or at the time of Permit issuance.
- (ii) the applicable requirements of the Acid Rain Program, consistent with 42 U.S.C. §7401, §408(a); or
- (iii) the ability of EPA to obtain information under 42 U.S.C. §7401, §114 or §303 of the Act.

13. <u>ENFORCEMENT</u>

The following regulations found at 310 CMR 7.02(8)(h) Table 6 for wood fuel, 7.02(8)(i), 7.04(9), 7.05(8), 7.09 (odor), 7.10 (noise), 7.18(1)(b), 7.21, 7.22, 7.70, and any condition(s) designated as "state only" are not federally enforceable because they are not required under the Act or under any of its applicable requirements. These regulations and conditions are not enforceable by the EPA. Citizens may seek equitable or declaratory relief to enforce these regulations and conditions pursuant to Massachusetts General Law Chapter 214, Section 7A.

All other terms and conditions contained in this Permit, including any provisions designed to limit a facility's potential to emit, are enforceable by MassDEP, EPA and citizens as defined under the Act.

A Permittee shall not claim as a defense in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Permit.

14. <u>PERMIT TERM</u>

This Permit shall expire on the date specified on the cover page of this Permit, which shall not be later than the date 5 years after issuance of this Permit.

Permit expiration terminates the Permittee's right to operate the facility's emission units, control equipment or associated equipment covered by this Permit, unless a timely and complete renewal application is submitted at least 6 months before the expiration date.

15. <u>PERMIT RENEWAL</u>

Upon MassDEP's receipt of a complete and timely application for renewal, this facility may continue to operate subject to final action by MassDEP on the renewal application.

In the event MassDEP has not taken final action on the Operating Permit Renewal application prior to this Permit's expiration date, this Permit shall remain in effect until MassDEP takes final action on the renewal application, provided that a timely and complete Renewal application has been submitted in accordance with 310 CMR 7.00: Appendix C(13).

16. <u>REOPENING FOR CAUSE</u>

This Permit may be modified, revoked, reopened, and reissued, or terminated for cause by MassDEP and/or EPA. The responsible official of the facility may request that MassDEP terminate the facility's Operating Permit for cause. MassDEP will reopen and amend this Permit in accordance with the conditions and procedures under 310 CMR 7.00: Appendix C(14).

The filing of a request by the Permittee for an Operating Permit revision, revocation and reissuance, or termination, or a notification of a planned change or anticipated noncompliance does not stay any Operating Permit condition.

17. DUTY TO PROVIDE INFORMATION

Upon MassDEP's written request, the Permittee shall furnish, within a reasonable time, any information necessary for determining whether cause exists for modifying, revoking and reissuing, or terminating the Permit, or to determine compliance with the Permit. Upon request, the Permittee shall furnish to MassDEP copies of records that the Permittee is required to retain by this Permit.

18. <u>DUTY TO SUPPLEMENT</u>

The Permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the Permit application, shall promptly submit such supplementary facts or corrected information. The Permittee shall also provide additional information as necessary to address any requirements that become applicable to the facility after the date a complete renewal application was submitted but prior to release of a Final Permit.

The Permittee shall promptly, on discovery, report to MassDEP a material error or omission in any records, reports, plans, or other documents previously provided to MassDEP.

19. TRANSFER OF OWNERSHIP OR OPERATION

This Permit is not transferable by the Permittee unless done in accordance with 310 CMR 7.00: Appendix C(8)(a). A change in ownership or operation control is considered an administrative permit amendment if no other change in the Permit is necessary and provided that a written agreement containing a specific date for transfer of Permit responsibility, coverage and liability between current and new Permittee, has been submitted to MassDEP.

20. <u>PROPERTY RIGHTS</u>

This Permit does not convey any property rights of any sort, or any exclusive privilege.

21. **INSPECTION AND ENTRY**

Upon presentation of credentials and other documents as may be required by law, the Permittee shall allow authorized representatives of MassDEP, and EPA to perform the following:

- (a) enter upon the Permittee's premises where an Operating Permit source activity is located or emissions-related activity is conducted, or where records must be kept under the conditions of this Permit;
- (b) have access to and copy, at reasonable times, any records that must be kept under the conditions of this Permit;
- (c) inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Permit; and
- (d) sample or monitor at reasonable times any substances or parameters for the purpose of assuring compliance with the Operating Permit or applicable requirements as per 310 CMR 7.00 Appendix C(3)(g)(12).

22. <u>PERMIT AVAILABILITY</u>

The Permittee shall have available at the facility, at all times, a copy of the materials listed under 310 CMR 7.00: Appendix C(10)(e) and shall provide a copy of the Permit, including any amendments or attachments thereto, upon request by MassDEP or EPA.

23. <u>SEVERABILITY CLAUSE</u>

The provisions of this Permit are severable, and if any provision of this Permit, or the application of any provision of this Permit to any circumstances, is held invalid, the application of such provision to other circumstances, and the remainder of this Permit, shall not be affected thereby.

24. <u>EMERGENCY CONDITIONS</u>

The Permittee shall be shielded from enforcement action brought for noncompliance with technology based¹ emission limitations specified in this Permit as a result of an emergency². In order to use emergency as an affirmative defense to an action brought for noncompliance, the Permittee shall demonstrate the affirmative defense through properly signed, contemporaneous operating logs, or other relevant evidence that:

(a) an emergency occurred and that the Permittee can identify the cause(s) of the emergency;

(b) the permitted facility was at the time being properly operated;

(c) during the period of the emergency, the Permittee took all reasonable steps as expeditiously as possible, to minimize levels of emissions that exceeded the emissions standards, or other requirements in this Permit; and

(d) the Permittee submitted notice of the emergency to MassDEP within two (2) business days of the time when emission limitations were exceeded due to the emergency. This notice must contain a description of the emergency, any steps taken to mitigate emission, and corrective actions taken.

If an emergency episode requires immediate notification to the Bureau of Waste Site Cleanup/Emergency Response, immediate notification to the appropriate parties should be made as required by law.

¹ Technology based emission limits are those established on the basis of emission reductions achievable with various control measures or process changes (e.g., a new source performance standard) rather than those established to attain health based air quality standards.

² An "emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation would require immediate corrective action to restore normal operation, and that causes the source to exceed a technology based limitation under the permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operations, operator error or decision to keep operating despite knowledge of any of these things.

25. <u>PERMIT DEVIATION</u>

Deviations are instances where any Permit condition is violated and not reported as an emergency pursuant to section 24 of this Permit. Reporting a Permit deviation is not an affirmative defense for action brought for noncompliance. Any reporting requirements listed in Table 6. of this Operating Permit shall supersede the following deviation reporting requirements, if applicable.

The Permittee shall report to MassDEP's Regional Bureau of Air and Waste the following deviations from Permit requirements, by telephone or fax, within three (3) days of discovery of such deviation:

- Unpermitted pollutant releases, excess emissions or opacity exceedances measured directly by CEMS/COMS, by EPA reference methods or by other credible evidence, which are ten percent (10%) or more above the emission limit.
- Exceedances of parameter limits established by your Operating Permit or other Approvals, where the parameter limit is identified by the Permit or Approval as surrogate for an emission limit.
- Exceedances of Permit operational limitations directly correlated to excess emissions.
- Failure to capture valid emissions or opacity monitoring data or to maintain monitoring equipment as required by statutes, regulations, your Operating Permit, or other Approvals.
- Failure to perform QA/QC measures as required by your Operating Permit or other Approvals for instruments that directly monitor compliance.

For all other deviations, three (3) day notification is waived and is satisfied by the documentation required in the subsequent Semi-Annual Monitoring Summary and Certification. Instructions and forms for reporting deviations are found in the Massachusetts Department of Environmental Protection Bureau of Air and Waste Air Operating Permit Reporting Kit, which is available to the Permittee via MassDEP's web site, http://www.mass.gov/dep/air/approvals/aqforms.htm. This report shall include the deviations, and the corrective actions or preventative measures taken.

Deviations that were reported by telephone or fax within 3 days of discovery, said deviations shall also be submitted in writing via the Operating Permit Deviation Report to the regional Bureau of Air and Waste within ten (10) days of discovery. For deviations, which do not require 3-day verbal notification, follow-up reporting requirements are satisfied by the documentation required in the aforementioned Semi-Annual Monitoring Summary and Certification.

26. <u>OPERATIONAL FLEXIBILITY</u>

The Permittee is allowed to make changes at the facility consistent with 42 U.S.C. \$7401, \$502(b)(10) not specifically prohibited by the Permit and in compliance with all applicable requirements provided the Permittee gives the EPA and MassDEP written notice fifteen days prior to said change; notification is not required for exempt activities listed at 310 CMR 7.00: Appendix C(5)(h) and (i). The notice shall comply with the requirements stated at 310 CMR 7.00: Appendix C(7)(a) and will be appended to the facility's Permit. The Permit shield allowed for at 310 CMR 7.00: Appendix C(12) shall not apply to these changes.

27. <u>MODIFICATIONS</u>

(a) Administrative Amendments - The Permittee may make changes at the facility which are considered administrative amendments pursuant to 310 CMR 7.00: Appendix C(8)(a)1, provided they comply with the requirements established at 310 CMR 7.00: Appendix C(8)(b).

(b) Minor Modifications - The Permittee may make changes at the facility which are considered minor modifications pursuant to 310 CMR 7.00: Appendix C(8)(a)2, provided they comply with the requirements established at 310 CMR 7.00: Appendix C(8)(d).

(c) Significant Modifications - The Permittee may make changes at the facility which are considered significant modifications pursuant to 310 CMR 7.00: Appendix C(8)(a)3, provided they comply with the requirements established at 310 CMR 7.00: Appendix C(8)(c).

(d) No Permit revision shall be required, under any approved economic incentives program, marketable permits program, emission trading program and other similar programs or processes, for changes that are provided in this Operating Permit. A revision to the permit is not required for increases in emissions that are authorized by allowances acquired pursuant to the Acid Rain Program under Title IV of the Act, provided that such increases do not require an Operating Permit revision under any other applicable requirement.

28. OZONE DEPLETING SUBSTANCES

This section contains air pollution control requirements that are applicable to this facility, and the United States Environmental Protection Agency enforces these requirements.

- A. The Permittee shall comply with the standards for labeling of products using ozone-depleting substances pursuant to 40 CFR Part 82, Subpart E:
 - All containers containing a class I or class II substance that is stored or transported, all products containing a class I substance, and all products directly manufactured with a class I substance must bear the required warning statement if it is being introduced into interstate commerce pursuant to 40 CFR 82.106.
 - 2) The placement of the required warning statement must comply with the requirements of 40 CFR 82.108.
 - 3) The form of the label bearing the required warning statement must comply with the requirements of 40 CFR 82.110.
 - 4) No person may modify, remove or interfere with the required warning statement except as described in 40 CFR 82.112.
- B. The Permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F, except as provided for motor vehicle air conditioners (MVAC) in Subpart B:
 - 1) Persons opening appliances for maintenance, service, repair or disposal must comply with the required practices of 40 CFR 82.156.
 - 2) Equipment used during the maintenance, service, repair or disposal of appliances must comply with the standards for recycling and recovery equipment of 40 CFR 82.158.
 - 3) Persons performing maintenance, service, repair or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.

- 4) Persons disposing of small appliances, MVACs and MVAC-like appliances (as defined in 40 CFR 82.152) must comply with recordkeeping requirements of 40 CFR 82.166.
- 5) Persons owning commercial or industrial process refrigeration equipment must comply with the leak repair equipment requirements of 40 CFR 82.156.
- 6) Owners/operators of appliances normally containing 50 or more pounds of refrigerant must keep records of refrigerant purchased and added to such appliances pursuant to 40 CFR 82.166.
- C. If the Permittee manufactures, transforms, imports or exports a class I or class II substance, the Permittee is subject to all the requirements as specified in 40 CFR Part82, Subpart A, "Production and Consumption Controls".
- D. If the Permittee performs a service on motor (fleet) vehicles when this service involves ozone-depleting substance refrigerant (or regulated substitute substance) in the motor vehicle air conditioner (MVAC), the Permittee is subject to all the applicable requirements as specified in 40 CFR Part 82, Subpart B, "Servicing of Motor Vehicle Air Conditioners". The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed. The term "MVAC" as used in Subpart B does not include the air-tight sealed refrigeration system used as refrigerated cargo or system used on passenger buses using HCFC-22 refrigerant.
- E. The Permittee shall be allowed to switch from any ozone-depleting substance to any alternative that is listed in the Significant New Alternatives Program (SNAP) promulgated pursuant to 40 CFR Part 82, Subpart G, "Significant New Alternatives Policy Program".

29. PREVENTION OF ACCIDENTAL RELEASES

This section contains air pollution control requirements that are applicable to this facility, and the United States Environmental Protection Agency enforces these requirements.

Your facility is subject to the requirements of the General Duty Clause, under 112(r)(1) of the CAA Amendments of 1990. This clause specifies that owners or operators of stationary sources producing, processing, handling or storing a chemical in any quantity listed in 40 CFR Part 68 or any other extremely hazardous substance have a general duty to identify hazards associated with these substances and to design, operate and maintain a safe facility, in order to prevent releases and to minimize the consequences of accidental releases which may occur.

APPEAL CONDITIONS FOR OPERATING PERMIT

This Permit is an action of MassDEP. If you are aggrieved by this action, you may request an adjudicatory hearing within 21 days of issuance of this Permit. In addition, any person who participates in any public participation process required by the Federal Clean Air Act, 42 U.S.C. §7401, §502(b)(6) or under 310 CMR 7.00: Appendix C(6), with respect to MassDEP's final action on Operating Permits governing air emissions, and who has standing to sue with respect to the matter pursuant to federal constitutional law, may initiate an adjudicatory hearing pursuant to Chapter 30A, and may obtain judicial review, pursuant to Chapter 30A, of a final decision therein.

If an adjudicatory hearing is requested, the facility must continue to comply with all existing federal and state applicable requirements to which the facility is currently subject, until a final decision is issued in the case or the appeal is withdrawn. During this period, the application shield shall remain in effect, and the facility shall not be in violation of the Act for operating without a Permit.

Under 310 CMR 1.01(6)(b), the request must state clearly and concisely the facts which are the grounds for the request, and the relief sought. Additionally, the request must state why the Permit is not consistent with applicable laws and regulations.

The hearing request along with a valid check payable to The Commonwealth of Massachusetts in the amount of one hundred dollars (\$100.00) must be mailed to:

The Commonwealth of Massachusetts Department of Environmental Protection P.O. Box 4062 Boston, MA 02211

The request will be dismissed if the filing fee is not paid unless the appellant is exempt or granted a waiver as described below.

The filing fee is not required if the appellant is a city or town (or municipal agency) county, or district of the Commonwealth of Massachusetts, or a municipal housing authority.

MassDEP may waive the adjudicatory hearing filing fee for a person who shows that paying the fee will create an undue financial hardship. A person seeking a waiver must file, together with the hearing request as provided above, an affidavit setting forth the facts believed to support the claim of undue financial hardship.